

# **DESIGN OF WASTEWATER COLLECTION SYSTEM FOR AL-SAMOU' TOWN**

**BY**

**ISMAEL ZA'AREER      HANI SHAWAR  
KHALED IDAIS**



**CIVIL & ARCHITECTURAL ENGINEERING DEPARTMENT  
COLLEGE OF ENGINEERING AND TECHNOLOGY  
PALESTINE POLYTECHNIC UNIVERSITY**

**HEBRON- WEST BANK  
PALESTINE  
OCTOBER 2007**

# **DESIGN OF WASTEWATER COLLECTION SYSTEM FOR AL-SAMOU' TOWN**

**BY**

**ISMAEL ZA'AREER      HANI SHAWAR  
KHALED IDAIS**

A PROJECT REPORT SUBMITTED IN PARTIAL FULFILLMENT OF THE  
REQUIREMENTS FOR THE DEGREE OF  
BACHELOR OF ENGINEERING  
IN  
CIVIL & ARCHITECTURAL ENGINEERING DEPARTMENT

**SUPERVISED BY**

**Dr. MAJED ABU SHARKH**



**CIVIL & ARCHITECTURAL ENGINEERING DEPARTMENT  
COLLEGE OF ENGINEERING AND TECHNOLOGY  
PALESTINE POLYTECHNIC UNIVERSITY**

**HEBRON- WEST BANK  
PALESTINE**

**OCTOBER 2007**

# **CERTIFICATION**

**Palestine Polytechnic University**

(PPU)

**Hebron- Palestine**

The Senior Project Entitled:

**DESIGN OF WASTEWATER COLLECTION SYSTEM  
FOR AI-SAMOU' TOWN**

**Prepared By:**

**ISMAEL ZA'AREER      HANI SHAWAR  
KHALED IDAIS**

*In accordance with the recommendations of the project supervisor, and the acceptance of all examining committee members, this project has been submitted to the Department of Civil and Architectural Engineering in the College of Engineering and Technology in partial fulfillment of the requirements of the department for the degree of Bachelor of Science in Engineering.*

**Project Supervisor**

**Department Chairman**

**OCTOBER 2007**

## إه نداء

إلى روح والدة ام اسماعيل..... التي توفيت وقت اعداد هذا المشروع .

إلى اقرب من في الوجود إلى نفسي ... والدي الحبيب .

إلى زوج واولاد الاحباء الاعزاء .

إلى أعلى من في الحياة على قلبي ... إخواننا الأعزاء .

إلى المنارات التي أضاءت لي الدرب ... أساتذتي الأجلاء .

إلى رئيس واعضاء بلدية السموع .

إلى رئيس قسم المياه م . د السلامين .

إلى كل اللحظات السعيدة التي قضيناها داخل اسوار هذه الجامعة الغراء .

إلى أرواح كل الشهداء ... إلى فلسطين الإباء .

إلى كل شيء طاهر جميل في هذا الوطن المعطاء .

إلى كل هؤلاء ... أهدي ما جنيت بعناء .

اسماعيل النرعارير

هاني شاور

خالد ادعيس

## **ACKNOWLEDGEMENT**

We would like to express our thanks and gratitude to Allah, the Most Beneficent, the most Merciful who granted us the ability and willing to start and complete this project. We pray to his greatness to inspire us the right path to his content and to enable us to continue the work started in this project to the benefits of our country.

We wish to express our deep and sincere thanks and gratitude to Palestine Polytechnic University, the Department of Civil & Architectural Engineering, College of Engineering & Technology. We wish to express our thanks to Dr. Majed Abu-Sharkh, for a valuable help, encouragement, supervision and guidance in solving the problems that we faced from time to time during this project.

We can find no words to express our sincere, appreciation and gratitude to our parents, sisters and brothers, for their endless support and encouragement, we are deeply indebted to you and we hope that we may someday reciprocate it in someway.

**Work Team**

## **ABSTRACT**

# **DESIGN OF WASTEWATER COLLECTION SYSTEM FOR AL-SAMOU TOWN**

**By:**

**ISMAEL ZA'AREER      HANI SHAWAR  
KHALED IDAIS**

*Palestine Polytechnic University*

There is no wastewater collection system at present in Al-samou' town. The sewage from residential and public buildings in the area is drained to cesspits. These have become clogged with time and require frequent emptying. The continued use of cesspits with the increase in population will cause environmental and health problem, and may create contamination of the underground water aquifer. Furthermore, emptying cesspools constitutes an offensive odor nuisance to the population. On the other hand, emptying the vacuum trunks in the nearby wadi causes negative impacts on the visual landscape.

In reference to above description of the existing situation, there is a clear need of project in order to improve the sanitary level in Al-samou' town. The first step is serving the city with wastewater collection system. So, the main objective of this

project is to design wastewater collection network for Al-samou' town of the Hebron district.

The present study considered the annual population growth and their water consumption for the coming 25 years that will be the design period, along with the commercial and industrial development in the area. The necessary hydraulic calculation needed for the design of the main trunks was carried out by simple calculation.

The results of the study show that wastewater disposal in Al-samou' area causes problems to the peoples; subsequently there is a big need for immediate steps for construction of the proposed wastewater collection system. Gravity flow sanitary sewer was proposed for most of Al-samou' areas .

## **TAPLE OF CONTENTS**

<b>Subject</b>	<b>Page</b>
<b>TITLE</b>	i
<b>CERTIFICATION</b>	ii
<b>DEDICTION</b>	iii
<b>ACKNOWLEDGMENT</b>	iv
<b>ABSTRACT</b>	v
<b>TABLE OF CONTENTS</b>	vii
<b>LIST OF FIGURES</b>	x
<b>LIST OF TABLES</b>	xii
<b>CHAPTER ONE: INTRODUCTION</b>	<b>1</b>
1.1 Background	2
1.2 Problem Definition	2
1.3 Purpose of Project	3
1.4 Scope of the Work	4
1.5 Stages of the Project	5
1.6 Organization of the Report	7
<b>CHAPTER TWO: CHARACTEEISTICS OF THE PEOJECT AREA</b>	<b>9</b>
<b>2.1 Al-samou' Town</b>	<b>10</b>
2.2 Physical Features	10
2-2-1 Topography	10
2-2-2 Climate	13
2-2-2-1 Rainfall	13
2-2-2-2 Temperature	13
2-2-2-3 Relative humidity	14



2-2-2-4 Winds	15
2.3 Demographic Features	15
2-3-1 Population	15
2-3-2 Population density and zoning	15
2.4 Water Supply	16

### **CHAPTER THREE: DESIGN AND PLANNING CRITERIA** 18

3.1 Introduction	19
3.2 Population Forecast	19
3-2 -1 Introduction	19
3-2 -2 Population projection	20
3-2 -3 Population density	22
3.3 Future Water Consumption	24
3-3 -1 Introduction	24
3-3 -2 Projected water consumption	25
3.4 Design Parameters	26
3-4 -1 Flow rate projections	26
3-4 -2 Hydraulic design	28
3-4 -3 Minimum and maximum velocities	29
3-4 -4 Pipes and sewer	29
3-4 -5 Manholes and covers	29
3-4 -6 Sewer slope	30
3-4 -7 Depth of sewer pipe	30
3-4 -8 Design period	30
3.5 Design and Planning Assumptions	31

### **CHAPTER FOUR: ANALYSIS AND DESIGN** 33

4.1 Introduction	34
4.2 Layout of the System	34
4.3 Design Computations	36

4-3 -1 Design example	36
4-3 -2 Solution	37
4.4 The Proposed Wastewater Collection System	40
4.5 Profiles of Sewer	41
<b>CHAPTER FIVE: BILL OF QUANTITY</b>	42
Bill of Quantity	43
<b>CHAPTER SIX: CONCLUSIONS</b>	44
Conclusions	45
<b>REFERENCES</b>	46
<b>APPENDIX-A CALCULATIONS TABLES</b>	47

## LIST OF FIGURES

<b>Figure No.</b>	<b>Description</b>	<b>Page</b>
2-1	Location Map of 'AL-samou' Town	11
2-2	Aerial Map of 'AL-samou' Town	12
4-1	General Layout of Proposed Wastewater Collection System for 'AL-samou' Town	42
A-1	Profile of Line A (MH1-MH7)	1
A-2	Profile of Line A (MH7-MH13)	2
A-3	Profile of Line A (MH13-MH19 )	3
A-4	Profile of Line A (MH19-MH25)	4
A-5	Profile of Line A (MH25-MH31)	5
A-6	Profile of Line A (MH31-MH37)	6
A-7	Profile of Line A (MH37-MH43)	7
A-8	Profile of Line A (MH43-MH49)	8
A-9	Profile of Line A (MH49-MH55)	9
A-10	Profile of Line A (MH55-MH61)	10
A-11	Profile of Line A (MH61-MH67)	11
A-12	Profile of Line A (MH67-MH73)	12
A-13	Profile of Line A (MH73-MH79)	13
A-14	Profile of Line A (MH79-MH85)	14
A-15	Profile of Line A (MH85-MH91)	15
A-16	Profile of Line A (MH91-MH96)	16
B-1	Profile of Line B (MH1-MH8)	17
B-2	Profile of Line B (MH8-MH15)	18
B-3	Profile of Line B (MH15-MH22)	19
B-4	Profile of Line B (MH22-MH29)	20
B-6	Profile of Line B (MH29-MH36)	21
B7	Profile of Line B (MH36-MH38)	22

<b>Figure No.</b>	<b>Description</b>	<b>Page</b>
C-1	Profile of Line C (MH1-MH8)	23
C-2	Profile of Line C (MH8-MH15)	24
C-3	Profile of Line C (MH15-MH22)	25
C-4	Profile of Line C (MH22-MH29)	26
C-5	Profile of Line C (MH29-MH36)	27
C-6	Profile of Line C (MH36-MH43)	28
C-7	Profile of Line C (MH43-MH50)	29
C-8	Profile of Line C (MH50-MH54)	30
D-1	Profile of Line D (MH8-MH15)	31
D-2	Profile of Line D (MH8-MH15)	32
D-3	Profile of Line D (MH8-MH15)	33
D-4	Profile of Line D (MH1-MH8)	34
D-5	Profile of Line D (MH8-MH15)	35
E-1	Profile of Line E (MH1-MH8)	36
E-2	Profile of Line E (MH8-MH15)	37
E-3	Profile of Line E (MH15-MH22)	38
E-4	Profile of Line E (MH22-MH24)	39
G-1	Profile of Line G (MH1-MH8)	40
G-2	Profile of Line G (MH8-MH15)	41
G-3	Profile of Line G (MH15-MH22)	42
G-4	Profile of Line G (MH22-MH29)	43
G-5	Profile of Line G (MH29-MH34)	44

## LIST OF TABLES

<b>Table No.</b>	<b>Description</b>	<b>Page</b>
4.1	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line A	45
4.2	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line B	50
4.3	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line C	52
4.4	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line D	55
4.5	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line E	57
4.5	Sanitary Sewer Design Calculation Sheet for Al-Samou' Town line G	59

# **CHAPTER ONE**

## **INTRODUCTION**

- 1.1 BACKGROUND**
- 1.2 PROBLEM DEFINITION**
- 1.3 PURPOSE OF PROJECT**
- 1.4 SCOPE OF THE WORK**
- 1.5 STAGES OF THE PROJECT**
- 1.6 ORGNIZATION OF THE REPORT**

## **CHAPTER ONE**

### **INTRODUCTION**

#### **1.1 Background**

Currently, there are no public wastewater collection and treatment facilities serving most of rural areas in the West Bank. And due to the lack of sewage collection and treatment system, large areas in the West Bank and ground water aquifer are being contaminated by raw sewage. This contamination will have long-term impact on agricultural land and creates health hazards when utilized for human consumption. For the above mentioned reasons, serious and major steps should be taken to collect, dispose and treat the wastewater before discharging it in open environment.

#### **1.2 Problem Definition**

More than 60% of the water used for domestic purposes and industry turn into sewage requiring purification (treatment) for reuse in irrigation or alternative disposal. Contrarily, if wastewater not treated and not disposed of, sewage may contaminate sources of drinking water. In Palestine, water-borne diseases are very commonplace.

In the West Bank, no piped wastewater disposal system is available in most of the rural areas. Wastewater from individual residence is discharge directly into

subsurface pits, allowing the wastewater to seep into the surrounding soil and percolate into the underlying aquifer causing ground water pollution. At the same time, the existing treatment plants are heavily overloaded and poorly operated and maintained.

Al-Samou' town like other towns in West Bank has no sewage facility and the people are using latrines, cesspits and septic tanks for the disposal of wastewater. These latrines and cesspits are deteriorating and they are in very bad condition, adding to this the increasing in water consumption and consequently increasing in wastewater production, resulting in overflow from the cesspits and excessive recharges of ground water in Al-Samou' area.

In view of this bad condition, and since there is no sewerage exist, along with the fast increase in the environmental and health problems, an evaluation and design of wastewater collection system study become a pressing necessity so as to solve all the problems that were mentioned above. This project which includes evaluation and design will consider the annual growth of the people and their water consumption for the coming 25 years, which will be the design period, along with the commercial and industrial development in the area.

### **1.3 Purpose of Project**

The overall purpose of this project is to investigate and evaluate wastewater collection and treatment processes along with conceptual designs that are suitable



for Al-Samou' town. More specifically the main purposes of this project may be classified as follow:

1. Display the current situation of wastewater disposal in **Al-Samou'** town.
2. Define the types of sewage facilities and their locations that will need to be constructed.
3. Propose wastewater collection system for the town and design the main trunks of the proposed sewerage collection network.
4. Estimate the cost for construction of the collection network.

The project will help in reducing the threat to the environment, water and land resources and to the health of the people living in **Al-Samou'** town.

#### **1.4 Scope of the Work**

The scope of work of this project is to evaluate and develop preliminary conceptual design for sewer networks for **Al-Samou'** town of the Hebron district. The preliminary design will incorporate a variety of design criteria including: investigation of site, site suitability, design alternatives, environmental consideration and cost estimate.

#### **1.5 Stages of the Project**

The project consists of six phases, which are proposed to be completed in accordance with time schedule shown in (Table 1.1). The description of each of the six phases of the project and tasks involved is listed below:

**Table (1.1): Phases of the Project with their Expected Duration**

Phase No.	Title	Duration								
		2/07	3/07	4/07	5/07	6/07	7/06	8/07	9/07	10/07
One	Collection and Analysis of Al-Samou'.	■	■	■						
Two	Performing the Surveying Works.			■	■					
Three	Design of the Sewage Network.				■	■	■			
Four	Preparing Plan Drawings and Profiles.				■	■	■			
Five	Preparing Bill of Quantities and Cost Estimates.						■	■		
Six	Writing the Report.						■	■	■	■

**Phase 1: Collection and Analysis of Data**

During this phase, available data and information were collected from different sources. Moreover, many site visits to the project area were undertaken. First phase included the following tasks:

1. Collection of aerial and topographical maps of the area.
2. Collection, analysis and augmentation as necessary data on population, land use, zoning, water consumption and environmental conditions.
3. Projection on land use development, population growth and density, and economic growth (industrial, commercial, etc).

4. Determination of the wastewater quantities and projection of wastewater production in year 2032.

### **Phase 2: Perform the Surveying Works**

The tasks which were performed in the second phase are:

1. Determination of the coordinates of some points in the area which help in preparing the necessary maps for the project.
2. Evaluation of the contour maps and matching it with actual ground levels.
3. Performing and selecting topographic survey for the sewage network.

### **Phase 3: Design of the Sewage Network**

During the third phase, the areas to be served by sewage were defined, the layout was established, and the necessary hydraulic calculations needed for the design of one of the main trunks were carried out. The tasks, which were performed in this phase, are:

1. Define the area to be served by sewerage and establish the boundaries.
2. Establish a system layout which includes the areas that are going to be served, existing streets and roads, topography ..... etc.
3. Establish the main catchments areas and routes of the sewer.
4. Prepare a design criterion that meets the sewage contribution and flow for the entire area through the year 2032.
5. Do the necessary hydraulic calculation and find out the sewers diameter.

**Phase 4: Preparing Plan Drawings and Profiles**

Plan drawings and profiles with appropriate scales for the wastewater collection system were prepared.

**Phase 5: Preparing Bill of Quantities and Cost Estimates**

After finishing the design calculation of the main trunks, the research team prepared bill of quantities and estimate the cost of the project.

**Phase 6: Writing the Report**

Upon the completion of the work, one final report was written and submitted to the Department of Civil and Architectural Engineering at Palestine Polytechnic University.

**1.6 Organization of the Report**

The study report has been prepared in accordance with the objectives and scope of work. The report consists of five chapters.

The **first chapter** entitled “**Introduction**” outlines the problem, purpose of project, scope of the work and phases of the project.

**Chapter two** entitled “**Characteristics of the Project Area**” talks about **Al-Samou'** Town, physical features, demographic features and water supply.

**Chapter three** entitled “**Design and Planning Criteria**” presents information about population and their densities, the actual water consumption, land use, and design criteria applicable to the sewerage networks.

**Chapter four** entitled “**Analysis and Design**” deals with the layout of the system, design calculation of the main trunks, and the profiles of the lines designed.

**Chapter five**, entitled “**Bill of Quantities**” deals with the quantities needed to complete the design system.

**Chapter six**, which is the last chapter, entitled “**Conclusions**” summarized the project into briefly notes.

## **CHAPTER TWO**

### **CHARACTEEISTICS OF THE PEOJECT AREA**

- 2.1 Al-Samou' Town**
- 2.2 PHYSICAL FEATURES**
- 2.3 DEMOGRAPHIC FEATURES**
- 2.4 WATER SUPPLY**

## CHAPTER TWO

### CHARACTERISTICS OF THE PROJECT AREA

#### 2.1 Al-Samou' Town

Al-Samou' town is located 23 kilometers to the south of the city of Hebron. The total land area of the town is about 18,000 dunams.

#### 2.2 Physical Features

A summary of physical features of the study area based on available data is presented below.

##### 2.2.1 Topography

The study area consists of mountains with steep slopes and few plain areas located center of the city. The city is about 750 meters above mean sea level (AMSL). The area of city center is located between 750 m and 700 m AMSL. The built-up area of town spreads between the elevations of 750 m to 650 m AMSL.

---




Fig.2.1-Location Map of Al-Samou' Town

### 2.2.2 Climate



Al-Samou' city has a typical Mediterranean climate with two main seasons: the dry season from May to October and the rainy season from November to April, spring and autumn are short and have special characteristics. The climatological data presented in the following paragraphs were obtained from the survey carried out by Meteorological Station which is located at the elevation of (+750) m AMSL.

### **2.2.2.1 Rainfall**

The average annual rainfall in Al-Samou' Town for the last five years is approximately (300) mm, of which about 98 percent falls between October and April. The maximum monthly rainfall recorded in January and amounted (100) mm. Table (2.1) shows the monthly rainfall during the period 2000-2005 at the Al-Samou' Meteorological Station.

### **2.2.2.2 Temperature**

The temperature range is characterized by considerable variations between summer and winter. The mean temperature values at the Al-Samou' Metrological Station for the period 2000 – 2005 are given in Table 2.1. The following characteristics values are shown:

- Mean maximum temperature: 20 °C
- Mean minimum temperature: 11 °C
- Maximum temperature recorded 3.96 °C
- Minimum temperature recorded 27.23 °C

**Table2.1: Meteorological Conditions at Al-Samou Town Weather Station for (2000-2005)**

<b>Month</b>	<b>Rainfall (mm)</b>	<b>Maximum Temperature (°C)</b>	<b>Minimum Temperature (°C)</b>		
<b>September</b>	0.0	10.25	3.96		
<b>October</b>	5	11.58	4.70		
<b>November</b>	30	14.57	6.46		
<b>December</b>	90	19.59	9.93		
<b>January</b>	100	23.63	13.23		
<b>February</b>	75	25.90	15.77		
<b>March</b>	30	27.16	17.04		
<b>April</b>	5	27.23	16.96		
<b>May</b>	0.0	25.97	15.94		
<b>June</b>	0.0	23.18	14.02		
<b>July</b>	0.0	17.50	9.90		
<b>August</b>	0.0	12.09	5.62		
<b>Total</b>	<b>335.0</b>				

### 2.2.2.3 Relative humidity

Al-Samou' situated at a considerable distance from the sea in a mountains region on the outskirts of the desert. Al-Samou' has low values of relative humidity as compared to those in the plain. As shown in Table 2.1 the relative humidity in Al-Samou' city ranges from 48% - 72%, it reaches the maximum value in August.

#### **2.2.2.4 Winds**

The directions and velocities of wind vary depending on the season of the year. In winter, the wind blows in the morning from the southwest, around noon from southwest and west, and at night from west and northwest. In summer, a north easterly wind blows all day long. According to the data obtained from the Al-Samou' Metrological Station, the average wind velocity in winter is about 12 m/s and in summer 8 m/s.

### **2.3 Demographic Features**

#### **2.3.1 Population**

The population within the municipal boundary has been determined according to a census carried out by the Palestinian Central Bureau of Statistic (PCBS) on the night of 9/10 December 1997.,. 17.000 .

#### **2.3.2 Population density and zoning**

According to data obtained from Municipality, the town of Al-Samou' is subdivided into planning zones according to the land use. The zones are residential, agricultural, commercial and industrial. Highest population density will remain almost constant as it is already saturated while the other residential zones represent the attractive areas for the citizens.

## 2.4 Water Supply

The main water source for Al-Samou' town is from Al-Semya well, which is owned and operated by Water Authority. The average water quantity which is supplied to Al-Samou' is around ( 384 )cubic meters per day. Table 2.2 represents the quantities of water supplied and billed for the last three years.

**Table 2.2: Quantities of Water Supplied and Billed for Al-Samou' Town**

Year	Water Supplied (m <sup>3</sup> )	Water Billed (m <sup>3</sup> )
2004	140000	32000
2005	140000	35000
2006	140000	38000

As presented in Table 2.2, the unaccounted for water in the distribution network is about 35-51% of the quantity of water pumped into the network.

Due to insufficient water quantities pumped into the network, the people of Al-Samou' rely on rainwater harvesting as an additional water supply source. Almost all new houses have underground cisterns built at the time of construction. It is estimated that around 50% of houses have individual cisterns with an average capacity of 50 m<sup>3</sup> per each.

## **CHAPTER THREE**

### **DESIGN AND PLANNING CRITERIA**

- 3.1 INTRODUCTION**
- 3.2 POPULATION**
- 3.3 PROJECTED WATER CONSUMPTION**
- 3.4 Al-Samou' MASTER PLAN**
- 3.5 DESIGN PARAMETERS**

## **CHAPTER THREE**

### **DESIGN AND PLANNING CRITERIA**

#### **3.1 Introduction**

In the previous chapters, the problem of the study area has been defined and the objectives of the project have been listed. The characteristics of the project area (Al-Samou' Town) have been described. Wastewater collection systems and design of sewer system were explained. In this chapter, basis for planning and design will be discussed including present population, population forecasting, projected water consumption, town structure plan, and the design and planning criteria of the project.

#### **3.2 Population Forecast**

##### **3.2.1 Introduction**

The ideal approach for population forecasting is by the study and use of previous census records, which cover along period. The longer the period, and the more comprehensive the census data, the more accurate will be the results, which will be obtained. In the analysis of these data, demographical, economical and political factors should be considered in order to develop a method of forecasting which will predict the expected growth rate, future population and its distribution in the different zones of the area under consideration.

In Al-Samou' Town, there is great uncertainty in the political and economical future. Additionally, there were no accurate population data since the occupation of the West Bank in 1967, until 1997 when the Palestinian Central Bureau of Statistic (PCBS) conducted comprehensive census covering the West Bank and Gaza Strip. The final results of this census show that the total population of Al-Samou' Town is 17000 inhabitants.

Due to the unstable condition of the area during the last 50 years, it would be very difficult to develop a statistical interpretation to extrapolate future population. Some reasonable assumptions have, therefore, been made to project the future population of Al-Samou' Town over the next 25 years.

### **3.2.2 Population projection**

Prediction of the future population of Al-Samou' Town is very difficult due to the lack of reliable historic data, and the political uncertainties, which will greatly influence future social and economic development. At the same time, the available data on past population growth do not constitute a reliable basis for projecting the future population growth in Al-Samou' town.

The base for the forecast is the 1997 population for Al-Samou' town obtained from PCBS of 17000 inhabitants. The annual growth rates for the next twenty years are also obtained from the PCPS and they are presented in Table 3.1.

To calculate the population at the end of the design period (year 2032), a geometric increase is assumed, represented by the following equation:

$$P = P_0 * (1 + r)^n \quad (3.1)$$

Where, P is the future population, P<sub>0</sub> is the present population, r is the annual population growth rate, and n is the period of projection.

Using the above assumption and equation, Table 3.1 presents the population projection up to the design horizon of 2030. The data show that the population of Al-Samou' town is estimated to be 42,500 in year 2030.

**Table 3.1: Population Forecast for Al-Samou Town.**

<b>Year</b>	<b>Annual Growth Rate(%)</b>	<b>Population</b>
<b>2005</b>	<b>4.24</b>	<b>23000</b>
<b>2010</b>	<b>3.73</b>	<b>27600</b>
<b>2015</b>	<b>2.51</b>	<b>31500</b>
<b>2020</b>	<b>2.26</b>	<b>35000</b>
<b>2030</b>	<b>2.00</b>	<b>42500</b>



### 3.2.3 Population Density

When determining the density of population, it is either related to the total municipal area (gross density) or to the built-up area only (net density). The gross density related to the municipal area includes large industrial areas, agricultural areas, un-built areas, public parks, large water surfaces, forests ...etc. The net density is related to the built up urban area, but it includes small-scale industries, schools, public and commercial buildings, and roads.

Sewer design, however, is based on the net densities of population, because the provision of sewers is limited to the built-up areas. The gross density are also used in the design of sewer system. The net density of population varies considerably from district to district. For Al-Samou' town the net densities it varies between 18.4 and 185 capita per hectare. The gross density for the same areas varies between 1.5 and 5.8 per hectare.

The Al-Samou' municipality studies the population densities for different areas of Al-Samou' based on the town study master plan, which serves for incisive building permits. The values of gross and net population densities are given in Table 3.2 along with the names of district and areas.

**Table 3.2: The Present and Future Population and Densities for Different Area of Al-samou' Town**

Area Name	Current Pop.	Area (ha)	Built Up Area(ha)	Net Pop. Density (C/ha)	Future Pop.	Future Built Up Area(ha)	Net Future Pop. Density (C/ha)
Biar –Elqanan Asail	7878	371.5	25	22	14558	100	117
Marah El-hattab- Abu sae'l	4428	71.24	33	63	8182	32	126
Al-omary-Main Street	1573	25.3	23	64	2908	25.3	115
Khadoor-Am-Ennewar	4399	69.8	15	62	8128	45	137
Wad shemo'on-El-husseiny	4721	76	32	73	8723	24	156

In present project, the gross population densities are used in design of wastewater collection system for Al-Samou' town, which give the same results if we use the net densities.

### 3.3 Future Water Consumption

#### 3.3.1 Introduction

Water consumption is not constant, yearly, monthly, weekly, daily and hourly variations in water consumptions are observed. Certain dry years cause more consumption. In hot months water is consumed in drinking, bathing, and watering

lawns and gardens. On holidays and weekends the water consumption may be high. Even during day water use varies with high use during morning hours and close to noon and low use at night. Maximum daily demand or maximum daily consumption usually occurs during summer months. The ideal approach to assess the existing and future per capita water consumption is by analyzing and extrapolating the available record on water consumption and demand in conjunction with the expected social and economical development. This approach can be adopted in areas having continuous supply systems where reliable information about population, population distribution and demand are known. There are problems adopting this approach for Hebron area including Al-Samou' Town due to insufficient data and also the intermittent water supply.

Restrictions on the Palestinian use of the annual ground water resources of the West Bank led to limited quantities availability of water and due to this condition; the average consumption of water in Al-Samou' Town for all purposes does not exceed 36.5 cubic meters per capita per year. Given these circumstances, the approach to determine per capita water consumption depends on the analysis of the existing information. The existing per capita consumption has already been assessed at (100 liter/capita. day).

### **3.3.2 Projected water consumption**

The present average consumption of water for domestic use in Al-Samou Town does not represent the present and actual demand of water. So, it is estimated the water consumption in Al-Samou' will dramatically increase during the next few years, due to several ongoing water projects, which are:

1. Drilling new production wells;
2. Upgrading the existing water supply system;
3. Rehabilitation of the existing network; and
4. Detecting network leakage as well as dealing with institutional development of water sector and tariff structures.

The Al-Samou Municipality has estimated the existing per capita water consumption at about 100 l/c.d, and the rate of increase in the annual water consumption per capita to 1.5 %. It is estimated that the per capita water supply will be 143 l/c.d including the physical losses in the year 2030. Assuming the physical losses at about 15%, the per capita water consumption will be around 120 l/c.d. It should be noted that the figure includes commercial and industrial consumption. The estimated per capita water consumptions for the year 2005, 2010, 2015, 2020 and 2030, is presented in Table

3.3.

**Table 3.3: Forecast Water Demand for Al-Samou Town.**

Year	Population	Water Demand (m <sup>3</sup> /year)		Water Demand(l/c.d)
		Per Capita	Total	
2005	23000	36.5	730000	100
2010	27600	39.42	1087992	108
2015	31500	42.34	1333710	116
2020	35300	45.63	1610739	125
2030	42500	52.20	2218500	143

It may be noted from Table 3.3 that the projected water consumption for the design period (year 2030) is 143 liter per capita per day. And as mentioned earlier if the losses are 15% the per capita water consumption will be 120 liter per capita per day. This figure is used in the design of wastewater.

### 3.4 Design Parameters

#### 3.4.1 Flow rate projections

The total wastewater flow in sanitary sewers is made up of two components:

(1) Residential. (2) Infiltration. Sanitary sewers are designed for peak flows from residential and peak infiltration allowance for the entire service area. The flow rate projections are necessary to determine the required capacities of sanitary sewers.

These projections will be based on:

1. Population: Future population at the end of design period should be estimated.  
The estimated population of Al-Samou' town in the year 2030 is 42500 inhabitants.
2. The present domestic water consumption and future consumption.
3. The percentage of water going to the sewer: In general, the average wastewater flow may vary from 60 to 90 percent of the water used in the community. A value of 80 percent has generally been agreed upon by all the authors of earlier projects in the West Bank and other locations under similar conditions.
4. The service connection percentage: The percentage of houses that will be served by sewers will depend on the nature of the habitat in the catchments area considered and of the design period. It has been assumed that the service connections will increase, to full coverage for the urban population in year 2032.
5. The uncontrolled inflow and infiltration: Infiltration is the entrance to the collection system of water from outside sources such as groundwater. Inflow is the entrance to the collection system of runoff during a rainfall event. Infiltration depends mainly on the state of the network; the depth at which it is buried and the groundwater elevations. Most of the sewers to be laid will be new and the ground water elevations in the area are low. Ground water infiltration seems then to be not significant. The network will be designed to avoid rainwater inflow. However, there will always be cases of manhole leaks, loose joints and private individuals who link up their rainwater pipes to the sewerage network. Given the difficulty of accurately estimating these parameters and according to previous studies and data

of another area under similar conditions, a mean discharge increase of liter per second per hectare will be applied when dimensioning the sewerage system.

6. The peak coefficient: In general, this coefficient increases when the rate of connected population decrease, for example when the flow rate is weak. In the other hand, when the connected population is important, the variation around a mean discharge is weaker. As there are few field investigations conducted in the study area to estimate this factor; it will be determined from the practice and experience of the designer. The following relation has been used commonly by the designer and gives satisfactory results:

$$P_f = 1.5 + 2.5 / \sqrt{q} \quad (3.2)$$

Where,  $q$  (in l/s) is the daily average flow rate of the network branch under consideration and  $P_f$  is the peak factor.

Using these assumptions, the flow rate projections were evaluated for the study area (Al-Samou' town).

### 3.4.2 Hydraulic design

As mentioned earlier and according to usual practice, the sewers will be designed for gravity flow using Manning's formula:

$$V = 1/n R^{2/3} S^{1/2} \quad (3.3)$$

Depending on pipe materials, the typical values of  $n$  are:

- Reinforced Concrete (RC)  $n = 0.013$
- Polyvinyl Chloride (PVC)  $n = 0.011$

- Ductile Iron:  $n = 0.013$

- Asbestos Cement:  $n = 0.012$

### **3.4.3 Minimum and maximum velocities**

For a circular sewer pipe, the velocity at half-depth is equal to the velocity at full-depth. To prevent the settlement of solid matter in the sewer, the literature suggested that the minimum velocity at half or full depth – during the peak flow period – should not be less than 0.6 m/s, but point out that the minimum self cleansing velocity of 1.0 m/s is to be preferred wherever this is practicable. Usually, a maximum sewer velocity are limited to about 3 m/s in order to limit abrasion and avoids damages which may occur to the sewers and manholes due to high velocities.

### **3.4.4 Pipes and sewers**

i) Necessary because some large objects such as scrub brush, sometimes gets into sewers. Experience indicates a minimum diameter of 200 mm (8 inch) for sewer pipes. For house connections, smaller sizes may be used.

ii) Pipe Materials: different pipe materials may be recommended for the sewers.

1. Polyvinyl chloride PVC, vitrified clay VCP or polyethylene PE material for small size pipes (approximately up to the size 400 mm in diameter).

2. Centrifugal cast reinforced concrete pipes may be used for larger diameter.



#### **3.4.5 Manholes and covers**

Manholes should be located at changes in size, slope direction or junction with secondary sewer. Manholes spacing generally does not exceed 60 m and should never be greater than 100 m except in sewers which can be walked through gravity. The minimum cover over sewer line will be of 1.5 m, for the buried section.

#### **3.4.6 Sewer slope**

For a circular sewer pipe, the slope must be between the minimum and maximum slope, the minimum and maximum slope is determined from minimum and maximum velocity. Generally the natural ground slope is used because it is the technical and economic solution, the solution is therefore recommended.

#### **3.4.7 Depth of sewer pipe**

As mentioned earlier, the depth of sewers is generally 1-2 m below the ground surface. Depth should be enough to receive the sewage by gravity, avoid excessive traffic loads, and avoid the freezing of the sewer. It is recommended that the top of sewer should not be less than 1 m below basement floor.

#### **3.4.8 Design period**

Sewers are designed on estimated future flows at the end of a design period. So the design period is thus the length of time throughout which the capacity of a sewer will be able to cope with the expected flows and may be assumed at:

1. Drains (concrete): 20 – 30 years.
2. Sanitary sewers: 25 – 30 years.

Buildings: 25 – 30 years.

The design period adopted for this project is 25 years.

### 3.5 Design and Planning Assumptions

The design and planning assumptions used in this project are as follow:

1. Design period 25 year (from 2007-2032).
2. Present (2007) population of municipality of Al-Samou' town is 23000 capita.
3. The growth rate will be 2%-4.5%.
4. The existing per capita water consumption has been assessed 100 l/c.d.
5. Total administrative area of municipality of Al-Samou' town 18,000 dounm.
6. Future 2030 population of Al-Samou' town 42000 capita.
7. Per capita water consumption by 2030 will reaches 120 l/c.d.
8. The wastewater production is about 80% of their water consumption.
9. Formula to be used in design of sewers :(Manning formula)

$$V=(1/n)* R^{2/3} *S^{1/2} \quad (3.3)$$

10. Minimum velocity 0.6 m/sec.
11. Maximum velocity 2.5-3.5 m/sec.
12.  $h/D = 0.5$  for main trunks.
13. Maximum manhole spacing 50 m for main trunk.

14. Minimum pipe diameter = 8 inch (200 mm)
15. Infiltration rate 20 % of average domestic wastewater.
16. Peak factor determine by equation

$$P_f = 1.5 + (2.5 / \sqrt{q}) \quad (3.2)$$

17. Depth of sewer pipe: Minimum covers not less than 1.5 from the crown.
18. Maximum slope  $S_{max} = 0.015$ .
19. Minimum slope  $S_{min} = 0.005$ .

## **CHAPTER FOUR**

### **ANALYSIS AND DESIGN**

- 4.1 GENERAL**
- 4.2 LAYOUT OF THE SYSTEM**
- 4.3 DESIGN COMPUTATIONS**
- 4.4 PROFILES OF SEWERS**

## **CHAPTER FOUR**

### **ANALYSIS AND DESIGN**

#### **4.1 Introduction**

In this project, an attempt is made to evaluate and design wastewater collection system for Al-Samou' town, and develop a future plans for construction of the collection system, corresponding to population growth and the water consumption and subsequently the wastewater production from different sources in the future, in order to reduce the problem causes by the disposal of raw wastewater in the area. In this chapter, the layout of the system established is presented, and the computation procedures and tables are given along the drawings of layout and profiles for all the lines designed.

#### **4.2 Layout of the System**

The first step in designing a sewerage system is to establish an overall system layout that includes a plan of the area to be sewered, showing roads, streets, buildings, other utilities, topography, soil type, and the cellar or lowest floor elevation or all buildings to be drained. Where part of the drainage area to be served is undeveloped and proposed development plans are not yet available , care must be taken to provide adequate terminal manholes that can later be connected to the system constructed serving the area .

In establishing the layout of wastewater collection system for Al-Samou' area, the following basic steps were followed:

1. Obtain a topographic map of the area to be served.
2. Locate the drainage outlet. This is usually near the lowest point in the area and is often along a stream or drainage way. In Al-Samou' area, the lowest point is in the western part of the town.
3. Sketch in preliminary pipe system to serve all the contributors.
4. Pipes are located so that all the users or future users can readily tap on. They are also located so as to provide access for maintenance and thus are ordinarily placed in streets or other rights-of-way.
5. Sewers layout is followed natural drainage ways so as to minimize excavation and pumping requirements. Large trunk sewers are located in low-lying areas closely paralleling streams or channels.
6. Establish preliminary pipe sizes. Eight inches pipe size (usually the minimum allowable) can serve several hundred residences even at minimal grades.
7. Revise the layout so as to optimize flow-carrying capacity at minimum cost. Pipe lengths and sizes are kept as small as possible, pipe slopes are minimized, and followed the ground surface slope to minimize the depth of excavation, and the numbers of appurtenances are kept as small as possible.
8. The pumping is avoided across drainage boundaries. Pumping stations are costly and add maintenance problems.

The final layout of wastewater collection system for Al-Samou' town is illustrated in Figure 4.1.

### 4.3 Design Computations

The detailed design of sanitary sewers involves the selection of appropriate pipe sizes and slopes to transport the quantity of wastewater expected from the surroundings and upstream areas the next pipe in series, subject to the appropriate design constrains. The design computations and procedures for Al-Samou' Sanitary sewers are illustrated in the design example given below.

#### 4.3.1 Design example: Design a gravity flow sanitary sewer

Design a gravity flow trunk sanitary sewer for the area from the old city center to outfall (line A) shown in Figure 4.1. Assume that the following design criteria have been developed and adopted based on an analysis of local conditions and codes.

1. For design period use 25 years as a design period.
2. For population growth use 2%-4%.
3. For water consumption uses 100 l/c.d, for the current use and 120 l/c.d, for the future use. The wastewater calculates as 80% of the water consumption.
4. For infiltration allowance use 20% of the domestic sewerage flow.
5. Peaking factor depending on the formula :

$$Pf = 1.5 + (2.5/\sqrt{q}). \quad (3.2)$$

6. For the hydraulic design equation use the Manning equation with a value of 0.015.
7. Minimum pipe size: the building code specifies 200 mm (8 in) as the smallest pipe permissible foe this situation.
8. Minimum velocity: to prevent the deposition of solids at low wastewater flows, use minimum velocity of 0.6 m/s during the peak flow conditions.
9. The minimum cover depth over the top of the sewer is 1.5 m.

### 4.3.2 Solution

1. Lay out the trunk sewer. Draw a line to represent the proposed sewer (Figure 4.1).
2. Locate and number the manholes. Locate manholes at (1) change in direction, (2) change in slope, (3) pipe junctions, (4) upper ends of sewers, and (5) intervals from 50 to 70 m or less. Identify each manhole with a number.
3. Prepare a sewer design computation table. Based on the experience of numerous engineers, it has been found that the best approach for carrying out sewer computations is to use a computation table. The necessary computations for the sanitary sewer are presented in Table 4.1. The data in the table are calculated as follow:
  - a. The entries in columns 1 and 2 are used to identify the line numbers and location.
  - b. The entries in columns 3 through 5 are used to identify the sewer manholes, their numbers and the spacing between each two manholes.
  - c. The entries in columns 6 and 7 are used to identify the sewered area, column 6 shows the incremental sewered area in hectare, and column 7 shows the cumulative area.
  - d. The Future population (year 2032) including population density, incremental population, and cumulative total population are entered in columns 8, 9, and 10 respectively. The population density (person/ha) in column 8 is obtained by determine the number of population on the all area. The incremental population (column 9) is obtained by multiplying column 8 by column 6. Column 10 shows the cumulative total population by adding column 9 to the last figure of column 10.



- e. To calculate cumulative peak design flow columns 11, 12, 13, and 13 are used. Column 11 is obtained by multiplying future wastewater production (80% \* 120 l/c.d.) with the future incremental population (column 9) then dividing by (24 hours \*60 minutes\*60 seconds). The peak factor (column 12) is calculated using equation 3.2 as:  $P_f = 1.5 + 2.5/\sqrt{q}$ , where q = Average Domestic sewage flow (Column 12). Column 13 represents the Maximum Domestic (Q) in (l/s), the value of it is obtained from multiplying column 11 by column 12. Column 14 gives the infiltration allowance, which equal 0.02 \* Column 11.
- f. The entries in columns 15 (total average flow rate) is calculated by sum the Column 11 and Column 13.
- g. The entries in columns 16 (total maximum flow rate) is calculated by sum the Column 13 and Column 14.
- h. The necessary layout data for the sewer (columns 17 through 20) are obtained as follows: The ground surface elevations at the manhole locations entered in columns 17 and 18. The ground slope given in column 19 is obtained by subtracting downstream elevation from upstream elevation (column 17-column 18) and dividing the result by sewer length (column 5).
- i. Sewer design information is summarized in columns 20 through 29. The slope of sewer (column 20) is taken as the slope of the ground or less depending on the values of the slope given in tables of Appendix-B (taking the value of ground slope and look to the tables and take the same value or the nearest less value). The reason for taking the slope of sewer equal to the slope of ground is to decrease the cost of construction the sewers. The

required pipe size (diameter) is chosen by trial and error as follow: (1) beginning with the minimum size (20 cm), the full capacity of selected pipe ( $Q_{full}$ ) at a given slope and diameter is obtained from the tables (Appendix), (2) calculate the ratio  $Q_p/Q_{full}$ , where  $Q_p$  is the total maximum flow rate l/s (column 16), (3) from the table of hydraulic properties for partially filled circular sewers given in Appendix, the ratio of  $h/D$  is obtained, where  $d$  is the depth of flow and  $D$  is the chosen diameter, (4) If the value of  $h/D > 0.5$  choose a larger diameter and repeat the same procedures until the value of  $h/D \leq 0.5$ . The last values of pipe diameter and full capacity of selected pipe obtained are given in columns 21 and 22.

- j. The entries in columns 23 (depth of flow) is calculated by multiply the value of  $h/D$  by Diameter.
- k. For the same pipe diameter and same ratio of  $Q_p/Q_{full}$  or  $h/D$ , the value of full velocity ( $V_{full}$ ) and ratio of  $V_p/V_{full}$  is obtained from the tables, where  $V_{actual}$  is the minimum partial velocity. The values of minimum velocities are calculated by multiplying  $V_{full}$  with  $V_p/V_{full}$  and presented in column 24. And then use the tables to find  $V_p/V_{full}$  ratio, where  $V_p$  here represent the minimum velocity and calculate the minimum velocity by multiplying  $V_p/V_{full}$  with full velocity. The data of minimum velocities are given in column 25.

The final design of this trunk sanitary sewer is shown in Figures 4.2a-4.7a. The lengths and diameters of the pipes along with the manholes are shown in this figure.

#### **4.4 The Proposed Wastewater Collection System**

In the proposed study for the wastewater collection system for Al-Samou' town, the trial is made to design the main trunks of the collection system for year 2032. There are five main trunks. This section deals with the results of the suggested wastewater collection network for year 2032.

The appropriate pipe diameters, lengths, land slopes, and location of the manholes are found by doing the calculations given in the previous section. During and once the sewer design computations have been completed, alternative alignments have been examined, and the most cost–and energy–effective alignment has been selected. The final results for the appropriate diameters for the proposed wastewater collection system, slopes and lengths of the pipes are given in Tables 4.2 through 4.5 along with all relevant data. The calculated velocities, flow rates, and depth of flow in pipes are given in the same tables. The proposed design of the collection system for each of the main trunk are plotted separately and shown in Figures 4.8a to 4.15a.

#### **4.5 Profiles of Sewer**

The profiles of sewer area assist in the design and are used as the basis of construction drawings. The profiles are usually prepared for each sewer line at a horizontal and vertical scale. The profile shows the ground or street surface, tentative manhole locations, elevation of important subsurface strata such as rock, locations of borings, all underground structures, basement elevations, and cross streets. A plan of the line and relevant other structures are usually shown on the same street (McGhee, 1991).

After all the calculation is completed and all the maps of the proposed collection system are prepared, detailed profiles for each sewer is drawn. The profiles of sewer lines are shown in Figures 4.2b-4.15c. These profiles had shown the ground elevation, the proposed sewer lines, manholes (manholes number and the spacing between the manholes), depth of excavations, the diameters and slopes of the pipes, and the type of soil.

## **CHAPTER FIVE**

### **BILL OF QUANTITY**

## **APPENDIX-A**

### **CALCULATIONS TABLES**