

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 1
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

Branch Losses Summary Report

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
C.20	A	0.036	0.021	-0.036	-0.021	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.035	0.020	-0.035	-0.020	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.037	0.020	-0.037	-0.020	0.0	0.0	100.0	100.0	0.00	0.00
C56	A	0.039	0.020	-0.039	-0.020	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.035	0.023	-0.035	-0.023	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.034	0.017	-0.034	-0.017	0.0	0.0	100.0	100.0	0.00	0.00
C59	A	0.135	0.069	-0.135	-0.069	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.127	0.092	-0.127	-0.092	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.111	0.073	-0.111	-0.073	0.0	0.0	100.0	100.0	0.00	0.00
C60	A	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
C61	A	0.153	0.087	-0.153	-0.087	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.139	0.108	-0.139	-0.108	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.128	0.086	-0.128	-0.086	0.0	0.0	100.0	100.0	0.00	0.00
C80	A	0.028	0.013	-0.028	-0.013	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.029	0.016	-0.029	-0.016	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.026	0.015	-0.026	-0.015	0.0	0.0	100.0	100.0	0.00	0.00
C96	A	0.234	0.136	-0.234	-0.136	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.224	0.149	-0.224	-0.149	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.218	0.135	-0.218	-0.135	0.0	0.0	100.0	100.0	0.00	0.00
C97	A	0.107	0.076	-0.107	-0.076	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.108	0.077	-0.108	-0.077	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.106	0.077	-0.106	-0.077	0.0	0.0	100.0	100.0	0.00	0.00
C100	A	0.015	0.008	-0.015	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.017	0.008	-0.017	-0.008	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.016	0.009	-0.016	-0.009	0.0	0.0	100.0	100.0	0.00	0.00
C107	A	0.012	0.007	-0.012	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.013	0.006	-0.013	-0.006	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.013	0.007	-0.013	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
C117	A	0.041	0.026	-0.041	-0.026	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.041	0.030	-0.041	-0.030	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.038	0.028	-0.038	-0.028	0.0	0.0	100.0	100.0	0.00	0.00
C120	A	0.066	0.055	-0.066	-0.055	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.075	0.058	-0.075	-0.058	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.067	0.064	-0.067	-0.064	0.0	0.0	100.0	100.0	0.00	0.00
C128	A	0.178	0.110	-0.178	-0.110	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.173	0.119	-0.173	-0.119	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.168	0.111	-0.168	-0.111	0.0	0.0	100.0	100.0	0.00	0.00
C160	A	0.110	0.078	-0.110	-0.078	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.109	0.079	-0.109	-0.079	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.108	0.078	-0.108	-0.078	0.0	0.0	100.0	100.0	0.00	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 2
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
C162	A	0.149	0.097	-0.149	-0.097	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.144	0.103	-0.144	-0.103	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.142	0.096	-0.142	-0.096	0.0	0.0	100.0	100.0	0.00	0.00
C163	A	-0.005	0.018	0.005	-0.018	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.003	0.018	-0.003	-0.018	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.001	0.025	0.001	-0.025	0.0	0.0	100.0	100.0	0.00	0.00
C191	A	0.110	0.078	-0.110	-0.078	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.109	0.079	-0.109	-0.079	0.0	0.0	100.0	99.9	0.00	0.00
	C	0.108	0.078	-0.108	-0.078	0.0	0.0	100.0	100.0	0.00	0.00
C193	A	0.001	0.003	-0.001	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.001	0.002	-0.001	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
C203	A	-0.073	-0.024	0.073	0.024	0.0	0.0	100.0	100.0	0.00	0.00
	B	-0.067	-0.029	0.067	0.029	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.066	-0.021	0.066	0.021	0.0	0.0	100.0	100.0	0.00	0.00
C216	A	0.066	0.055	-0.066	-0.055	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.075	0.058	-0.075	-0.058	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.067	0.064	-0.067	-0.064	0.0	0.0	100.0	100.0	0.00	0.00
C246	A	0.188	0.115	-0.188	-0.115	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.184	0.124	-0.184	-0.124	0.0	0.0	100.0	100.0	0.01	0.00
	C	0.178	0.116	-0.178	-0.116	0.0	0.0	100.0	100.0	0.01	0.00
C280	A	0.008	0.004	-0.008	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.006	0.003	-0.006	-0.003	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.008	0.002	-0.008	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
C319	A	0.007	0.011	-0.007	-0.011	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.010	0.011	-0.010	-0.011	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.009	0.013	-0.009	-0.013	0.0	0.0	100.0	100.0	0.00	0.00
C322	A	-0.073	-0.024	0.073	0.024	0.0	0.0	100.0	100.0	0.00	0.00
	B	-0.067	-0.029	0.067	0.029	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.066	-0.021	0.066	0.021	0.0	0.0	100.0	100.0	0.00	0.00
C330	A	0.003	0.001	-0.003	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.002	0.001	-0.002	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
C352	A	0.066	0.035	-0.066	-0.035	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.063	0.040	-0.063	-0.040	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.061	0.035	-0.061	-0.035	0.0	0.0	100.0	100.0	0.00	0.00
C361	A	0.032	0.036	-0.032	-0.036	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.039	0.038	-0.039	-0.038	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.034	0.043	-0.034	-0.043	0.0	0.0	100.0	100.0	0.00	0.00
C365	A	-0.013	0.014	0.013	-0.014	0.0	0.0	100.0	100.0	0.00	0.00
	B	-0.004	0.013	0.004	-0.013	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.008	0.021	0.008	-0.021	0.0	0.0	100.0	100.0	0.00	0.00
C368	A	0.017	0.011	-0.017	-0.011	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.019	0.011	-0.019	-0.011	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.018	0.013	-0.018	-0.013	0.0	0.0	100.0	100.0	0.00	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 3
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
C399	A	0.041	0.026	-0.041	-0.026	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.041	0.030	-0.041	-0.030	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.038	0.029	-0.038	-0.029	0.0	0.0	100.0	100.0	0.00	0.00
C409	A	0.008	0.004	-0.008	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.007	0.005	-0.007	-0.005	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.007	0.004	-0.007	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
C419	A	0.008	0.004	-0.008	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.006	0.003	-0.006	-0.003	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.008	0.002	-0.008	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
C422	A	0.012	0.010	-0.012	-0.010	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.012	0.012	-0.012	-0.012	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.010	0.012	-0.010	-0.012	0.0	0.0	100.0	100.0	0.00	0.00
C440	A	0.001	0.002	-0.001	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.003	0.002	-0.003	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
C450	A	0.011	0.008	-0.011	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.007	0.004	-0.007	-0.004	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.012	0.002	-0.012	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
C.450	A	-0.113	-0.049	0.113	0.049	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.113	-0.050	0.113	0.050	0.0	0.0	100.0	100.0	0.01	0.00
	C	-0.112	-0.050	0.112	0.050	0.0	0.0	100.0	100.0	0.01	0.00
C461	A	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.005	0.001	-0.005	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.003	0.003	-0.003	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
C462	A	0.008	0.006	-0.008	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.006	0.004	-0.006	-0.004	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.009	0.003	-0.009	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
C463	A	0.003	0.001	-0.003	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.002	0.001	-0.002	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
C473	A	0.221	0.130	-0.221	-0.130	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.212	0.142	-0.212	-0.142	0.0	0.0	100.0	100.0	0.01	0.00
	C	0.207	0.128	-0.207	-0.128	0.0	0.0	100.0	100.0	0.01	0.00
C476	A	0.023	0.011	-0.023	-0.011	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.020	0.014	-0.020	-0.014	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.019	0.010	-0.019	-0.010	0.0	0.0	100.0	100.0	0.00	0.00
C514	A	0.020	0.014	-0.020	-0.014	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.020	0.018	-0.020	-0.018	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.016	0.016	-0.016	-0.016	0.0	0.0	100.0	100.0	0.00	0.00
C517	A	-0.103	-0.043	0.103	0.043	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.101	-0.046	0.101	0.046	0.0	0.0	100.0	100.0	0.01	0.00
	C	-0.099	-0.042	0.099	0.042	0.0	0.0	100.0	100.0	0.01	0.00
C518	A	-0.090	-0.036	0.090	0.036	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.088	-0.039	0.088	0.039	0.0	0.0	99.9	100.0	0.01	0.00
	C	-0.087	-0.036	0.087	0.036	0.0	0.0	100.0	100.0	0.01	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 4
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
C526	A	0.017	0.013	-0.017	-0.013	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.018	0.016	-0.018	-0.016	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.015	0.015	-0.015	-0.015	0.0	0.0	100.0	100.0	0.00	0.00
C558	A	0.007	0.004	-0.007	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.007	0.004	-0.007	-0.004	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.007	0.004	-0.007	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
C577	A	-0.078	-0.030	0.078	0.030	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.075	-0.032	0.075	0.032	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.074	-0.029	0.074	0.029	0.0	0.0	100.0	100.0	0.00	0.00
C587	A	0.015	0.007	-0.015	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.012	0.008	-0.012	-0.008	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.012	0.005	-0.012	-0.005	0.0	0.0	100.0	100.0	0.00	0.00
C603	A	-0.019	0.010	0.019	-0.010	0.0	0.0	100.0	100.0	0.00	0.00
	B	-0.009	0.009	0.009	-0.009	0.0	0.0	99.9	99.9	0.00	0.00
	C	-0.013	0.018	0.013	-0.018	0.0	0.0	100.0	100.0	0.00	0.00
C622	A	0.009	0.004	-0.009	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.009	0.006	-0.009	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.007	0.005	-0.007	-0.005	0.0	0.0	100.0	100.0	0.00	0.00
C727	A	0.009	0.006	-0.009	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.009	0.008	-0.009	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.008	0.006	-0.008	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
C728	A	0.017	0.010	-0.017	-0.010	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.015	0.010	-0.015	-0.010	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.016	0.008	-0.016	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
C806	A	0.059	0.032	-0.059	-0.032	0.0	0.0	100.0	99.9	0.01	0.00
	B	0.056	0.036	-0.056	-0.036	0.0	0.0	99.9	99.9	0.01	0.00
	C	0.054	0.031	-0.054	-0.031	0.0	0.0	100.0	100.0	0.01	0.00
C811	A	0.019	0.011	-0.019	-0.011	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.017	0.009	-0.017	-0.009	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.019	0.008	-0.019	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
C815	A	-0.107	-0.045	0.107	0.045	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.108	-0.047	0.108	0.047	0.0	0.0	100.0	100.0	0.01	0.00
	C	-0.106	-0.047	0.106	0.047	0.0	0.0	100.0	100.0	0.01	0.00
C880	A	-0.113	-0.049	0.113	0.049	0.0	0.0	100.0	100.0	0.01	0.00
	B	-0.113	-0.050	0.113	0.050	0.0	0.0	100.0	100.0	0.01	0.00
	C	-0.112	-0.050	0.112	0.050	0.0	0.0	100.0	100.0	0.01	0.00
Co14	A	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
Co57	A	0.007	0.011	-0.007	-0.011	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.010	0.011	-0.010	-0.011	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.009	0.013	-0.009	-0.013	0.0	0.0	100.0	100.0	0.00	0.00
Co58	A	0.027	0.008	-0.027	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.021	0.021	-0.021	-0.021	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.013	0.009	-0.013	-0.009	0.0	0.0	100.0	100.0	0.00	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 5
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
Co130	A	0.115	0.055	-0.115	-0.055	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.107	0.074	-0.107	-0.074	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.094	0.058	-0.094	-0.058	0.0	0.0	100.0	100.0	0.00	0.00
Co260	A	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
Co261	A	0.005	0.002	-0.005	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.004	0.004	-0.004	-0.004	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.003	0.003	-0.003	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
Co294	A	0.025	0.007	-0.025	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.018	0.018	-0.018	-0.018	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.012	0.007	-0.012	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
Co528	A	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.001	0.002	-0.001	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
Co600	A	0.115	0.055	-0.115	-0.055	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.107	0.074	-0.107	-0.074	0.0	0.0	100.0	99.9	0.01	0.00
	C	0.094	0.058	-0.094	-0.058	0.0	0.0	100.0	100.0	0.01	0.00
Co645	A	0.005	0.002	-0.005	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.004	0.004	-0.004	-0.004	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.003	0.003	-0.003	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
Co999	A	0.027	0.007	-0.027	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.021	0.020	-0.021	-0.020	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.013	0.008	-0.013	-0.008	0.0	0.0	100.0	100.0	0.00	0.00
Co.1032	A	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.000	0.000	0.000	0.000	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
D240	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
D256	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
D276	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
D634	A	0.007	0.004	-0.007	-0.004	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.007	0.005	-0.007	-0.005	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.007	0.005	-0.007	-0.005	0.0	0.0	100.0	100.0	0.00	0.00
D655	A	0.025	0.007	-0.025	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.018	0.018	-0.018	-0.018	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.012	0.007	-0.012	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
D711	A	0.025	0.007	-0.025	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.018	0.018	-0.018	-0.018	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.012	0.007	-0.012	-0.007	0.0	0.0	100.0	100.0	0.00	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 6
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
D718	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
R10	A	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.001	0.002	-0.001	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
R36	A	0.387	0.223	-0.387	-0.223	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.364	0.257	-0.364	-0.257	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.346	0.220	-0.346	-0.220	0.0	0.0	100.0	100.0	0.00	0.00
R45	A	0.036	0.021	-0.036	-0.021	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.035	0.020	-0.035	-0.020	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.037	0.020	-0.037	-0.020	0.0	0.0	100.0	100.0	0.00	0.00
R106	A	0.153	0.087	-0.153	-0.087	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.139	0.108	-0.139	-0.108	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.128	0.086	-0.128	-0.086	0.0	0.0	100.0	100.0	0.00	0.00
R150	A	0.036	0.021	-0.036	-0.021	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.035	0.020	-0.035	-0.020	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.037	0.020	-0.037	-0.020	0.0	0.0	100.0	100.0	0.00	0.00
R164	A	0.077	0.040	-0.077	-0.040	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.074	0.046	-0.074	-0.046	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.070	0.040	-0.070	-0.040	0.0	0.0	100.0	100.0	0.00	0.00
R190	A	0.152	0.086	-0.152	-0.086	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.139	0.107	-0.139	-0.107	0.0	0.0	100.0	100.0	0.01	0.00
	C	0.128	0.085	-0.128	-0.085	0.0	0.0	100.0	100.0	0.01	0.00
R380	A	0.036	0.021	-0.036	-0.021	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.035	0.020	-0.035	-0.020	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.037	0.020	-0.037	-0.020	0.0	0.0	100.0	100.0	0.00	0.00
R410	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
R436	A	0.152	0.086	-0.152	-0.086	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.139	0.107	-0.139	-0.107	0.0	0.0	100.0	100.0	0.01	0.00
	C	0.128	0.085	-0.128	-0.085	0.0	0.0	100.0	100.0	0.01	0.00
R455	A	0.001	0.003	-0.001	-0.003	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.001	0.002	-0.001	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
R560	A	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.0	0.0	100.0	100.0	0.00	0.00
R734	A	0.077	0.040	-0.077	-0.040	0.0	0.0	100.0	100.0	0.01	0.00
	B	0.074	0.046	-0.074	-0.046	0.0	0.0	99.9	99.9	0.01	0.00
	C	0.070	0.040	-0.070	-0.040	0.0	0.0	100.0	100.0	0.01	0.00
R803	A	0.013	0.006	-0.013	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.012	0.007	-0.012	-0.007	0.0	0.0	100.0	100.0	0.00	0.00
	C	0.011	0.007	-0.011	-0.007	0.0	0.0	100.0	100.0	0.00	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 7
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
R844	A	0.003	0.001	-0.003	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.003	0.002	-0.003	-0.002	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.001	0.002	-0.001	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
R950	A	0.009	0.006	-0.009	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.009	0.008	-0.009	-0.008	0.0	0.0	100.0	99.9	0.00	0.00
	C	0.008	0.006	-0.008	-0.006	0.0	0.0	100.0	100.0	0.00	0.00
R1435	A	0.014	0.007	-0.014	-0.007	0.0	0.0	99.9	99.9	0.00	0.00
	B	0.009	0.010	-0.009	-0.010	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.009	0.005	-0.009	-0.005	0.0	0.0	100.0	100.0	0.00	0.00
R1499	A	0.001	0.001	-0.001	-0.001	0.0	0.0	100.0	100.0	0.00	0.00
	B	0.002	0.001	-0.002	-0.001	0.0	0.0	99.9	99.9	0.00	0.00
	C	0.002	0.002	-0.002	-0.002	0.0	0.0	100.0	100.0	0.00	0.00
T1 Al-masjid Al_kaber	A	0.030	0.014	-0.031	-0.016	-0.7	-1.7	100.0	99.5	0.46	0.00
	B	0.026	0.016	-0.024	-0.010	1.7	6.2	100.0	99.7	0.28	0.00
	C	0.026	0.011	-0.027	-0.012	-0.2	-0.8	100.0	99.6	0.35	0.00
T2 Mothalath Al_borg	A	0.030	0.014	-0.031	-0.016	-0.7	-1.7	100.0	99.5	0.46	0.00
	B	0.026	0.016	-0.024	-0.010	1.7	6.2	100.0	99.7	0.28	0.00
	C	0.026	0.011	-0.027	-0.012	-0.2	-0.8	100.0	99.6	0.35	0.00
T3 Maskaneh	A	0.030	0.014	-0.031	-0.016	-0.7	-1.7	100.0	99.5	0.46	0.00
	B	0.026	0.016	-0.024	-0.010	1.7	6.2	99.9	99.7	0.28	0.00
	C	0.026	0.011	-0.027	-0.012	-0.2	-0.8	100.0	99.6	0.35	0.00
T4 Bear mtawi'	A	0.017	0.018	-0.012	-0.015	5.4	2.1	100.0	99.6	0.39	0.00
	B	0.012	0.015	-0.014	-0.013	-1.4	1.6	100.0	99.6	0.32	0.00
	C	0.017	0.012	-0.020	-0.012	-3.1	-0.3	100.0	99.7	0.33	0.00
T5 Wad algamary 1	A	0.010	0.007	-0.014	-0.010	-3.7	-2.6	100.0	99.5	0.45	0.00
	B	0.012	0.010	-0.011	-0.007	1.0	2.8	100.0	99.6	0.32	0.00
	C	0.008	0.010	-0.005	-0.008	3.3	1.9	100.0	99.7	0.31	0.00
T6 Wad algamary 2	A	0.001	0.003	-0.001	-0.002	0.6	0.6	100.0	99.8	0.16	0.00
	B	0.001	0.002	-0.001	-0.001	-0.2	1.0	100.0	99.9	0.06	0.00
	C	0.002	0.002	-0.002	-0.002	-0.1	-0.4	100.0	99.8	0.15	0.00
T7 Al_deir 1	A	0.020	0.009	-0.020	-0.009	-0.4	-0.1	100.0	99.5	0.49	0.00
	B	0.020	0.010	-0.020	-0.009	0.1	1.2	100.0	99.5	0.44	0.00
	C	0.020	0.010	-0.019	-0.009	0.9	1.3	100.0	99.6	0.43	0.00
T8 Karam al_ashqar	A	0.010	0.004	-0.011	-0.004	-1.2	-0.1	99.9	99.7	0.25	0.00
	B	0.011	0.006	-0.010	-0.006	1.6	-0.1	99.9	99.6	0.28	0.00
	C	0.009	0.006	-0.008	-0.004	0.2	2.3	100.0	99.8	0.20	0.00
T9 Abu al_humas	A	0.020	0.009	-0.020	-0.009	-0.4	-0.1	100.0	99.5	0.49	0.00
	B	0.020	0.010	-0.020	-0.009	0.1	1.2	99.9	99.5	0.44	0.00
	C	0.020	0.010	-0.019	-0.009	0.9	1.3	100.0	99.5	0.43	0.00
T10 Meqtaa' duma	A	0.013	0.008	-0.013	-0.006	0.0	2.6	100.0	99.7	0.31	0.00
	B	0.016	0.008	-0.016	-0.011	0.0	-2.8	99.9	99.5	0.47	0.00
	C	0.015	0.011	-0.014	-0.009	0.6	2.4	100.0	99.6	0.40	0.00
T11 Wad ali	A	0.017	0.009	-0.016	-0.008	1.7	0.3	99.9	99.5	0.43	0.00
	B	0.015	0.008	-0.015	-0.006	-0.1	2.2	99.9	99.6	0.30	0.00
	C	0.017	0.006	-0.018	-0.006	-0.9	-0.3	100.0	99.6	0.36	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 8
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
T12 Aqabit ghararah	A	0.012	0.007	-0.012	-0.005	0.5	1.9	100.0	99.7	0.32	0.00
	B	0.013	0.006	-0.013	-0.007	0.2	-0.6	99.9	99.6	0.37	0.00
	C	0.013	0.007	-0.013	-0.006	-0.1	0.9	100.0	99.6	0.36	0.00
T13 Qata't al_jamal	A	0.009	0.004	-0.010	-0.006	-1.1	-2.2	100.0	99.7	0.31	0.00
	B	0.009	0.006	-0.009	-0.004	0.1	2.0	99.9	99.7	0.20	0.00
	C	0.007	0.005	-0.005	-0.003	1.6	2.2	100.0	99.8	0.15	0.00
T14 Al_markaz	A	0.015	0.008	-0.015	-0.009	0.4	-1.1	100.0	99.5	0.43	0.00
	B	0.017	0.008	-0.019	-0.008	-2.3	0.1	99.9	99.5	0.40	0.00
	C	0.016	0.009	-0.014	-0.006	2.5	3.3	100.0	99.7	0.30	0.00
T15 Abu hashim	A	0.017	0.011	-0.018	-0.010	-0.8	1.2	99.9	99.5	0.49	0.00
	B	0.019	0.011	-0.018	-0.011	0.4	-0.2	99.9	99.4	0.51	0.00
	C	0.018	0.013	-0.017	-0.011	1.0	1.4	100.0	99.5	0.50	0.00
T16 Sa'ada	A	0.011	0.005	-0.012	-0.005	-1.2	-0.1	100.0	99.7	0.27	0.00
	B	0.011	0.005	-0.010	-0.004	0.7	1.3	99.9	99.7	0.22	0.00
	C	0.010	0.005	-0.009	-0.005	1.0	0.8	100.0	99.7	0.23	0.00
T17 Al_baladiya	A	0.011	0.005	-0.012	-0.005	-1.2	-0.1	100.0	99.7	0.27	0.00
	B	0.011	0.005	-0.010	-0.004	0.7	1.3	100.0	99.7	0.22	0.00
	C	0.010	0.005	-0.009	-0.005	1.0	0.8	100.0	99.8	0.23	0.00
T18 Al_sheehk	A	0.018	0.010	-0.020	-0.012	-1.5	-1.2	100.0	99.4	0.56	0.00
	B	0.019	0.012	-0.018	-0.010	0.5	1.9	99.9	99.5	0.48	0.00
	C	0.017	0.012	-0.015	-0.010	1.6	1.6	100.0	99.5	0.46	0.00
T19 Kerbit alama	A	0.004	0.002	-0.004	-0.001	0.6	0.9	100.0	99.8	0.17	0.00
	B	0.008	0.000	-0.011	-0.003	-3.0	-2.2	100.0	99.6	0.34	0.00
	C	0.008	0.004	-0.005	-0.002	2.8	2.6	100.0	99.8	0.19	0.00
T20 Aqabit al_tarsha	A	0.013	0.006	-0.013	-0.007	-0.1	-0.8	100.0	99.4	0.61	0.00
	B	0.012	0.007	-0.012	-0.007	0.3	0.7	100.0	99.4	0.57	0.00
	C	0.011	0.007	-0.011	-0.005	0.2	1.5	100.0	99.5	0.48	0.00
T21 Al_mustashfah	A	0.009	0.004	-0.010	-0.006	-1.2	-2.4	100.0	99.4	0.53	0.00
	B	0.009	0.006	-0.009	-0.004	0.0	1.8	99.9	99.6	0.38	0.00
	C	0.007	0.005	-0.005	-0.003	1.5	2.0	100.0	99.7	0.26	0.00
T22 Da'na	A	0.000	0.000	0.000	0.000	0.1	0.4	100.0	99.9	0.03	0.00
	B	0.000	0.000	0.000	0.000	0.1	0.4	99.9	99.9	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.1	0.4	100.0	100.0	0.01	0.00
T23 Kurza	A	0.013	0.006	-0.013	-0.007	-0.1	-0.8	100.0	99.4	0.62	0.00
	B	0.012	0.007	-0.012	-0.007	0.3	0.7	100.0	99.4	0.57	0.00
	C	0.011	0.007	-0.011	-0.005	0.2	1.5	100.0	99.5	0.48	0.00
T24 Al-deire 2	A	0.009	0.004	-0.010	-0.006	-1.2	-2.4	100.0	99.4	0.53	0.00
	B	0.009	0.006	-0.009	-0.004	0.0	1.8	100.0	99.6	0.38	0.00
	C	0.007	0.005	-0.005	-0.003	1.5	2.0	100.0	99.7	0.26	0.00
T25 Rasmi wahab	A	0.000	0.000	0.000	0.000	0.1	0.4	100.0	100.0	0.03	0.00
	B	0.000	0.000	0.000	0.000	0.1	0.4	100.0	100.0	0.00	0.00
	C	0.000	0.000	0.000	0.000	0.1	0.4	100.0	100.0	0.01	0.00
T26 Baten alqar'	A	0.008	0.006	-0.009	-0.005	-0.3	1.0	100.0	99.5	0.46	0.00
	B	0.009	0.006	-0.010	-0.006	-0.2	-0.2	99.9	99.5	0.48	0.00
	C	0.009	0.007	-0.008	-0.006	0.8	0.5	100.0	99.5	0.49	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 9
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
T27 Al_muntazah	A	0.017	0.002	-0.023	-0.012	-5.7	-9.5	100.0	98.9	1.08	0.00
	B	0.011	0.013	-0.004	-0.002	6.8	10.7	99.9	99.7	0.20	0.00
	C	0.005	0.002	-0.005	-0.002	-0.6	0.3	100.0	99.8	0.21	0.00
T28 Domet al_wridat	A	0.015	0.007	-0.014	-0.007	1.0	-0.1	100.0	99.3	0.64	0.00
	B	0.012	0.008	-0.010	-0.006	1.5	2.1	99.9	99.5	0.48	0.00
	C	0.012	0.005	-0.014	-0.005	-2.1	-0.4	100.0	99.4	0.55	0.00
T29 Juret al_dama	A	0.011	0.008	-0.006	-0.005	4.7	3.1	100.0	99.6	0.38	0.00
	B	0.007	0.004	-0.008	-0.003	-1.2	0.6	99.9	99.6	0.32	0.00
	C	0.012	0.002	-0.016	-0.005	-3.1	-2.2	100.0	99.4	0.54	0.00
T30 Kafar joul	A	0.009	0.004	-0.008	-0.006	1.5	-1.4	99.9	99.5	0.46	0.00
	B	0.005	0.006	-0.004	-0.003	1.1	2.5	99.9	99.7	0.25	0.00
	C	0.006	0.002	-0.008	-0.002	-2.2	0.2	100.0	99.7	0.25	0.00
T31 Sam'a	A	0.001	0.002	-0.001	-0.001	0.2	1.1	99.9	99.8	0.09	0.00
	B	0.002	0.001	-0.002	-0.001	-0.5	0.1	99.9	99.8	0.08	0.00
	C	0.003	0.002	-0.002	-0.002	0.7	0.0	100.0	99.8	0.13	0.00
T32 Khalet al_ayaseh	A	0.002	0.002	-0.002	-0.001	-0.2	0.4	100.0	99.8	0.13	0.00
	B	0.005	0.001	-0.006	-0.003	-1.1	-1.3	99.9	99.7	0.24	0.00
	C	0.003	0.003	-0.002	-0.001	1.7	2.1	100.0	99.9	0.11	0.00
T33 Al_mizrab	A	0.003	0.001	-0.003	-0.001	-0.3	-0.3	100.0	99.8	0.14	0.00
	B	0.003	0.002	-0.002	-0.002	0.9	0.4	99.9	99.8	0.12	0.00
	C	0.001	0.002	-0.002	0.000	-0.3	1.1	100.0	99.9	0.06	0.00
T34 Al_shadaqa	A	0.003	0.001	-0.003	-0.001	-0.3	-0.3	100.0	99.8	0.14	0.00
	B	0.003	0.002	-0.002	-0.002	0.9	0.4	99.9	99.8	0.12	0.00
	C	0.001	0.002	-0.002	0.000	-0.3	1.1	100.0	99.9	0.06	0.00
T35 Al_shuqfan	A	0.007	0.004	-0.007	-0.003	0.1	0.2	100.0	99.4	0.57	0.00
	B	0.007	0.004	-0.007	-0.003	0.2	0.4	99.9	99.4	0.52	0.00
	C	0.007	0.004	-0.007	-0.003	0.0	0.3	100.0	99.4	0.53	0.00
T36 Al_estad	A	0.003	0.001	-0.003	-0.001	-0.3	-0.3	99.9	99.8	0.14	0.00
	B	0.003	0.002	-0.002	-0.002	0.9	0.4	99.9	99.8	0.12	0.00
	C	0.001	0.002	-0.002	0.000	-0.3	1.1	100.0	99.9	0.06	0.00
T37 Eshreete	A	0.008	0.004	-0.007	-0.003	1.0	1.6	100.0	99.7	0.30	0.00
	B	0.006	0.003	-0.006	-0.001	0.3	1.4	99.9	99.8	0.18	0.00
	C	0.008	0.002	-0.009	-0.004	-1.0	-1.7	100.0	99.6	0.37	0.00
T38 Al_muhtasib	A	0.006	0.004	-0.005	-0.003	0.9	1.3	100.0	99.7	0.28	0.00
	B	0.005	0.004	-0.004	-0.003	0.4	0.6	100.0	99.7	0.24	0.00
	C	0.006	0.003	-0.007	-0.004	-1.0	-0.6	100.0	99.7	0.33	0.00
T39 Jammoq	A	0.008	0.004	-0.008	-0.005	0.1	-1.1	100.0	99.5	0.43	0.00
	B	0.007	0.005	-0.008	-0.003	-0.3	1.5	99.9	99.6	0.30	0.00
	C	0.007	0.004	-0.007	-0.003	0.5	1.0	100.0	99.7	0.27	0.00
T40 Al_helal	A	0.000	0.000	0.000	0.000	0.1	0.4	100.0	99.9	0.04	0.00
	B	0.000	0.001	0.000	0.000	0.1	0.4	99.9	99.9	0.01	0.00
	C	0.000	0.001	0.000	0.000	0.1	0.4	100.0	100.0	0.01	0.00
T41 Al_muntazah 2	A	0.006	0.003	-0.006	-0.003	0.1	-0.3	100.0	99.6	0.32	0.00
	B	0.005	0.004	-0.004	-0.002	0.6	1.4	99.9	99.7	0.20	0.00
	C	0.005	0.003	-0.005	-0.002	-0.4	0.1	100.0	99.7	0.23	0.00

Project:
Location:
Contract:
Engineer:
Filename: unbalance

ETAP
12.6.0H

Study Case: ULF

Page: 10
Date: 11-08-2017
SN:
Revision: Base
Config.: Normal

CKT / Branch		From-To Bus Flow		To-From Bus Flow		Losses		% Bus Voltage		Vd % Drop in Vmag	Amperes in Buried Winding
ID	Phase	MW	Mvar	MW	Mvar	kW	kvar	From	To		
T42 Abu njeem 2	A	0.006	0.003	-0.006	-0.003	-0.2	-0.2	100.0	99.7	0.28	0.00
	B	0.006	0.004	-0.005	-0.003	0.9	0.4	100.0	99.7	0.26	0.00
	C	0.004	0.003	-0.005	-0.002	-0.3	1.1	100.0	99.8	0.21	0.00
T43 Al jame'a	A	0.003	0.004	-0.002	-0.001	0.8	2.8	100.0	99.8	0.13	0.00
	B	0.004	0.002	-0.005	-0.003	-0.7	-1.4	99.9	99.7	0.25	0.00
	C	0.005	0.004	-0.005	-0.004	0.3	-0.1	100.0	99.7	0.31	0.00
T44 Alghwla	A	0.002	0.001	-0.002	-0.001	-0.1	0.3	99.9	99.8	0.13	0.00
	B	0.001	0.002	-0.001	-0.001	0.6	1.1	99.9	99.9	0.04	0.00
	C	0.001	0.001	-0.002	-0.001	-0.2	-0.2	100.0	99.9	0.10	0.00
T45 Masafi	A	0.006	0.003	-0.007	-0.004	-0.6	-0.8	100.0	99.6	0.36	0.00
	B	0.005	0.004	-0.004	-0.002	1.0	2.3	99.9	99.8	0.18	0.00
	C	0.005	0.003	-0.005	-0.003	-0.1	-0.2	100.0	99.7	0.24	0.00
T46 Al_jebreni	A	0.011	0.008	-0.010	-0.006	1.2	1.5	100.0	99.5	0.54	0.00
	B	0.011	0.007	-0.011	-0.008	0.0	-0.4	100.0	99.4	0.59	0.00
	C	0.012	0.007	-0.013	-0.007	-0.8	0.4	100.0	99.4	0.60	0.00
T47 Abu_njeem 1	A	0.003	0.001	-0.003	-0.002	-0.3	-0.4	100.0	99.7	0.29	0.00
	B	0.002	0.002	-0.001	-0.001	0.9	1.5	100.0	99.9	0.08	0.00
	C	0.002	0.001	-0.002	-0.001	-0.4	-0.3	100.0	99.8	0.18	0.00
T48 Inab al_kabeer	A	0.001	0.001	-0.001	-0.001	-0.1	0.3	100.0	99.8	0.14	0.00
	B	0.002	0.001	-0.003	-0.002	-0.5	-0.7	99.9	99.7	0.24	0.00
	C	0.002	0.002	-0.001	-0.001	0.8	1.1	100.0	99.9	0.12	0.00
T49 Shweki	A	0.001	0.001	-0.001	-0.001	-0.1	0.3	100.0	99.8	0.14	0.00
	B	0.002	0.001	-0.003	-0.002	-0.5	-0.7	99.9	99.7	0.24	0.00
	C	0.002	0.002	-0.001	-0.001	0.8	1.1	100.0	99.9	0.12	0.00
T50 Al-baha	A	0.008	0.005	-0.007	-0.007	1.4	-1.9	100.0	99.2	0.79	0.00
	B	0.006	0.007	-0.006	-0.006	0.1	1.0	99.9	99.3	0.67	0.00
	C	0.006	0.004	-0.007	-0.002	-1.2	1.8	100.0	99.5	0.47	0.00
T51 Inab al_sagher	A	0.011	0.005	-0.011	-0.004	-0.7	0.1	100.0	99.1	0.84	0.00
	B	0.011	0.006	-0.009	-0.005	1.3	0.4	99.9	99.1	0.79	0.00
	C	0.010	0.005	-0.010	-0.005	-0.2	0.6	100.0	99.2	0.77	0.00
T52 Bank al_eskan	A	0.003	0.001	-0.003	-0.002	-0.3	-0.4	100.0	99.7	0.29	0.00
	B	0.002	0.002	-0.001	-0.001	0.9	1.5	99.9	99.9	0.08	0.00
	C	0.002	0.001	-0.002	-0.001	-0.4	-0.3	100.0	99.8	0.17	0.00
T53 Al_tork	A	0.007	0.011	-0.008	-0.009	-0.9	1.3	100.0	99.7	0.25	0.00
	B	0.010	0.011	-0.010	-0.011	-0.2	-0.2	99.9	99.7	0.26	0.00
	C	0.009	0.013	-0.007	-0.011	1.9	2.0	100.0	99.7	0.25	0.00
T54 Wad algamary 3	A	0.003	0.001	-0.003	-0.002	-0.3	-0.4	100.0	99.7	0.29	0.00
	B	0.002	0.002	-0.001	-0.001	0.9	1.5	100.0	99.9	0.08	0.00
	C	0.002	0.001	-0.002	-0.001	-0.4	-0.3	100.0	99.8	0.17	0.00
T55 Mana'	A	0.001	0.001	0.000	-0.001	0.1	0.4	100.0	99.9	0.08	0.00
	B	0.000	0.001	0.000	-0.001	0.1	0.6	99.9	99.9	0.03	0.00
	C	0.001	0.001	0.000	-0.001	0.1	0.2	100.0	99.9	0.06	0.00
T56 Al jebreny step up	A	0.127	0.061	-0.124	-0.057	2.3	4.2	99.9	100.0	0.16	0.00
	B	0.127	0.061	-0.124	-0.057	2.2	4.1	99.9	100.0	0.13	0.00
	C	0.127	0.061	-0.124	-0.057	2.5	4.0	99.9	100.0	0.14	0.00

For branches below center-tap transformers, Phases A, B, and C correspond to (1), (2), and (N) respectively.

Project:

ETAP

Page: 12

Location:

12.6.0H

Date: 11-08-2017

Contract:

SN:

Engineer:

Revision: Base

Filename: unbalance

Study Case: ULF

Config.: Normal
