

Palestine Polytechnic University



Design of Mechanical systems using PV cells to reduce energy usage for a Pilgrims rest building located at Jericho

By

Ameer Abu Sharkh

Yassir Abu Qathele

Supervisor : Kazem Osaile

Submitted to the College of Engineering  
in partial fulfillment of the requirements for the degree of  
Bachelor degree in Refrigeration & Air Conditioning Engineering

Dec 2015

**Palestine Polytechnic University**  
**Hebron-Palestine**  
**College of Engineering & Technology**  
**Mechanical Engineering Department**  
**Refrigeration & Air Conditioning Engineering**

**Project Name:**

**Design of Mechanical systems using PV cells to reduce energy usage for a Pilgrims rest building located at Jericho**

**Project Team:**

**Ameer Abu Sharkh**

**Yassir Abu Qathele**

**According to the project supervisor and according to the agreement of the testing committee members, this project is submitted to the Department of Mechanical Engineering at college of engineering and technology in partial fulfillment of requirement of (B.SC) degree in engineering of refrigeration and air conditioning.**

**Supervisor signature**

.....

**Examine committee signature**

.....

**Department Head signature**

.....

## اهداء

{يَرْفَعُ اللَّهُ الَّذِينَ آمَنُوا مِنْكُمْ وَالَّذِينَ أُوتُوا الْعِلْمَ دَرَجَاتٍ وَاللَّهُ بِمَا تَعْمَلُونَ

خَيْرٌ} اهداء الى الهادي نور القلوب سيدنا محمد صلى الله عليه وسلم الى

ارواح من سطروا بدمانهم منار الحرية الشهداء البررة الى من اثاروا لنا

دروب الحياة الى اهـ وا من كانوا سببا في وجودي واهلى اخوة

رياحين النفس الى من نور الله قلوبهم بنور العلم اساتذتنا اولي الفضل

د. الى كل طالب علم الى كل زميل شاركنا الفرحه بعد العناء

نهدي هذا العمل المتواضع في سبيل الله.

## **Acknowledgment**

We would like to thank Palestine Polytechnic University, Collage of Engineering and Technology , and mechanical Engineering Department. Thanks from our hearts for all support and for this worthy learning environment.

Also thanks to the head of hopefulness, our parents.

We would like to thank everybody shared in success of this work either by suggestion, directives, or tips. Thanks to Eng. Kazem Osaily for his great efforts in supervision, suggestion, and providing experience to accomplish this work. Also we want to thank both Dr. Ishaq Sider and Eng. Mohammed Awad for all helps and worthy suggestions and tips to accomplish this project.

## Abstract

يهدف هذا المشروع تصميم الخدمات الميكانيكية واستخدام الخلايا الشمسية لتقليل الطاقة الكهربائية لاستراحة حجاج في مدينة أريحا . وتصميم هذا المشروع يشمل عمل حسابات وتجهيز رسومات واختيار المواد والمعدات وحساب جدول الكميات لنظام تزويد المياه ونظام الصرف الصحي ونظام التكييف والتبريد الحريق والخلايا الشمسية .

This project aims to design the mechanical systems Using PV Cells To Reduce Energy Usage for Pilgrims rest building in Jericho City. The design of this project include making the calculations, drawings, material selection and determine the table of quantity for the water system, drainage system, air conditioning system , the firefighting system and solar cells .

## TABLE OF CONTENTS

## **1 CHAPTER ONE:Introduction**

1.1. Project objectives.....	1
1.2. Time table .....	2
1.3. Project content .....	3

## **2 CHAPTER TWO: Cooling Load**

2.1 ASHRAE chart.....:	5
2.2 Data analysis .....	6
2.3 Calculation of the overall heat transfer coefficient .....	8
2.3.1 Overall heat transfer coefficient for external walls .....	8
2.3.2 Overall heat transfer coefficient for internal walls .....	10
2.3.3 Overall heat transfer coefficient for ceiling .....	10
2.3.4 Overall heat transfer coefficient for floor, doors and window.....	12
2.4 Cooling load calculations .....	12
2.4.1 Heat gain from walls, ceiling and the sun .....	12
2.4.2 Heat gain from the solar transmitted through windows.....	13
2.4.3 Sensible &latent heat gain from the occupants .....	14
2.4.4 Heat gain from the lights .....	14
2.4.5 Heat loss due to infiltration .....	15
2.4.6 Heat gain due to ventilation .....	16
2.5 The VRF system and its calculations .....	18
2.5.1 VRV system .....	18
2.5.2 VRV components .....	18
2.5.3 Advantages of VRV .....	20
2.5.4 Design of VRV system .....	20
2.5.5 Selection of outdoor and indoor unit .....	20
2.5.6 Selection of pipes and joints .....	22

### **3 CHAPTER THREE: Heating Load**

3.1 Outdoor and indoor design conditions .....	24
3.2 Heat gain calculations .....	24
3.2.1 Rate of heat transfer from the external walls .....	25
3.2.2 Rate of heat transfer from the ceiling.....	25
3.2.3 Rate of heat transfer from the ground .....	25
3.2.4 Rate of heat transfer from the doors and windows .....	26
3.2.5 Heat loss due to infiltration .....	26
3.2.6 Heat gain due to ventilation .....	28
3.2 Mechanical ventilation : .....	29
3.3.1 How ventilation system work: .....	29
3.3.2 ventilation benefits :.....	30
3.3.3 Design air ventilation: .....	30

### **4 CHAPTER FOUR : Plumbing System**

4.1 Water supply system .....	32
4.1.1 Fixture unit load calculations .....	32
4.1.1.1 Fixture unit load for the collectors in restaurant .....	32
4.1.2 Friction Method .....	33
4.1.3 Calculation of Branch and Riser .....	35
4.1.3.1 Table shows the sizing pipe for cold water .....	35
4.1.3.2 Table shows the sizing pipe for hot water .....	36
4.2 Drainage system .....	37
4.2.1 Table shows the Drainage Fixture unit load and the sizing stack .....	37

### **5 CHAPTER FIVE : Firefighting System**

5.1 Fire extinguisher .....	44
5.2 Fire hose reel.....	46
5.3 Fire hydrant system .....	46

5.4 Automatic sprinkler system .....	47
5.5 Smoke sensor .....	48
5.6 Pumps room .....	48
5.6.1 Component and equipment used .....	48
5.6.2 Shut off the pumps .....	49
5.7 Pipe size calculation .....	50

## **6 CHAPTER SIX : Photovoltaic System**

6.1 On grid solar .....	52
6.2 Off grid solar .....	52
6.3 Calculation .....	53

## **7 CHAPTER SEVEN : Bills Of Quantity**

Table 1-1: Time table for the first semester : .....	2
Table 1-2: Time table for the first second : .....	3
Table 2-1: Data for outside and inside temperature :.....	7
Table 2-2: CLTD for walls and roof : .....	8
Table 2-3:parameters of CLTD for walls and roof : .....	8
Table 2-4:External wall constructions: .....	9
Table 2-5:Internal wall construction: .....	10
Table 2-6:Ceiling construction: .....	11
Table 2-7:heat gain from walls and ceiling .....	12
Table 2-8: heat gain from the sun .....	13
Table 2-9:Heat gain from solar transmitted through the glass: .....	13
Table 2-10:The cooling load for each room in the building: .....	17
Table 2-11: Specification of outdoor and indoor unit for riser 1: .....	21
Table 2-12: Specification of outdoor and indoor unit for riser 2: .....	21
Table 2-13: Specification of outdoor and indoor unit for riser 3: .....	22
Table 2-14: Specification of pipes and joints for riser 2: .....	22
Table 2-15: Specification of pipes and joints for riser 1: .....	23
Table 2-16: Specification of pipes and joints for riser 3: .....	23
Table 3-1: Outdoor design conditions: .....	24
Table 3-2:Indoor design conditions: .....	24
Table 3-3:The heating load for each room in the building:.....	29
Table 3-4: Description of fans used for air change:.....	31
Table 4-1: The fixture units load for collector 1: .....	32
Table 4-2: The fixture units load for collector 2: .....	32
Table 4-3: The fixture units load for collector 3: .....	32

Table 4-4: Table for estimating demand for collector 1: .....	33
Table 4-5: Table for estimating demand for collector 2: .....	33
Table 4-6: Table for estimating demand for collector 2: .....	33
Table 4-7 : The sizing pipe for cold water on the ground floor: .....	35
Table 4-8 : The sizing pipe for cold water on the first floor : .....	35
Table 4-9 : The sizing pipe for hot water on the ground floor: .....	36
Table 4-10 : The sizing pipe for hot water on the first floor : .....	36
Table 4-11 : Sizing of stack 1: .....	37
Table 4-12 : Sizing of stack 2: .....	37
Table 4-13: Sizing of stack 3: .....	38
Table 4-14 : Sizing of stack 4: .....	38
Table 4-15 : Sizing of stack 5: .....	38
Table 4-16 : Sizing of stack 6: .....	38
Table 4-17 : Sizing of stack 7: .....	39
Table 4-18 : Sizing of stack 8: .....	39
Table 4-19 : Sizing of stack 9: .....	39
Table 4-20 : Sizing of stack 10: .....	40
Table 4-21 : Sizing of stack 11: .....	40
Table 4-22 : Sizing of stack 12: .....	40
Table 4-23 : Sizing of stack 13: .....	41
Table 4-24 : Sizing of stack 14: .....	41
Table 4-25 : Sizing of stack 15: .....	41
Table 4-26 : Sizing of stack 16: .....	41
Table 4-27 : Sizing of stack 17: .....	42
Table 4-28 : Sizing of stack 18: .....	42

Table 4-29 : Building drain: .....	42
Table 5-1 : Pipe schedule for supply piping:.....	50
Table 7-1 : Bills of quantities for the a Pilgrims rest building:.....	55

## **List of Figures**

Figure 1: Comfort ASHRAE Comfort Chart.....	6
Figure 2:External wall .....	9
Figure 3:Internal wall .....	10
Figure 4:Ceiling construction .....	11
Figure 5: The VRV system component .....	19
Figure 6: Calculation the Ventilation by program for kitchen:.....	30
Figure 7: Calculation the Ventilation by program for bathroom:.....	31
Figure 8: Fire extinguisher rating guide:.....	44
Figure 9: House Reel:.....	46
Figure 10: House Rack:.....	46
Figure 11: Fire hydrant:.....	47
Figure 12: Smoke sensor:.....	48
Figure 13: panel in series:.....	52

# **1 Chapter 1: Introduction :**

In business, industry, schools, hospitals, hotels, theaters, restaurants and homes air conditioning is no longer auxiliary but an essential part of modern living. There are four atmospheric conditions. True air conditioning implies that all four of these atmospheric conditions for human comfort are being met.

The air conditioning system include much more than the control of the inside temperature of a given space. It include the controlling and maintaining of the following four atmospheric conditions that affect the human comfort :

1. Temperature of the inside space.
2. Humidity contents of the air.
3. Purity and quality of the inside air.
4. Air velocity and air circulation within the space .

The main goal of plumbing design for building is to safely and reliably provide domestic water and water for fire fitting. And also to get rid of the wastes.

## **1.1. Project objectives**

The main objectives of the project are:

1. To calculate and design air conditioning, heating and plumbing systems.
2. To prepare the required drawings for each system.
3. To select the required equipments and parts.
4. Design a suitable firefighting system that covers the requirements of the building.
5. Design Photovoltaic System .

**1.2. Time table:**

**Table 1-1:Time table for the first semester:**

<b>tasks\week</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>	<b>7</b>	<b>8</b>	<b>9</b>	<b>10</b>	<b>11</b>	<b>12</b>	<b>13</b>	<b>14</b>	<b>15</b>
Choosing the building plan	■														
Overview previous projects			■												
Overall coefficient calculations for walls , ceiling , floor ,doors and windows				■											
Heating and cooling loads calculations						■									
Water supply system calculations				■											
Plumbing system calculations									■						
Printing													■		

**Table 1-2:Time table for the second semester:**

<b>tasks\week</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>	<b>7</b>	<b>8</b>	<b>9</b>	<b>10</b>	<b>11</b>	<b>12</b>	<b>13</b>	<b>14</b>	<b>15</b>
Editing and modifying	█														
Design the firefighting system			█												
Design the VRV system				█											
Design Photovoltaic System								█							
Doing bill of quantity tables											█				
Printing														█	

**1.3. Project contents :**

Chapter One: Introduction

Includes an overview, the project objectives and time table .

Chapter Two: Cooling Load

Includes a sample calculation for one room in details , the other rooms loads VRV system

Chapter Three: Heating Load

Includes a sample calculation for one room in details , the other rooms loads and mechanical ventilation.

Chapter Four: Plumbing System

Includes the calculation of water supply system to determine the total required amount of water and the drainage system

## Chapter Five : Firefighting System

Includes general introduction about each system, and the pipe size calculations for one branch.

## Chapter Six : Photovoltaic System .

Includes calculation and type of photovoltaic System .

## Chapter Seven: Bill Of Quantity

This chapter includes the total number of quantity for each system and its cost.











## **2 Chapter 2: Cooling load**

The main purpose of air conditioning is to provide a comfortable atmosphere for people inside a closed space. The parameters that govern this comfort are four parameters namely air temperature, humidity, air velocity and air purity. Therefore, cooling decrease the temperature of the surrounding air, heating increase the temperature of the surrounding air, humidifying increase the moisture content in the surrounding air, and dehumidifying decrease the moisture content in the surrounding air. Ventilation renew and clean the air inside the space.

Human body temperature is normally  $37^{\circ}\text{C}$ . We are comfortable when the heat level in our body is transferring to the surrounding air at comfort rate. The rate of this heat transfer depends on the properties of surrounding air and other factors like the type of clothes the human put on. Therefore, to maintain the correct rate of heat transfer, the surrounding air must be conditioned (i.e. changing the properties of the air to suitable ones).

An air conditioner is an appliance or mechanism designed to extract heat from humanly occupied space air temperature using refrigeration cycle. When air conditioning is available it may be central air conditioning where all parts of the building including common areas are cooled or it may be provided only in the specific spaces. In general comfort occurs when body temperature is held within narrow ranges, skin moisture is low and physiological effort of regulation is minimized. Comfortable conditions result from a desirable combination of air temperature, humidity, air velocity, and air purity.

### **2.1 ASHRAE comfort chart**

Research studies have been conducted to show that, with a specific amount of air movement, thermal comfort can be produced with certain combinations of dry-bulb temperature and relative humidity. When plotted on a psychometric chart, these combinations form a range of conditions for delivering acceptable thermal comfort to 80% of the people in a space. This “comfort zone” and the associated assumptions are defined by ASHRAE Standard

55, Thermal Environmental Conditions for Human Occupancy. Determining the desired condition of the space is the first step in estimating the cooling and heating loads for the space. In this restaurant , We design on [24°C] dry-bulb temperature and 40% relative humidity as the desired inside condition during the summer season from the ASHRAE Comfort Chart.




Figure 1: ASHRAE Comfort Chart

## 2.2 Data analysis

$$(CLTD)_{corr.} = (CLTD + LM)k + (25.5 - T_i) + (T_{o,m} - 29.4) f \quad (1.1)$$

Where:

- ✓ CLTD: Is called cooling load temperature difference for medium wall construction.
- ✓ LM: Latitude correction factor for horizontal and vertical surfaces .

- ✓  $K$ : Colors adjustment factor such that  $k = 1.0$  for dark colored roofs, and  $k=0.65$  for Permanently Light colored walls.
- ✓  $DR$ : The daily temperature range which equal to the difference between the average maximum and Average minimum temperature for warmest month of the summer season.
- ✓  $f$ : The factor  $f$  is attic or roof fan factor such that  $f = 1$  if there is no attic or roof fan, and the value of  $f = 0.75$  if there is an attic or roof fan.
- ✓  $T_{o.m}$ : The outdoor main temperature

$$T_{o.m} = T_{out} - \frac{DR}{2} \quad (1.2)$$

Then :

$$T_{out.m} = T_{out} - \frac{DR}{2} = 36.64 - \frac{12}{2} = 30.64 \text{ } ^\circ\text{C}$$

The following table contains all assumptions needed for the next calculations:-

**Table 2-1: Data for outside and inside temperature :**

Outdoor temperature ( $T_o$ )	36.64 °C From the Palestinian code
Indoor temperature ( $T_i$ )	24 °C From Figure 1
Latitude( LM )	July @ latitude 32° North From Table 9-2
Day of calculations	21 <sup>st</sup> day of july
Color of surfaces ( K )	Permanent light colour wall

In the following table is the corrected CLTD for walls and roof and its tabulated as follow:

**Table 2-2 : (CLTD)<sub>corr</sub> for walls and roof :**

Wall	CLTD From table (9-1)	LM From table (9-2)	K	F	CLTD <sub>corr.</sub>
S	6	-1.6	0.65	0.75	9.79
SW	7	-0.5	0.65	0.75	11.155
W	8	0	0.65	0.75	12.13
NW	6	0.5	0.65	0.75	11.155
N	5	0.5	0.65	0.75	10.505
NE	9	0.5	0.65	0.75	13.105
E	12	0	0.65	0.75	14.73
SE	10	-0.5	0.65	0.75	13.105
Roof	35	0.5	1	1	44.24


**Table 2-3 : Parameters of (CLTD)<sub>corr</sub> for walls and roof :**

Parameters	Properties
Roof	Without suspending ceiling type 2 @solar time 13h
Wall	Group B @solar time 13h
LM	JULY @Latitude 32c
K	Permanent light colour wall
f	The value of attic or roof fan factor
Type of glass	Double , thickness 3mm , without interior shading
CLF	Construction medium without inertia shading

## 2.3 Calculation of the overall heat transfer coefficient:

### 2.3.1 Overall heat transfer coefficient for external walls:

The construction of the external walls are explained in details in the following figure:-



**Figuer 2: External wall**

**Table 2-4:External wall constructions:**

Material	Thickness(m)	R-value (m <sup>2</sup> . °C /W)
Outside air film	-----	0.12
Stone(1)	0.07	0.041
Concrete(2)	0.2	0.114
Insulation(3)	0.03	0.750
Cement Brick(4)	0.07	0.078
Plaster(5)	0.03	0.025
Inside air film	-----	0.08

$$U_{\text{walls,out}} = \frac{1}{R_{th}} = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}} \quad (1.3)$$

$$U_{\text{walls,out}} = \frac{1}{R_{th}} = \frac{1}{0.08 + \frac{.07}{1.7} + \frac{0.2}{1.75} + \frac{0.03}{0.04} + \frac{0.07}{0.897} + \frac{0.03}{1.2} + 0.12}$$

$$U_{\text{walls,out}} = \frac{1}{R_{th}} = \frac{1}{1.2} = 0.833 \text{ W/m}^2 \cdot \text{°C}$$

### 2.3.2 Overall heat transfer coefficient for internal walls:

The construction of the internal walls are explained in details in the following figure:-




Figure 3: Internal wall

Table 2-5: Internal wall constructions:

Material	Thickness (m)	R-value (m <sup>2</sup> .°C /W)
Inside air film	-----	0.12
Bleach(1)	0.02	0.02
Brick(2)	0.07	0.65
Bleach(3)	0.02	0.02
Inside air film	-----	0.12


$$U_{\text{walls,in}} = \frac{1}{R_{th}} = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}}$$

$$U_{\text{walls,in}} = \frac{1}{R_{th}} = \frac{1}{0.12 + \frac{0.02}{1} + \frac{0.07}{0.107} + \frac{0.02}{1} + 0.12}$$

$$U_{\text{walls,in}} = \frac{1}{0.93} = 1.075 \text{ W/m}^2 \cdot \text{°C}$$

### 2.3.3 Overall heat transfer coefficient for ceiling

The construction of the ceiling are explained in details in the following:-



**Figuer 4: Ceiling construction**

**Table 2-6:Ceiling constructions:**

Material	Thickness (m)	R-value (m <sup>2</sup> .°C /W)
Outside air film	-----	0.12
Alphalt Mix(1)	0.02	0.028
Concrete(2)	0.05	0.029
Insulation(3)	0.03	0.75
Reinforced Concrete(4)	0.1	0.057
Plaster(5)	0.2	0.017
Inside air film	-----	0.08

$$U_{\text{Ceiling}} = \frac{1}{R_{th}} = \frac{1}{\frac{1}{h_i} + \frac{x_1}{k_1} + \frac{x_2}{k_2} + \dots + \frac{1}{h_o}}$$

$$U_{\text{Ceiling}} = \frac{1}{R_{th}} = \frac{1}{0.08 + \frac{0.02}{0.7} + \frac{0.05}{1.7} + \frac{0.03}{0.04} + \frac{0.1}{1.75} + \frac{0.02}{1.17} + 0.12}$$

$$U_{\text{Ceiling}} = \frac{1}{R_{th}} = \frac{1}{1.08} = 0.925 \text{ W/m}^2 \cdot \text{°C}$$

### 2.3.4 Overall heat transfer coefficient for floor, doors and windows

The doors are made from wood, and the windows are double glass Aluminum with a wind speed range from 0.5 to 5 m/s from table 4-5.

$$U_{\text{floor}} = 0.9 \text{ W/m}^2 \cdot ^\circ\text{C} \quad U_{\text{windows}} = 3.2 \text{ U W/m}^2 \cdot ^\circ\text{C} \quad U_{\text{door}} = 2.4 \text{ W/m}^2 \cdot ^\circ\text{C}$$

### 2.4 Cooling load calculations

the calculations for restaurant in ground floor which is an area of 398 m<sup>2</sup> and can accommodate 100 people. In the following subsections determined the heat gain that comes from different resources. And these resources are the walls, sun, occupants, infiltration, ventilation, and windows.

#### 2.4.1 Heat gain from walls, ceiling and the sun

**Table 2-7:heat gain from walls and Ground:**

Surface	Area (m <sup>2</sup> )	U (W/m <sup>2</sup> · °C)	T (°C)	Q (W)
External	746	1.179	12.64	11117
Ceiling	398	0.925	12.64	4653
Ground	398	1.03	12.64	5181
<b>Q<sub>total</sub></b>				<b>20951</b>

In this step determined the heat gain from the direct contact with the sun, the sun is directly contact with the all walls and the ceiling for this room, the following table shows the total amount of heat gain from the sun using the cooling load temperature difference (CLTD) corr.

**Table 2-8: heat gain from the sun:**

Surface	CLTD	LM	CLTDcorr	Area(m <sup>2</sup> )	U (W/m <sup>2</sup> . °C)	Q (W)
North wall	5	0.5	10.5	246.174	0.83	2141.2
South wall	6	-1.6	9.79	231	0.83	1873.2
East wall	12	0	14.73	130	0.83	1590.9
West wall	8	0	12.1	145.6	0.83	1462.8
ceiling	35	0.5	44.24	398	0.83	16286
					<b>Q<sub>total</sub></b>	<b>23355</b>

#### 2.4.2 Heat gain from the solar transmitted through windows

In the selected room the all wall is exposed to the sun. heat gain due to solar transmission through glass window and glass door is estimated by using table 9-7 to 9-11. The values of the variables are taken from the inserted tables in the appendix.

$$Q_g = A \times (SHG) \times (SC) \times (CLF) \quad (1.4)$$

Where:

- ✓ SHG : Solar heat gain factor
- ✓ SC : Shading coefficient
- ✓ CLF : Cooling load factor

**Table 2-9:Heat gain from solar transmitted through the glass:**

Surface	Area (m <sup>2</sup> )	SHG From table (9-7)	SC From table (9-8)	CLF From table (9-10)	Q(W)	
S-glass	1	227	0.9	0.57	116	
E-glass	15.2	678	0.9	0.35	3246	
W-glass	1	478	0.9	0.19	116	
					<b>Q<sub>total</sub></b>	<b>3478</b>

### 2.4.3 Sensible & latent heat gain from the occupants

The heat gain from the occupants depend on the number of occupants inside the restaurant .

$$Q_{oc} = Q_{oc,sens} + Q_{oc,latent} \quad (1.5)$$

$$Q_{oc,sens} = \# \text{ Of Occupants} \times \text{sensible heat} \times CLF_{occ} \quad (1.6)$$

$CLF_{occ}$  cooling load factor due to occupants , for sensible heat gain , From Table 9\_16  
Sensible and Latent heat From Table 4 – 2

$$Q_{oc,sens} = 100 \times \frac{70}{1000} \times 0.62 = 4.43 \text{ kW}$$

$$Q_{oc,latent} = \# \text{ Of Occupants} \times \text{latent heat}$$

$$Q_{oc,latent} = 100 \times \frac{44}{1000} = 4.4 \text{ kW}$$

### 2.4.4 Heat gain from the lights:

there is Twenty lights through this restaurant, so:

$$Q_{lights} = N \times P \times CLF_{lights} \times \text{Diversity factor} \quad (1.7)$$

Where:

N: The number of lights.

P : The power for the lights.

$CLF_{lights}$  : Cooling load factor for the lights , From Table 9 - 14.

$$CLF_{lights} = 0.69$$

$$Q_{lights} = 20 \times 70 \times 0.69 \times 0.5 = 0.483 \text{ kW.}$$

#### 2.4.5 Heat loss due to infiltration:

Infiltration is the leakage of the outside air through cracks or clearances around the windows and doors. We use the crackage method to calculate it as follow:

##### For Windows :

$$Q_{infiltration} = m_f \times (h_o - h_i) \quad (1.8)$$

$$m_f = \frac{V_f}{v_o} \quad (1.9)$$

$$V_f = \text{crack length}(L) \times \text{Infiltration through windows} \quad (1.10)$$

Where  $V_f$  is obtained from table 6-1 at 8 km/h as  $2\text{m}^3/\text{h}$  per meter of crack. the crack length of the five double hung metal windows is :

$$L = 5 \times 2 \times 1.1 + 3 = 41 \text{ m.}$$

Therefore ;

$$V_f = 41 \times 2 = 82 \frac{\text{m}^3}{\text{h}} = \frac{82}{3600} = 0.02277 \frac{\text{m}^3}{\text{s}}.$$

Also, from the psychrometric chart, at the given outside conditions then the specific volume  $v_o$  of outside air is :

$$v_o = 0.907 \text{ m}^3/\text{kg}$$

$$m_f = \frac{0.02277}{0.907} = 0.02511 \text{ Kg/s.}$$

Then total heat loss due to infiltration is :

$$Q_{infiltration} = 0.02511 \times 1 \times (85 - 46) = 0.979 \text{ kW}$$

##### For Doors :

$$Q_{infiltration} = m_{inf} \times (h_o - h_i)$$

$$m_{inf} = \frac{V_f}{v_0}$$

$V_f$  = crack length  $\times$  Infiltration through doors .

Where  $V_f$  is obtained from table 6-1 at 8 km/h as 5.4 m<sup>3</sup>/h per meter of crack. the crack length of the tow poorly fitted door is :

$$L = 2 \times 2 \times 2 + 3 + 2 \times 1.25 + 3 = 28.5 \text{ m} .$$

$$v_0 = 0.907 \text{ m}^3/\text{kg}$$

$$V_f = 28.5 \times 5.4 = 153.9 \frac{\text{m}^3}{\text{h}} = \frac{153.9}{3600} = 0.0427 \frac{\text{m}^3}{\text{s}} .$$

$$m_f = \frac{0.0427}{0.907} = 0.0471 \text{ Kg/s} .$$

Then total heat loss due to infiltration is :

$$Q_{infiltration} = 0.0471 \times 1 \times (85 - 46) = 1.838 \text{ kW}$$

#### 2.4.6 Heat gain due to ventilation:

$$Q_{ventilation} = m_v \times (h_o - h_i) \quad (1.11)$$

$$m_v = \frac{V_v}{v_0} \quad (1.12)$$

$$V_v = \text{minimum outside air requirements ventilation} \times \text{No. of persons} \quad (1.13)$$

minimum outside air requirements ventilation from Table 4-5

$$V_v = 8 \times 100 = 800 \text{ l/s} = 0.8 \text{ m}^3/\text{s} .$$

$$v_0 = 0.907 \text{ m}^3/\text{kg}$$

$$m_v = \frac{0.8}{0.907} = 0.89 \text{ Kg/s.}$$

Then total heat loss due to ventilation is :

$$Q_{\text{ventilation}} = 0.89 \times 1000 \times (85 - 46) = 34.6 \text{ kW.}$$

❖ Finally, the total load for this restaurant is the summation of all the heat gain resources .

$$Q_{\text{total}} = 73.5 \text{ kW}$$

**Table 2-10: The cooling load for each room of the building:**

Name of room	Cooling load (kW)	Area (m <sup>2</sup> )	Name of room	Cooling Load (kW)	Area (m <sup>2</sup> )
<b>Ground Floor</b>			<b>First Floor</b>		
shop	70	369.45	room1	5.6	33.01
restaurant	73.5	398	room2	5.1	31.5
mosque	41.5	167.57	room3	5.4	31.5
room1	7	33.31	room4	5.2	31.5
room2	6.7	31.5	room5	5.5	33
room3	6.3	31.5	room6	6.1	33.3
room4	6.6	31.5	room7	5.6	31.5
room5	6.9	31.5	room8	5.4	31.5
room6	7	33.31	room9	5.2	31.5
majlis1	25.7	66.03	room10	5.3	31.5
majlis2	23.9	80.34	room11	6	33.3
			account	4.5	16.5
			manag	4.3	12.4
			secer	3.6	10.2
			room	5	21.6

## **2.5 The VRF system and its calculations**

### **2.5.1 VRF system**

The primary function of all air-conditioning systems is to provide thermal comfort for building occupants. There are a wide range of air conditioning systems available, starting from the basic window-fitted units to the small split systems, to the medium scale package units, to the large chilled water systems, and currently to the variable refrigerant flow (VRF) systems.


Variable refrigerant flow (VRF) is an air-condition system configuration where there is outdoor condensing unit and multiple indoor units. The term variable refrigerant flow refers to the ability of the system to control the amount of refrigerant flowing to the multiple evaporators (indoor units), enabling the use of many evaporators of differing capacities and configurations connected to a single condensing unit. The arrangement provides an individualized comfort control, and simultaneous heating and cooling in different zones

VRF systems operate on the direct expansion (DX) principle meaning that heat is transferred to or from the space directly by circulating refrigerant to evaporators located near or within the conditioned space. Refrigerant flow control is the key to many advantages as well as the major technical challenge of VRF systems.

### **2.5.2 VRV components**

The VRV system have some of main components :

- 1) outdoors units.
- 2) indoors units.
- 3) piping connection



**Figure 5: The VRV system components**

### **-Outdoors units.**

The outdoor unit contains a heat pump, A heat pump is a machine that by reversing its refrigeration cycle can provide heating instead of cooling. Because a heat pump uses refrigerant it can upgrade the heat in air at even  $-15^{\circ}\text{C}$  to a usable heat source to heat buildings.

### **-Indoor Units:**

The indoor units were developed to be highly efficient, compact, low noise, and to have user friendly operation. Care was also taken with the design to make that go well with the interior decoration and to be easy to install and maintain. Further, a variety of options are available to achieve an air conditioning environment that is more desirable from the user's perspective.

### **-Expansion valve controller:**

Thermostatic Expansion Valves (TXV) is very important part to control the flow in vrv system As the thermostatic expansion valve regulates the rate at which liquid refrigerant flows into the evaporator, it maintains a proper supply of refrigerant by matching this flow rate against how quickly the refrigerant evaporates (boils off) in the evaporator coil.

### **2.5.3 Advantages of VRV**

#### **- Comfort:**

Comfort by providing “even” cooling or heating when and where it is required. Multiple types of fan coils and sizes provides design flexibility for different applications. Design software simplifies selecting and piping design.

#### **- Energy savings:**

No energy loss due to moving conditioned air in duct work. Equipment handling –Smaller wire sizes and disconnects Smaller pipe sizes when compared to chilled water.

### **2.5.4 Design of VRV system**

There are two method to design of VRV according to daikin company system:

- \* By xpress program.

- \*By Table.

\*what is the Xpress program?

“Xpress” is a selection software for VRV systems And it can helps your quick selection for quotation with easy operation.

This program is made from daikin company , the program can help you to choose a lot of very important thing about VRV system .

- \* Table is made from daikin company , the table can help you to choose a pipes size , refent joint, header joint and other thing .

### **2.5.5 Selection of outdoor and indoor units:**

This tables show the characteristics of used unit and cooling load for each room :

**Table2-11:Specification of outdoor and indoor unit for riser 1:**

Name of the room	Cooling load (kW)	Name of indoor unit	Capacity of indoor unit (kW)	Num. of indoor unit	Dim.of indoor unit (mm)	Specifications Of outdoor unit
mosque	41.5	FXFQ63A	7.1	6	60X950X950	Capacity range : 50 hp Cooling load : 140 kW Heating capacity : 156 kW
room1	7	FXFQ63A	7.1	1		
room2	6.7	FXFQ63A	7.1	1		
room3	6.3	FXFQ63A	7.1	1		
room4	6.6	FXFQ63A	7.1	1		
room5	6.9	FXFQ63A	7.1	1		
room6	7	FXFQ63A	7.1	1		
majlis1	25.7	FXFQ50A	5.6	5		
majlis2	23.9	FXFQ50A	5.6	4		

**Table2-12:Specification of outdoor and indoor unit for riser 2:**

Name of the room	Cooling load (kW)	Name of indoor unit	Capacity of indoor unit (kW)	Num. of indoor unit	Dim.of indoor unit (mm)	Specifications Of outdoor unit
shop	70	FXFQ63A	7.1	10	60X950X950	Capacity range : 54 hp Cooling load : 150 kW Heating capacity : 168 kW
restaurant	73.5	FXFQ63A	7.1	11		

**Table2-13:Specification of outdoor and indoor unit for riser 3:**

Name of the room	Cooling load (kW)	Name of indoor unit	Capacity of indoor unit (kW)	Num. of indoor unit	Dim. of indoor unit (mm)	Specifications Of outdoor unit
room1	5.6	FXFQ50A	5.6	1	60X950X950	Capacity range : 30 hp Cooling load : 83.5 kW Heating capacity : 93.5 kW
room2	5.1	FXFQ50A	5.6	1		
room3	5.4	FXFQ50A	5.6	1		
room4	5.2	FXFQ50A	5.6	1		
room5	5.5	FXFQ50A	5.6	1		
room6	6.1	FXFQ50A	5.6	1		
room7	5.6	FXFQ50A	5.6	1		
room8	5.4	FXFQ50A	5.6	1		
room9	5.2	FXFQ50A	5.6	1		
room10	5.3	FXFQ50A	5.6	1		
room11	6	FXFQ50A	5.6	1		
account	4.5	FXFQ40A	4.5	1		
manag	4.3	FXFQ20A	2.2	2		
secer	3.6	FXFQ32A	3.6	1		
room	5	FXFQ50A	5.6	1		

### 2.5.6 Selection of pipes and joints

This table show the characteristics of pipes and joints for VRV system .

**Table2-14:Specification of pipes and joints for riser 2 .**

Name of the room	Dim. from indoor to header (in)	Dim. from header to refnet joint(in)	Dim. From refnet joint to refnet joint(in)	Dim. From refnet joint to outdoor(in)
shop	5/8 X 3/8	1 1/8 X 1/2	-----	1 5/8 X 3/4
restaurant	5/8 X 3/8	1 3/8 X 3/4	-----	

**Table2-15:Specification of pipes and joints for riser 1 .**

<b>Name of the room</b>	<b>Dim. from indoor to header (in)</b>	<b>Dim. from header to refnet joint(in)</b>	<b>Dim. From refnet joint to refnet joint(in)</b>	<b>Dim. From refnet joint to outdoor(in)</b>
mosque	5/8 X 3/8	1 1/8 X 1/2	-----	1 5/8 X 3/4
room1	5/8 X 3/8	1 1/8 X 1/2	1 3/8 X 3/4	
room2	5/8 X 3/8			
room3	5/8 X 3/8			
room4	5/8 X 3/8			
room5	5/8 X 3/8			
room6	5/8 X 3/8			
majlis1	5/8 X 3/8	7/8 X 3/8	1 1/8 X 5/8	
majlis2	5/8 X 3/8			

**Table2-16:Specification of pipes and joints for riser 3 .**

<b>Name of the room</b>	<b>Dim. from indoor to header (in)</b>	<b>Dim. from header to refnet joint(in)</b>	<b>Dim. From refnet joint to refnet joint(in)</b>	<b>Dim. From refnet joint to outdoor(in)</b>
<b>room1</b>	5/8 X 3/8	7/8 X 3/8	1 3/8 X 3/4	1 3/8 X 3/4
<b>room2</b>	5/8 X 3/8			
<b>room3</b>	5/8 X 3/8			
<b>room4</b>	5/8 X 3/8			
<b>room5</b>	5/8 X 3/8			
<b>room6</b>	5/8 X 3/8	1 1/8 X 1/2	-----	
<b>room7</b>	5/8 X 3/8			
<b>room8</b>	5/8 X 3/8			
<b>room9</b>	5/8 X 3/8			
<b>room10</b>	5/8 X 3/8			
<b>room11</b>	5/8 X 3/8			
<b>account</b>	5/8 X 3/8	3/4 X 3/8	1 3/8 X 3/4	
<b>manag</b>	5/8 X 3/8			
<b>secer</b>	5/8 X 3/8			
<b>room</b>	5/8 X 3/8			

### 3 Chapter 3: Heating load

#### 3.1 Outdoor and indoor design conditions

These conditions include the dry bulb temperature, relative humidity, and the average air speed. We obtain these values from Meteorological and the psychrometric chart.

**Table 3-1: Outdoor design conditions:**

Season	T <sub>out</sub> (°C)	φ <sub>out</sub> %	v <sub>out</sub> (m <sup>3</sup> /kg dry air)	h <sub>out</sub> (kJ/kg)
Heating	10	66.4	0.845	49

**Table 3-2: Indoor design conditions:**

Season	T <sub>in</sub> (°C)	φ <sub>in</sub> %	h <sub>in</sub> (kJ/kg)
Heating	24	40	46

#### 3.2 Heat loss calculations

The main resources of heat losses come from the walls, floor, ceiling, doors, and windows. To calculate each one of them we use the following equation:

$$Q = A \times U \times (T_{in} - T_{out}) \quad (3.1)$$

Where:

Q : The heat transfer rate (W).

A : Area of the layer which heat flow through it (m<sup>2</sup>).

T : The difference between the inside and outside temperatures (°C).

U: The overall heat transfer coefficient (W/ m<sup>2</sup> . °C).

### 3.2.1 Rate of heat transfer from the external walls:

From Table 2-4 and Figure 2 we know the construction of the external walls, then by using equation (3.1), we can determine the rate of heat transfer for the restaurant as follow :

$$Q_{\text{walls.out}} = U_{\text{walls.out}} \times A_{\text{walls.out}} \times T_{\text{in}} - T_{\text{out}}$$

$$Q_{\text{walls.out}} = 0.833 \times 746 \times 24 - 10$$

$$Q_{\text{walls.out}} = 11.8 \text{ kW}$$

### 3.2.2 Rate of heat transfer from the ceiling:

From Table 2-6 and Figure 4 we know the construction of the ceiling, then by using equation (3.1), we can determine the rate of heat transfer for the restaurant from the ceiling as Follow :

$$Q_{\text{Roof}} = U_{\text{Roof}} \times A_{\text{Roof}} \times T_{\text{in}} - T_{\text{out}}$$

$$Q_{\text{Roof}} = 0.925 \times 398 \times 24 - 10$$

$$Q_{\text{Roof}} = 6.9 \text{ kW}$$

### 3.2.3 Rate of heat transfer from the ground:

by using the equation (3.1), we can determine the rate of heat transfer for the restaurant from the ground as Follow :

$$Q_{\text{Ground}} = U_{\text{Ground}} \times A_{\text{Ground}} \times T_{\text{in}} - T_{\text{out}}$$

$$Q_{\text{Ground}} = 1.038 \times 398 \times 24 - 16$$

$$Q_{\text{Ground}} = 7.8 \text{ kW}$$

### 3.2.4 Rate of heat transfer from the doors and windows:

By using the equation (3.1), we can determine the rate of heat transfer for the restaurant from the doors and windows as follow:

#### Doors:

$$Q_{\text{door}} = U_{\text{door}} \times A_{\text{door}} \times T_{\text{in}} - T_{\text{out}}$$

$$Q_{\text{door}} = 2.4 \times 16.5 \times 24 - 10$$

$$Q_{\text{door}} = 0.75 \text{ kW}$$

#### Windows:

$$Q_{\text{windows}} = U_{\text{windows}} \times A_{\text{windows}} \times T_{\text{in}} - T_{\text{out}}$$

$$Q_{\text{windows}} = 3.2 \times 15.2 \times 24 - 10$$

$$Q_{\text{windows}} = 0.9 \text{ kW}$$

### 3.2.5 Heat loss due to infiltration:

Infiltration is the leakage of the outside air through cracks or clearances around the windows and doors. We use the crackage method to calculate it as follow:

#### For windows :

$$Q_{\text{infiltration}} = m_{\text{inf}} \times (h_o - h_i) \quad (3.2)$$

$$m_{\text{f}} = \frac{V_{\text{f}}}{v_o} \quad (3.3)$$

$$V_{\text{f}} = \text{crack length} \times \text{Infiltration through windows} \quad (3.4)$$

Where  $V_i$  is obtained from table 6-1 at 8 km/h as  $2\text{m}^3/\text{h}$  per meter of crack. the crack length of the five double hung metal windows is :

$$L = 5 \times 2 \times 1.1 + 3 = 41 \text{ m} .$$

$$V_i = 41 \times 2 = 82 \frac{\text{m}^3}{\text{h}} = \frac{82}{3600} = 0.02277 \frac{\text{m}^3}{\text{s}} .$$

$$m_i = \frac{0.02277}{0.846} = 0.0269 \text{ Kg/s} .$$

$$v_0 = 0.907 \text{ m}^3/\text{kg}$$

Then total heat loss due to infiltration is :

$$Q_{\text{infiltration}} = 0.0269 \times 1 \times (49 - 46) = 4.3 \text{ kW}$$

### **For Doors :**

$$Q_{\text{infiltration}} = m_i \times (h_o - h_i)$$

$$m_i = \frac{V_i}{v_0}$$

$$V_i = \text{crack length} \times \text{Infiltration through doors}$$

$$L = 2 \times 2 \times 2 + 3 + 2 \times 1.25 + 3 = 28.5 \text{ m} .$$

$$V_i = 28.5 \times 5.4 = 153.9 \frac{\text{m}^3}{\text{h}} = \frac{153.9}{3600} = 0.0427 \frac{\text{m}^3}{\text{s}} .$$

Where  $V_i$  is obtained from table 6-1 at 8 km/h as  $5.4 \text{m}^3/\text{h}$  per meter of crack. the crack length of the two poorly fitted doors is :

$$m_i = \frac{0.0427}{0.846} = 0.05 \text{ Kg/s} .$$

$$v_0 = 0.907 \text{ m}^3/\text{kg}$$

Then total heat loss due to infiltration is :

$$Q_{\text{infiltration}} = 0.05 \times 1 \times (49 - 46) = 2.8 \text{ kW}$$

### 3.2.6 Heat loss due to ventilation:

$$Q_{\text{ventilation}} = m_{\text{ventilation}} \times h_{\text{out}} - h_{\text{in}} \quad (3.5)$$

$$m_v = \frac{V_v}{v_0} \quad (3.6)$$

$$V_v = \text{minimum outside air requirements ventilation} \times \text{No. of persons} \quad (3.6)$$

minimum outside air requirements ventilation from Table 5-4

Also, from the psychrometric chart, at the given outside conditions then the specific volume

$v_0$  of outside air is :

$$v_0 = 0.846 \text{ m}^3/\text{kg}$$

$$m_v = \frac{75 \text{ (l/s)}}{0.846(1000)} = 0.62 \text{ kg/s}$$

Then total heat loss due to ventilation is :

$$Q_{\text{ventilation}} = 0.62 \times 1000 \times 49 - 46$$

$$Q_{\text{ventilation}} = 1.86 \text{ kW}$$

Finally, the total load for this restaurant is the summation of all the heat gain resources .

$$Q_{\text{total}} = 11.8 + 6.9 + 7.8 + 0.75 + 0.9 + 6.2 + 1.86$$

$$Q_{\text{total}} = 36.2 \text{ kW}$$

**Table 3-3: The heating load for each room in the building:**

Name of room	Cooling load (kW)	Area (m <sup>2</sup> )	Name of room	Cooling Load (kW)	Area (m <sup>2</sup> )
<b>Ground Floor</b>			<b>First Floor</b>		
<b>shop</b>	31.15	369.45	<b>room1</b>	3.2	33.01
<b>restaurant</b>	36.2	398	<b>room2</b>	2.7	31.5
<b>mosque</b>	14.9	167.57	<b>room3</b>	2.9	31.5
<b>room1</b>	4.1	33.31	<b>room4</b>	2.8	31.5
<b>room2</b>	3.4	31.5	<b>room5</b>	3	33
<b>room3</b>	3.4	31.5	<b>room6</b>	3.1	33.3
<b>room4</b>	3.4	31.5	<b>room7</b>	2.6	31.5
<b>room5</b>	3.4	31.5	<b>room8</b>	2.8	31.5
<b>room6</b>	4.1	33.31	<b>room9</b>	2.7	31.5
<b>majlis1</b>	7.1	66.03	<b>room10</b>	2.4	31.5
<b>majlis2</b>	8.4	80.34	<b>room11</b>	2.9	33.3
			<b>account</b>	3	16.5
			<b>manag</b>	2.6	12.4
			<b>secer</b>	1.9	10.2
			<b>room</b>	2.8	21.6

### 3.3 Mechanical ventilation

The purpose of ventilation is to provide fresh air for comfort and to ensure healthy indoor air quality by diluting contaminants to provide fresh air, moisture, odors, and other pollutants can build up inside a home.

Mechanical ventilation systems circulate fresh air using ducts and fans, rather than relying on air flow through small holes or cracks in a home's walls, roof, or windows. Homeowners can breathe easier knowing their home has good ventilation...

#### 3.3.1 How ventilation system work?

A variety of mechanical ventilation systems are available to select, based on local climate and the home's heating and cooling system. In addition to one of the primary systems described below, "spot" ventilation fans should also be provided for kitchens and baths to remove the concentrated moisture and odors that can occur in these rooms.

**3.3.2 Ventilation benefits**

- Better Indoor Air Quality. Indoor air can be many times more polluted than outdoor air. Ventilation systems can significantly improve a home’s air quality by removing allergens, pollutants, and moisture that can cause mold problems.
- More Control. When homes rely on air flow through walls, roofs, and windows for ventilation, there is no control over the source or amount of air that comes into the house. In fact, air leaking into the house may come from undesirable areas such as the garage. Mechanical ventilation systems provide proper fresh air flow along with appropriate locations.
- Improved Comfort. Mechanical ventilation systems allow a constant flow of outside air into the home and can also provide filtration, dehumidification, and conditioning of the incoming outside air.

**3.3.3 Design air ventilation**

we used Ventilation Rates Calculator 2015 program to calculate required Ventilation for Kitchen and bathrooms.



**Figure 6: Calculation the Ventilation by program for kitchen**



Figure 7: Calculation the Ventilation by program for bathroom

Table 3-4 Description of fans used for air change

Type fan	Flow Rate (L/s)	Working principle	Dimension (cm)
Lineo 100 Q V0	43.1	Polluted air outlet	15X23
M 100/4	25	Fresh air inlet and Polluted air outlet	15X16
M 120/5	48.6	Fresh air inlet and Polluted air outlet	17X18

## 4 Chapter 4 : Plumbing System

### 4.1 Water supply system

#### 4.1.1 Fixture unit load calculations:

In this section calculate the total amount of cold and hot water in the that required for the restaurant. By using the water supply fixture unit technique. We use this technique because we have a huge number of fixture units and that make this technique more accurate.

##### 4.1.1.1 Fixture unit load for the collector in restaurant

**Table 4-1: The fixture units load for collector A:**

Fixture Type	No. of Fixture unit	Load per Fixture unit	Total load for cold water	Total load for hot water
Water closet (G)	3	5	15	0
Lavatory (G)	3 × 3/4	2	6	4.5
<b>Total (FU)</b>			<b>21</b>	<b>4.5</b>
<b>Total (gpm)</b>			<b>15</b>	<b>5</b>

**Table 4-2: The fixture units load for collector B:**

Fixture Type	No. of Fixture unit	Load per Fixture unit	Total load for cold water	Total load for hot water
Water closet (G)	3	5	15	0
Lavatory (G)	3 × 3/4	2	6	4.5
<b>Total (FU)</b>			<b>21</b>	<b>4.5</b>
<b>Total (gpm)</b>			<b>15</b>	<b>5</b>

**Table 4-3: The fixture units load for collector C:**

Fixture Type	No. of Fixture unit	Load per Fixture unit	Total load for cold water	Total load for hot water
Water closet (G)	2	5	10	0
Lavatory (G)	2 × 3/4	2	4	3
Kitchen Sink	1 × 3/4	4	4	3

Shower head (G)	1 × 3/4	5	5	3.75
		<b>Total (FU)</b>	<b>23</b>	<b>9.75</b>
		<b>Total (gpm)</b>	<b>16</b>	<b>8</b>

**Table 4-4: Table for estimating demand for collector 1:**

The total amount of cold and hot water	Total load WSFU	Total Demand gpm
Total demand for cold water	21	---
Total demand for hot water	4.5	---
<b>Total (FU)</b>	<b>25.5</b>	<b>17</b>

**Table 4-5: Table for estimating demand for collector 2:**

The total amount of cold and hot water	Total load WSFU	Total Demand gpm
Total demand for cold water	21	---
Total demand for hot water	4.5	---
<b>Total (FU)</b>	<b>25.5</b>	<b>17</b>

**Table 4-6: Table for estimating demand for collector 3:**

The total amount of cold and hot water	Total load WSFU	Total Demand gpm
Total demand for cold water	23	---
Total demand for hot water	9.75	---
<b>Total (FU)</b>	<b>32.75</b>	<b>22</b>

The total amount of cold and hot water supply fixture unit for collector 3 is 23 WSFU and 9.75 WSFU. After determined the amount of WSFU we use the table for estimating demand to calculate the total required amount of cold and hot water which is 22 gallon per minute (gpm).

#### 4.1.2 Friction method

The water velocity in the piping system in building is not preferred to exceed 8fps. Outside building it may exceed 8 fps. Note: (1m = 3.28 ft).

Calculate sizing pipe for collector1 cold water.

1) The maximum instantaneous cold water demand is 21, And from table 9-4  
by interpolation : 45FU = 15 gpm

2) Static head = floor to floor height + tank outlet height  
– sink faucet outlet height

$$\text{Static head} = (2 + 7.95 - 1)/0.33 \times 0.433 = 11.74 \text{ ft}$$

3) Total Equivalent length (TEL) =  $((2 + 1.3 + 7.95 + 4.6 + 1)/0.33) \times 1.5 = 77 \text{ ft}$

4) Minimum flow pressure at the critical fixture = 8psi , from table 9-1

5) friction head = static pressure +min. flow pressure

$$\text{friction head} = 11.74 - 8 = 3.74 \text{ psi}$$

6) friction loss = friction head / TEL

$$= 3.74 / (0.77 \times 100) = 4.85 \text{ psi/100ft}$$

7) From figure 9-5 steel pipes :-

Flow rate = 15 gpm  
Friction head loss = 4.85 psi/100ft } pipe size = 1"

Calculate sizing pipe for collector1 hot water:-

1) The maximum instantaneous hot water demand is 21, And from table 9-4  
by interpolation : 4.5FU = 5 gpm

2) Static head = floor to floor height + tank outlet height  
– sink faucet outlet height

$$\text{Static head} = (2 + 7.95 - 1)/0.33 \times 0.433 = 11.74 \text{ ft}$$

3) Total Equivalent length (TEL) =  $((2 + 1.5 + 7.95 + 2.4 + 1)/0.33) \times 1.5 = 68 \text{ ft}$

4) Minimum flow pressure at the critical fixture = 8psi , from table 9-1

5) friction head = static pressure +min. flow pressure

$$\text{friction head} = 11.74 - 8 = 3.74 \text{ psi}$$

6) friction loss = friction head / TEL

$$= 3.74 / (0.68 \times 100) = 5.5 \text{ psi/100ft}$$

7) From figure 9-5 steel pipes :-

Flow rate = 5 gpm  
Friction head loss = 5.5 psi/100ft } pipe size = 3/4"

#### 4.1.3 Calculation of branch and riser :-

##### 4.1.3.1 Table shows the sizing pipe for cold water

**Table 4-7 : The sizing pipe for cold water on the ground floor :**

<b>Riser</b>	<b>Flow rate (gpm)</b>	<b>Total equivalent length (ft)</b>	<b>Friction (psi/100ft)</b>	<b>Pipe size (inch)</b>	<b>Velocity (fps)</b>
<b>Riser1</b>	15	77	4.85	1"	5
<b>Riser2</b>	15	77	4.85	1"	5
<b>Riser3</b>	16	68	5.5	3/4"	5
<b>Riser4</b>	18	111	6.3	1 1/4"	6
<b>Riser5</b>	18	115	6	1 1/4"	6
<b>Riser6</b>	19	165	3.8	1 1/4"	5
<b>Riser7</b>	19	102	6.17	1 1/4"	6
<b>Riser8</b>	19	90	7	1 1/4"	6

**Table 4-8 : The sizing pipe for cold water on the first floor :**

<b>Riser</b>	<b>Flow rate (gpm)</b>	<b>Total equivalent length (ft)</b>	<b>Friction (psi/100ft)</b>	<b>Pipe size (inch)</b>	<b>Velocity (fps)</b>
<b>Riser9</b>	17	99	1.2	1 1/2"	3
<b>Riser10</b>	23	94	1.3	1 1/2"	5
<b>Riser11</b>	29	169	0.7	2"	3
<b>Riser12</b>	29	151	0.8	2"	3
<b>Riser13</b>	29	72	1.6	2"	4
<b>Riser14</b>	9	77	3.2	1"	4

4.1.3.2 Table shows the sizing pipe for hot water

Table4-9: The sizing pipe for hot water on the ground floor :

Riser	Flow rate (gpm)	Total equivalent length (ft)	Friction (psi/100ft)	Pipe size (inch)	Velocity (fps)
Riser1	5	75	4.98	3/4"	5
Riser2	5	75	4.98	3/4"	5
Riser3	8	69	5.3	1"	5
Riser4	5	113	6.2	3/4"	5
Riser5	5	114	6.1	3/4"	5
Riser6	8	166	3.8	1"	4
Riser7	8	100	6.3	3/4"	5
Riser8	8	92	6.8	3/4"	5

Table 4-10 : The sizing pipe for hot water on the first floor :

Riser	Flow rate (gpm)	Total equivalent length (ft)	Friction (psi/100ft)	Pipe size (inch)	Velocity (fps)
Riser9	8	100	1.2	1 1/4"	3
Riser10	12	95	1.3	1 1/4"	3
Riser11	15	168	0.7	2"	3
Riser12	15	150	0.8	2"	3
Riser13	15	73	1.6	2"	3
Riser14	2	78	3.2	1/2"	3

## 4.2 Drainage system

The wastewater system should be designed, constructed, and maintained to guard against fouling, deposit of solids, and clogging. And the foul air in the wastewater system should be exhausted to the outside, through vent pipes.

We made our calculations using the table of drainage fixture unit values for various plumbing fixture to find the amount of drainage fixture unit (dfu). Then we use the table of horizontal fixture branch and stuck to determine the diameters of the pipes.

### 4.2.1 Table shows the drainage fixture unit and sizing the stack

**Table 4-11 : Sizing of stack 1:**

Stack 1			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	24	4

**Table 4-12: Sizing of stack 2:**

Stack 2			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	24	4

**Table 4-13: Sizing of stack 3:**

Stack 3			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	20	3

**Table 4-14 : Sizing of stack 4:**

Stack 4			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	6	2

**Table 4-15: Sizing of stack 5:**

Stack 5			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	30	4

**Table 4-16: Sizing of stack 6:**

Stack 6			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	30	4

**Table 4-17:Sizing of stack 7:**

Stack 7			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	10	4	From first floor	10	4
from ground floor to manhole drain	10	4	From ground floor	-----	-----

**Table 4-18:Sizing of stack 8:**

Stack 8			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	10	4	From first floor	10	4
from ground floor to manhole drain	10	4	From ground floor	-----	-----

**Table 4-19:Sizing of stack 9:**

Stack 9			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	10	4	From first floor	10	4
from ground floor to manhole drain	10	4	From ground floor	-----	-----

**Table 4-20: Sizing of stack 10:**

Stack 10			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	10	4	From first floor	10	4
from ground floor to manhole drain	10	4	From ground floor	-----	-----

**Table 4-21: Sizing of stack 11:**

Stack 11			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	10	4	From first floor	10	4
from ground floor to manhole drain	10	4	From ground floor	-----	-----

**Table 4-22: Sizing of stack 12:**

Stack 12			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	20	4	From first floor	20	4
from ground floor to manhole drain	20	4	From ground floor	-----	-----

**Table 4-23: Sizing of stack 13:**

Stack 6			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	20	4

**Table 4-24: Sizing of stack 14:**

Stack 12			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	20	4	From first floor	20	4
from ground floor to manhole drain	20	4	From ground floor	-----	-----

**Table 4-25: Sizing of stack 15:**

Stack 6			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	20	4

**Table 4-26: Sizing of stack 16:**

Stack 12			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	20	4	From first floor	20	4
from ground floor to manhole drain	20	4	From ground floor	-----	-----

**Table 4-27: Sizing of stack 17:**

Stack 6			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from ground floor to manhole drain	-----	-----	From ground floor	20	4

**Table 4-28: Sizing of stack 18:**

Stack 12			Horizontal branch		
Section	Total (dfu)	Pip size (inch)	Branch (section)	Total (dfu)	Pipe size (inch)
from first floor to ground floor	14	4	From first floor	14	4
from ground floor to manhole drain	14	4	From ground floor	-----	-----

**Table 4-29: Building drain:**

Branch of building drain from stack	Total dfu value from stacks	Diameter of building drain (inch)	Slope %	Velocity ft/s
Building drain from stack 1	24	4	1/2	3.86
Building drain from stack 2	24	4	1/2	3.86
Building drain from stack 3	20	3	1/2	3.19
Building drain from stack 4	6	2	1/2	2.43
Building drain from stack 5	30	4	1/2	3.86
Building drain from stack 6	30	4	1/2	3.86
Building drain from stack 7	10	4	1/2	3.86
Building drain from stack 8	10	4	1/2	3.86
Building drain from stack 9	10	4	1/2	3.86

Building drain from stack 10	10	4	$\frac{1}{2}$	3.86
Building drain from stack 11	10	4	$\frac{1}{2}$	3.86
Building drain from stack 12	20	4	$\frac{1}{2}$	3.86
Building drain from stack 13	20	4	$\frac{1}{2}$	3.86
Building drain from stack 14	20	4	$\frac{1}{2}$	3.86
Building drain from stack 15	20	4	$\frac{1}{2}$	3.86
Building drain from stack 16	20	4	$\frac{1}{2}$	3.86
Building drain from stack 17	20	4	$\frac{1}{2}$	3.86
Building drain from stack 18	14	4	$\frac{1}{2}$	3.86

## 5 Chapter 5: Firefighting System

property management is entrusted with the responsibility of protecting and preserving an institution's buildings, collections, operations and occupants. Constant attention is required to minimize adverse impact due to climate, pollution, theft, vandalism, insects, mold and fire. Because of the speed and totality of the destructive forces of fire, it constitutes one of the more serious threats. An uncontrolled fire can obliterate an entire room's contents within a few minutes and completely burn out a building in a couple hours.

The first step toward halting a fire is to properly identify the incident, raise the occupant alarm, and then notify emergency response professionals. This is often the function of the fire detection and alarm system. Several system types and options are available, depending on the specific characteristics of the protected space.

Fire fighting systems and equipment vary depending on the age, size, use and type of building construction. A building may contain some or all of the following features:





- Fire extinguishers.
- Fire hose reels.
- Fire hydrant systems.
- Automatic sprinkler systems.

In the following sections each feature is to be described.

### 5.1 Fire extinguisher

Fire extinguishers are provided for a 'first attack' fire fighting measure generally undertaken by the occupants of the building before the fire service arrive. It is important that occupants are familiar with extinguisher type to use on fire. Most fires start as a small fire and may be extinguished if the correct type and amount of extinguishing agent is applied whilst the fire is controllable.

The following table shows the principle use for different extinguishing agent :

ID sign	Typical appearance	Extinguisher Type cylinder contains	<b>Class A</b> Wood, paper, textiles etc, normal combustibles	<b>Class B</b> Flammable liquids, petrol, paints	<b>Class E</b> Electrical fires	<b>Class F</b> Cooking oil, animal fats & vegetable oils
		<b>Dry Chemical Powder</b>	YES	YES	YES	NO
		<b>Co2 Carbon Dioxide</b>	NO	YES	YES	NO
		<b>Water</b>	YES	NO	NO	NO
		<b>Foam</b>	YES	YES	NO	NO
		<b>Wet Chemical</b>	YES	NO	NO	YES

**Figure 8: Fire extinguisher rating guide**

Fire extinguisher locations must be clearly identified. It is the policy of the Community Safety , Department that fire extinguishers be logically grouped at exits from the building, so that occupants first go to the exit and then return to fight the fire, knowing that a safe exit behind them away from the fire. In some instances this will be at odds with the prescriptive requirements of Australian Standard AS2444 Portable fire extinguishers and fire blankets - Selection and location which simply specifies a distance of travel to a fire extinguisher rather than their location in relation to escape paths.

## 5.2 Fire hose reel

Fire Hose cabinet should be installed according to NPFA 14 and shown in drawings:

1-Near escape stairs

2- 30 m(100ft) length of the pipe which is the distance traveled by the pipeline passing barriers and walls until it reaches the fire place .

3- Next to the main door of the building.

4- Fire house cabinet height above the ground (90-150)cm.

Note: all Fire Hose cabinet distribution is shown on drawings..

Fire house cabinet includes two types:

a) Hose Reel :



**Figure 9: Hose Reel**

b) Hose Rack:



**Figure10 : Hose Rack**

## 5.3 Fire hydrant system

Located in the street and it is used in case that we couldn't overcome the fire from inside the building .

Fire Hydrant should be installed according to NPFA 14:

-A pipe with 4'' diameter branched into two pipes each with 2.5'' diameter with a flow of 250 gpm.



**Figure 11: Fire hydrant**

#### **5.4 Automatic sprinkler system**

Time is essential in the control of fire. Automatic sprinkler systems are one of the most reliable methods available for controlling fires. Today's automatic fire sprinkler systems offer state of the art protection of life and property from the effects of fire. Sprinkler heads are now available which are twenty times more sensitive to fire than they were ten years ago.

A sprinkler head is really an automatic (open once only) tap. The sprinkler head is connected to a pressurized water system. When the fire heats up the sprinkler head, it opens at a preset temperature, thus allowing pressurized water to be sprayed both down onto the fire and also up to cool the hot smoky layer and the building structure above the fire. This spray also wets combustible material in the vicinity of the fire, making it difficult to ignite, thereby slowing down or preventing fire spread and growth.

When a sprinkler head operates, the water pressure in the system drops, activating an alarm which often automatically calls the fire brigade via a telephone connection .

## 5.5 Smoke sensor

A smoke detector is a device that senses smoke, typically as an indicator of fire. Commercial security devices issue a signal to a fire pump to open Automatically as part of a fire alarm system.



**Figure 12: Smoke sensor**

## 5.6 Pumps room

### 5.6.1 Component and equipment used

In any fire fighting system we need water to be pumped until it reaches the desired fire place .

1- Gate valve

2- check valve : It prevents back flow, and allows only flow in on direction, and is installed in pump discharge line directly to prevent pumps from starting at a load or at the system pressure.

3- Suction header: It prevents vortex

4- Discharge header

5- Diesel pump: It's a 100% stand-by pump, operates in case of power failure with the failure of pressure make up process by the electric pump, or to even with the present of power if failure of pressure make up process.

**6- Jockey pump** :It's the first pump to start in case of fire, It operates as a pressure maintenance pump so in case of a leakage in the system pressure it will makes the system pressure as recommended, and A jockey pump should be sized to make up the allowable leakage rate within 10 minutes or 1GPM (3.8 L/min), whichever is larger, and is used for this job instead-off starting the electric pump to protect it from starting until a serious problem occurs.

7- Electric pumps : It's the second pump to start in case of fire; it's the 100% duty pump.

8- Pressure relief valve : A valve being set at a pressure higher than the system pressure or shut off pressure of the diesel pump to protect the system from the very high pressure generated by the diesel pump in case of sudden acceleration.

The relief valve shall be located between the pump and the pump discharge check valve and shall be so attached that it can be readily removed for repairs without disturbing the piping.

**Note:** - locations of all gate valves in the pump room are mainly for make ease maintenance for each component in the room and without loss water in pipes as possible as we can and for make maintenance which stops the system 100 % is very not possible as we can.

9- Flow switch It gives signal when a flow happened in a pipe.

10- Fuel tank Which is used in diesel pump

### **5.6.2 Shut off of the pumps**

1- The Jockey pumps stops automatically when the pressure in pipes reached its rated pressure.

2- The Electric pump stops after reached the rated pressure by 10 minutes.

3- The Diesel pump stops after 30minutes after reaching its rated pressure.

## 5.7 Pipe size calculation

The fire hose reel system is to be used, so the pipe size for this system will be calculated as follows:

The minimum flow rate for single cabinet = 23 (l/min) .

Then:

The total flow rate = min. flow rate × No. of cabinet

The total flow rate = 23 × 6 = 138 L/min = 8.22 m<sup>3</sup>/h = 36.16gpm

**Table 5-1:Pipe schedule for supply piping**

Total Accumulated Flow		Total Distance of Piping from Farthest Outlet		
L/min	gpm	<15.2 m (<50 ft)	15.2–30.5 m (50–100 ft)	>30.5 m (>100 ft)
379	100	2	2½	3
382–1893	101–500	4	4	6
1896–2839	501–750	5	5	6
2843–4731	751–1250	6	6	6
4735	1251 and over	8	8	8

Note: For SI units, 3.785 L/min = 1 gpm; 0.3048 m = 1 ft.

Then the

is to be used to calculate the pipe size by follow the next procedure. First, the total flow Table rate is determined which is 138 l/min for our calculation sample. Then the total distance of piping from farthest outlet is to be chose. Finally, the intersection between the two values in

Table will give the size of pipe supply which is equal to 3".

Standpipes are classified in NFPA 14 into the following three groups on the basis of hose size and use:

- Class I: Provided with 2½-inch hose stations and intended primarily for use by fire department personnel and not by building occupants.

- Class II: Provided with 1½-inch hose stations and intended for use by building occupants as well as by fire department personnel.
- Class III: Provided with 1½-inch and 2½-inch hose stations and intended for use by building occupants as well as by fire department personnel.

Then to determine the outlet pipe size from pipe supply to hose connection the class of the building must be chosen from the NFPA. For this building the class is chosen to be class II. A class II referred to NFPA means: standpipe system provides (1½-in.) hose stations to supply water for use primarily by the building occupants or by the fire department during initial response. According to the NFPA 14 the pressure required for the (1½-in.) pipes is 6.9 bar.

## 6 Chapter 6 : Photovoltaic System

There are tow system :

- **On-Grid system**
- **Off-Grid Solar system**

### 6.1 On grid solar

**Definition:** On-Grid Systems are solar PV systems that only generate power when the power grid is available and interface with the grid to send excess power out when you are over producing so you can bank it for later use.

**Benefits:** These are simplest systems and the most cost effective to install. These systems will pay for themselves by offsetting utility bills in 6-10 yrs.

**Downside:** These do not provide power during a grid outage.

### 6.2 Off grid solar

**Definition:** These systems allow you to store your solar power in batteries for use when the power grid goes down. Additionally, they provide power to offset the grid power whenever the sun is shining and will even send excess power to the grid to bank if for later use.

**Benefits:** Provides power for critical loads when they power grid is down.

**Downside:** Cannot be expected to provide power for all loads since the cost and volume of batteries would be prohibitive. Off-Grid systems require a lot more specialized equipment to function that is more costly and more complex to install. Specifically they require a central/string inverter, a charge controller as well as a batteries.


Sizing the solar array and the batteries required is complex. Detailed analysis of requirements will be needed to provide for minimal critical needs. You'll also need to rewire you main electrical panel to isolate the "critical loads" so that only they are provided power in an

outage. This means that your well pump, refrigerator and a few lights are provided power while your air conditioners and TV and other non-essential loads are not.

This is definitely not a homeowner installable system. Installing it is both dangerous and complex. Also, batteries are expensive, require ongoing maintenance and periodic replacement.

Given the additional specialized equipment required and the fact that it required expert installation, expect a off-grid system to cost four(4) times as much to install per watt and to require ongoing maintenance outlays.

**6.3 Calculation**



**Figure 13: panel in series**

$$V_{Rated} = N \times V_{mpp} \tag{6.1}$$

N : panel in series (shown on drawings)

V<sub>mpp</sub> : Voltage at maximum power from data sheet.

$$V_{Rated} = 2 \times 36.1 = 72.2 \text{ volt/string.}$$

the inverter range from data sheet is (44-85) volt so is 72.2V Acceptable.

We can use 76 panel on different surfaces of the Building.

$$\text{Area of panels} = \text{number of panels} \times \text{area of one panel} \tag{6.2}$$

\* Area of one panel from data sheet (1966mm X 1000mm X 50mm)

$$\text{Area of panels} = 76 \times 1.966 = 149 \text{ m}^2$$

$$\text{Area Of the roof that we need} = \frac{\text{Area of panels}}{0.4} = \frac{149}{0.4} = 372.5 \text{ m}^2$$

$$P_{DC} = 1k \times \mu_{pv} \times \text{Area of panel} = 1000 \times 14\% \times 149 = 20860 \text{ W}$$

module efficiency  $\mu_{pv}$  from data sheet .

$$P_{AC} = \mu_{\text{Conventional}} \times P_{dc} = 75\% \times 20860 = 15645 \text{ W}$$

Data Sheet For the Inverter.

Manufacturer:	Xantrex	Xantrex	Xantrex	Sunny Boy	Sunny Boy
Model:	STXR1500	STXR2500	PV 10	SB2000	SB2500
AC power:	1500 W	18,000 W	10,000 W	2000 W	2500 W
AC voltage:	211–264 V	211–264 V	208 V, 3Φ	198–251 V	198–251 V
PV voltage range	44–85 V	44–85 V	330–600 V	125–500 V	250–550 V
MPPT:					
Max input voltage:	120 V	120 V	600 V	500 V	600 V
Max input current:	—	—	31.9 A	10 A	11 A
Maximum efficiency:	92%	94%	95%	96%	94%

## 7 Chapter 7: Bills Of Quantity

Table 7-1: Bills of quantities for pilgrims rest building :

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<p><b>Preamble.</b></p> <p>a- The contractor shall, when pricing the rates of this bill, take into consideration to include and allow for the costs and expenses of all requirements stipulated herein below, drawings and the specifications of the tender.</p> <p>b- The contractor should visit the site to verify the amount of work and familiarize himself with the nature of work for proper construction of the new floors.</p> <p>c- c-The surplus &amp; demolished materials shall be removed out from the site to a dump site approved by the municipality through a pre-coordinated manner to ensure minimal noise and dust pollution within the vicinity and to avoid obstruction for building activities. The contractor should coordinate with the client for any possible materials or elements that need to be preserved and handed over to the client stores.</p> <p>The contractor is requested to equally consider the following notes when quoting his prices:</p> <p>1- The price shall include all required chipping in concrete walls, cutting holes (any diameter), excavation, backfilling and cement covering as specified.</p> <p>2- The Contractor is requested to read the bill of quantities in conjunction with the set specifications, drawings, addendums and contract conditions</p> <p>3- (S &amp; I) implies supply and install, including testing, adjusting,</p>				

	balancing, ...all the way to a successful operation, including the commissioning.				
12.1	Supply and Install porcelain wall mounted W.C white color European type or E.A. Price shall include all fixation and hanging bracket, 8-LT Capacity .(concealed) cistern ,valves ,fitting, hard solid seat and 13mm stop angle valve , chrome plated 13mm hose , and accessories , side 1 m length 13mm chrome plated hand shower for W.C (heavy duty ) with spring nozzle outlet and all other required materials, including connection to drainage system and water system including 3/8" angle valve (European type or E.A) and paper holder. All to be done as per drawings, specifications and the approval of the Engineers.	NO.	33	600	19800
12.2	ditto , but for handicapped toilet (creavit type),including all necessary fitting and accessories as shows on drawings and in specifications. price includes supplying and installing 40 * 60 cm mirror	NO.	2	1000	2000
12.3	Supply and install porcelain wall hung semi pedestal wash basin European type class A, size (45* 55) cm. Complete with all fittings, valves, waste pipes to nearest floor trap, taps (mixers) (Class A and approved by Palestine Standards Institution), connection to water distribution, traps, with soap holder and any other necessary parts as Specification and as directed by Eng. Price including supplying and installing 40*60cm Aluminum framed mirror.	NO.	20	500	10000
12.4	Supply and Install White Vitreous European Sink (30 cm. Deep) double bowl. (Class A and approved by Palestine Standards Institution). Complete with all necessary valves, Goose neck taps (mixer) (Class A and approved by Palestine Standards Institution), connection to water distribution, fittings, anti-chemical waste siphon, and any other necessary parts and accessories to complete works per specifications and as directed by Engineer.	NO.	1	450	450
<b>Total for this page</b>					<b>32250</b>

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				32250
12.5	a. Supply and Install 4” PVC Floor Trap. “With Quality approval Tag” Price to include siphon to be fixed in reinforced concrete, (20*20) cm double Chrome plated cover one grated and one-closed, the connection with 2” pipe) And all other fittings needed to comply with specifications and as directed by Engineer.	NO.	45	80	3600
12.7	Supply and Install (Clean Out) UPVC 4”, of Drainage Network. “With Quality approval Tags” In size and location shown in the drawings and where necessary, including all needed to complete work as specification and directed by Eng.	NO.	57	70	3390
12.8	UPVC Drainage Pipe and UPVC Fittings: Supply, installation, testing and commissioning of UPVC drainage and ventilation pipes down to manholes with all required fittings including excavation, back filling, incasing with concrete and roof vent caps, including connections as shown in drawings and in accordance to specifications.				
	a- Size 2-inch diameter. b-	MR	220	12	2640
	c- Size 4-inch diameter. d-	MR	100	19	1900
	d- Size 6-inch diameter. e-	MR	290	35	10150
	e- Size 8-inch diameter. f-	MR	350	45	15750
	<b>Total for this page</b>				37430
	<b>TOTAL CARRIED TO NEXT PAGE</b>				69680

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				69680
12.9	Roof Drains: Supply, installation and commissioning of U.P.V.C Rain water(Storm Water) roof drain (Class A and approved by Palestine Standards Institution) .	NO.	8	80	640
12.10	Rain Water pipes: - U.P.V.C rain(storm) water pipes down to a free discharge with wired mesh above ground level, with all required hanging accessories, fittings and vent caps, all as shown in drawings, specifications, and approval of supervisor engineer. U.P.V.C Pipe of 4 -inch diameter.	MR	180	15	2700
12.11	Supply Materials for , and Construct Manholes In compliance with specifications and Drawings. Price to include excavation, concrete works, block works, back filling, cement plaster, benching, Cast Iron cover of weight not less than 50 kg, and bearing capacity load for the cover not less than 8 ton. And all necessary works to comply with drawings and specifications.				
	a. Manholes Ø 50 cm clear size	NO.	19	300	5100
	a. Manholes Ø 60 cm clear size	NO.	9	350	2450
	b. Manholes Ø 80 cm clear size	NO.	14	450	4500
	d. Manholes Ø 100 cm clear size	NO.	2	600	1800
12.12	Supply Materials for , and Construct Manholes Oil separator In compliance with specifications and Drawings. Price to include excavation, concrete works, block works, back filling, cement plaster, benching, Cast Iron cover of weight not less than 50 kg, and bearing capacity load for the cover not less than 8 ton. And all necessary works to comply with drawings and specifications.				
	Manholes Ø 120 cm clear size	NO.	1	950	950
	<b>Total for this page</b>				18140
	<b>TOTAL CARRIED TO NEXT PAGE</b>				87820

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				87820
12.13	<p><b>WATER METER:</b> Supply and install Water meter inside steel box, as per specification, drawings and supervisor engineer. Price includes all galvanized steel main water pipes (Ø ¾") or more, (Class A and approved by Palestine Standards Institution) with asphalt protection (factory covered), laid underground with all necessary fittings e.g. elbows, T's, unions, stop valves, non-return valves, automatic air vents, of best quality (Class A and approved by Palestine Standards Institution).</p>	L.S	1	1000	1000
12.14	<p>Supply and install of approved quality local made solar heating unit including 2 solar plates 0.90*1.90m and 200 Lit Cylindrical double jacket galvanized steel tank with glazed lining And also it works in electric powered water heating , the price also includes automatic air vent and all required fittings and connections.</p>	NO.	11	1600	17600
12.15	<p>Galvanized cold &amp; hot water supply pipes: Supply and installation of cold water distribution network of galvanized pipes of various diameters, (Seamless piping as per standard ASTM-A53schedule 40). From roof to sanitary fixture collectors and external water distribution network. Price includes all fittings, T's, elbows, insulation, etc., and all is needed to complete the works.</p>				
	1- 1/2" pipe size	MR	30	14	420
	2- 3/4" pipe size	MR	180	18	3240
	3- 1" pipe size.	MR	200	26	5200
	4- 1, 1/4" pipe size.	MR	90	30	2700
	5- 1, 1/2" pipe size.	MR	50	35	1750
	6- 2" pipe size	MR	150	43	6450
12.16	<p>Water Filter. The unit price shall include, isolating valves, check valves, pressure relief valve, automatic back wash and all accessories as called for in the Specification.</p>	NO.	1	1000	1000
	<b>Total for this page</b>				39360
	<b>TOTAL CARRIED TO NEXT PAGE</b>				127180

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				127180
12.17	Supply and install Hot and cold-water collectors with aluminum box price includes copper collectors, automatic air vent and with all necessary fittings (Italian made), all according to drawings specifications and Engineer's approval.				
	1- size 3/4'' for EYES 24	NO.	14	250	3500
12.18	Supply and install the outlets for hot and cold water feeding lines to the sanitary fixture units (Class A and approved by Palestine Standards Institution), the price includes all needed Pex. Pipes of 16mm diameter and a 2.2mm thickness (type Vesbo or equivalent ), with a network connection not less than 75% and a 10 bar pressure ,and isolated by a 1'' PVC pipe for protection , and that's from collector to the sanitary outlet, and copper bent 16mm*1/2'' all with its plastic box, all according to drawings specifications and Engineer's approval.	NO.	31	18	558
12.19	Solenoid valve Supply and installation of works by 220 volts natural state is closed for Solenoid valve includes installation and electric wires needed to run made by Spartan Scientific or EA.	NO.	5	50	250
12.20	Supply and install LIFTING pump in the mechanical room of approved manufacture, including all valves, strainer, pressurized tank, electrical power supply complete with concrete base and connections to rising main, the price include all pipes from pump to roof tanks. All are according to drawings and specifications and approval of supervisor engineer. A 50m <sup>3</sup> /hr & 27m head.	NO.	2	2500	5000
12.21	Supply and Install PVC White Water Tank Two 2 Cubic meters in size for water system. Price to include well-painted steel stand, automatic float valves, valves, fittings, vents, watertight cover, lock and all necessary works to complete works as per Specifications and drawings.	NO.	13	400	5200
	<b>Total for this page</b>				14508
	<b>TOTAL CARRIED TO NEXT PAGE</b>				141688

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				141688
12.22	Supply and install a fire hose cabinet , made of galvanized steel of thickness 1.5 mm , price includes hinges lock, pipes ,valves ,extinguisher Co2 , nozzles ,1 1/2’’hose reel ,1 1/2’’ linen hose ,and all necessary accessories to be exist inside this fire cabinet as details on drawings and all according to specification and Engineer’s approval .	NO.	6	600	3600
12.23	Supply, install, test and commission package type electric driven split case end suction multi-stage booster pump, LPC Approved, for firefighting system. The set is composed of three pumps (one is electrical pump, the second one is a diesel pump, and the third one is a jockey pump), and control panel. The price includes all fittings needed for installation, such as but not limited to, strainers, stop valves, flexible joints, OS & Y valves, non-return valves, ..... On addition to reinforced concrete bases, anti-vibration isolators, pressurized tank, pressure switches, pressure gauges, electric floating valve installed inside well, 2X8’’ headers at both suction and discharge ports, test line with flow switch with all related accessories, and all needed pipes and fittings inside pumps room, supplying and installing 6’’ chimney for diesel pump, The pumps specifications are: Electrical Pump 16m Head &138 L/min Water Flow Diesel Pump 16m Head & 138L/min Water Flow Rate Jockey Pump 16m Head &138 L/min Water Flow Rate	NO.	2	22000	44000
12.24	Expansion Tank (closed type). The unit price shall include gate valve, double check valve, safety valve, drain valve. Expansion Tank volume: 100 Gallons .	NO.	1	200	200
12.25	Supply and install Portable Fire Extinguisher each in Location as decided by the Engineer.	NO.	16	80	1280
	<b>Total for this page</b>				49080
	<b>TOTAL CARRIED TO NEXT PAGE</b>				190768

<b>PLUMBING, SANITARY AND MECHANICAL WORKS</b>					
<b>No.</b>	<b>Work Description</b>	<b>Unit</b>	<b>Qty.</b>	<b>Unit Price US \$</b>	<b>Total Price US \$</b>
	<b>FORWARDED TOTAL</b>				190768
	Supply and install a Sch-40 fire water pipes (Seamless piping as per standard ASTM-A53 schedule 40). grooved or screwed connections, including all the requested fittings and supports UL/FM approved				
	1- 3" Sch-40 fire pipes.	MR	100	65	6500
	2- 1 1/2" Sch-40 fire pipes.	MR	240	45	10800
12.26	a. Supply and install in-line Axial fans of approved manufacture (Vortices or equally approved). Price includes the making necessary holes in glass and fixing, electrical connections. All is according to nearest power point and disconnect switch, drawings, specifications and approval of supervisor engineer.				
	* wall mounted Exhaust fan, capacity 50 cfm	NO.	22	50	1100
	* wall mounted Exhaust fan, capacity 100 cfm	NO.	4	100	400
12.27	b. Supply and install wall-mounted kitchen hood of size 200cm*50cm*100cm. The hood should be made from 316 stainless steel sheets of gauge 14 and equipped with built-in 500 CFM exhaust fan and gravity shutter.	NO.	1	1000	1000
12.28	Supply and installation of solar cells according to the manufacturer's instructions and accounts. The price includes all the required equipment, installation and extension of electric wires and rules for solar cells.	NO.	76	300	22800
12.29	Supply and installation of inverter dc to ac according to the manufacturer's instructions and accounts. The price includes all the required equipment, installation and extension of electric wires and devices to protect network .	NO.	1	3000	3000
	<b>Total for this page</b>				45600
	<b>TOTAL CARRIED TO NEXT PAGE</b>				236368

PLUMBING, SANITARY AND MECHANICAL WORKS					
No.	Work Description	Unit	Qty.	Unit Price US \$	Total Price US \$
	<b>FORWARDED TOTAL</b>				236368
12.30	<b>VRF SYSTEM</b> Supply, install & commissioning for Heat pump VRF (variable refrigerant Flow) system ,of type Daikin or equivalent Korean brands . Refrigerant R410a.Complete with the outdoor and indoor units, piping & wiring network, control system and all necessary parts needed according to drawings and specifications.				
12.31	<b>Outdoor Units</b> Variable refrigerant flow outdoor unit, scroll compressor with invertors drive, refrigerant R 410 A, Outdoor design conditions 24C summer indoor temperature,36C summer outdoor temperature.				
	a- Outdoor unit size30 HP- for riser 3	No.	1	12000	12000
	b- Outdoor unit size 50 HP- for riser 1	No.	1	32000	32000
	c- Outdoor unit size 54 HP- for riser 2	No.	1	35000	35000
12.32	<b>Indoor Units</b> The around flow cassette type VRF indoor units with filter, Wall mounted thermostat including on-off, real time clock, schedule timer, fan control, Darin UPVC piping network2'' to nearest floor trap, and temperature set and display. Indoor design conditions 24 C cooling, 50%relative humidity at high speed flow. According to the following capacities:				
	a-Cooling Capacity up to 2.2 kW 60cm x60cm	No.	2	1200	2400
	b-Cooling Capacity up to 3.6 kW,60cm x60cm	No.	1	1300	1300
	e-Cooling Capacity up to 4.5 kW 60cm x60cm	No.	1	1450	1450
	c-Cooling Capacity up to 5.6 kW,60cm x60cm	No.	21	1500	31500
	d-Cooling Capacity up to7.1 kW,60cm x60cm	No.	33	1600	19800
	<b>Total for this page</b>				135450
	<b>TOTAL CARRIED TO NEXT PAGE</b>				371818

<b>PLUMBING, SANITARY AND MECHANICAL WORKS</b>					
<b>No.</b>	<b>Work Description</b>	<b>Unit</b>	<b>Qut.</b>	<b>Unit Price US \$</b>	<b>Total Price US \$</b>
	<b>FORWARDED TOTAL</b>				371818
12.33	<b>Centralized controller</b> Centralized controller for VRF system to control all indoor units set points, programmed on off operation, and alarms view, to be connected to 170 indoor units.	NO.	1	1500	1500
12.34	<b>copper piping network</b> Supply, install & commissioning for copper valves on both liquid and gas lines	NO.	120	70	8400
12.35	All joints Indoore and outdoor unit :				
	a. Refnet	NO.	6	150	900
	b. Header	NO.	8	200	1600
12.36	Supply and installation of solar cells according to the manufacturer's instructions and accounts. The price includes all the required equipment, installation and extension of electric wires and rules for solar cells.	NO.	76	300	22800
12.37	Supply and installation of inverter dc to ac according to the manufacturer's instructions and accounts. The price includes all the required equipment, installation and extension of electric wires and devices to protect network .	NO.	1	3000	3000
	<b>Total for this page</b>				38200
	<b>FORWARDED TOTAL</b>				410018

# Appendix




TABLE 9-1 Cooling load temperature differences (CLTD) for sunlit roofs, °C.

Roof Description of No. Construction	$U_m$ W/m <sup>2</sup> ·°C	Solar Time, <i>h</i>																								
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
<b>Without Suspended Ceiling</b>																										
1 Steel sheet with 25.4 mm (or 50.8 mm) insulation	1.209 (0.704)	0	-1	-2	-2	-3	-2	3	11	19	27	34	40	43	44	43	39	33	25	17	10	7	5	3	1	
2 25 mm wood with 25.4 mm insulation	0.963	3	2	0	-1	-2	-2	-1	2	8	15	22	29	35	39	41	41	39	35	29	21	15	11	8	5	
3 101.6 mm L.W. concrete	1.209	5	3	1	0	-1	-2	-2	1	5	11	18	25	31	36	39	40	40	37	32	25	19	14	10	7	
4 50.8 mm H.W. concrete 25.4 mm (or 50.8 mm) insulation	1.170 (0.693)	7	5	3	2	0	-1	0	2	χ	6	11	17	23	28	33	36	37	37	34	30	25	20	16	12	10
5 25.4 mm wood with 50.8 mm insulation	0.619	2	0	-2	-3	-4	-4	-4	-2	3	9	15	22	27	32	35	36	35	32	27	20	14	10	6	3	
6 152.4 mm L.W. concrete	0.897	12	10	7	5	3	2	1	0	2	4	8	13	18	24	29	33	35	36	35	32	28	24	19	16	
7 63.5 mm wood with 25.4 mm insulation	0.738	16	13	11	9	7	6	4	3	4	5	8	11	15	19	23	27	29	31	31	30	27	25	22	19	
8 203.4 mm L.W. concrete	0.715	20	17	14	12	10	8	6	5	4	4	5	7	11	14	18	22	25	28	30	30	29	27	25	22	
9 101.6 mm H.W. concrete with 25.4 mm (or 50.8 mm) insulation	1.136 (0.681)	14	12	10	8	7	5	4	4	6	8	11	15	18	22	25	28	29	30	29	27	24	21	19	16	
10 63.5 mm wood with insulation	0.528	18	15	13	11	9	8	6	5	5	5	7	10	13	17	21	24	27	28	29	29	27	25	23	20	
11 Roof terrace system	0.602	19	17	15	14	12	11	9	8	7	8	8	10	12	15	18	20	22	24	25	26	25	24	22	21	
12 152.4 mm H.W. concrete with 25.4 mm (or 50.8 mm) insulation	0.664	18	16	14	12	11	10	9	8	8	9	10	12	15	17	20	22	24	25	25	25	24	22	20	19	
13 101.6 mm wood with 25.4 mm (or 50.8 mm) insulation	0.602 (0.443)	21	20	18	17	15	14	13	11	10	9	9	9	10	12	14	16	18	20	22	23	24	24	23	22	

TABLE 9-2 Latitude-Month correction factor LM, as applied to walls and horizontal roofs, north latitudes.

Lat.	Month	NNE NE ENE E ESE SE SSE									Horizontal Roofs
		N	NNW	NW	WNW	W	WSW	SW	SSW	S	
16	December	-2.2	-3.3	-4.4	-4.4	-2.2	-0.5	2.2	5.0	7.2	-5.0
	Jan./Nov.	-2.2	-3.3	-3.8	-3.8	-2.2	-0.5	2.2	4.4	6.6	-3.8
	Feb./Oct.	-1.6	-2.7	-2.7	-2.2	-1.1	0.0	1.1	2.7	3.8	-2.2
	Mar/Sept.	-1.6	-1.6	-1.1	-1.1	-0.5	-0.5	0.0	0.0	0.0	-0.5
	Apr./Aug.	-0.5	0.0	-0.5	-0.5	-0.5	-1.6	-1.6	-2.7	-3.3	0.0
	May/July	2.2	1.6	1.6	0.0	-0.5	-2.2	-2.7	-3.8	-3.8	0.0
	June	3.3	2.2	2.2	0.5	-0.5	-2.2	-3.3	-4.4	-3.8	0.0
24	December	-2.7	-3.8	-5.5	-6.1	-4.4	-2.7	1.1	5.0	6.6	-9.4
	Jan./Nov.	-2.2	-3.3	-4.4	-5.0	-3.3	-1.6	-1.6	5.0	7.2	-6.1
	Feb./Oct.	-2.2	-2.7	-3.3	-3.3	-1.6	-0.5	1.6	3.8	5.5	-3.8
	Mar/Sept.	-1.6	-2.2	-1.6	-1.6	-0.5	-0.5	0.5	1.1	2.2	-1.6
	Apr./Aug.	-1.1	-0.5	0.0	-0.5	-0.5	-1.1	-0.5	-1.1	-1.6	0.0
	May/July	0.5	1.1	1.1	0.0	0.0	-1.6	-1.6	-2.7	-3.3	0.5
	June	1.6	1.6	1.6	0.5	0.0	-1.6	-2.2	-3.3	-3.3	0.5
32	December	-2.7	-3.8	-5.5	-6.1	-4.4	-2.7	1.1	5.0	6.6	-9.4
	Jan./Nov.	-2.7	-3.8	-5.0	-6.1	-4.4	-2.2	1.1	5.0	6.6	-8.3
	Feb./Oct.	-2.2	-3.3	-3.8	-4.4	-2.2	-1.1	2.2	4.4	6.1	-5.5
	Mar/Sept.	-1.6	-2.2	-2.2	-2.2	-1.1	-0.5	1.6	2.7	3.8	-2.7
	Apr./Aug.	-1.1	-1.1	-0.5	-1.1	0.0	-0.5	0.0	5.0	0.5	-0.5
	May/July	0.5	0.5	0.5	0.0	0.0	-0.5	-0.5	-1.6	-1.6	0.5
	June	0.5	1.1	1.1	0.5	0.0	-1.1	-1.1	-2.2	-2.2	1.1
40	December	-3.3	-4.4	-5.5	-7.2	-5.5	-3.8	0.0	3.8	5.5	-11.6
	Jan./Nov.	-2.7	-3.8	-5.5	-6.6	-5.0	-3.3	0.5	4.4	6.1	-10.5
	Feb./Oct.	-2.7	-3.8	-4.4	-5.0	-3.3	-1.6	1.6	4.4	6.6	-7.7
	Mar/Sept.	-2.2	-2.7	-2.7	-3.3	-1.6	0.5	2.2	3.8	5.5	-4.4
	Apr./Aug.	-1.1	-1.6	-1.6	-1.1	0.0	0.0	1.1	1.6	2.2	1.6
	May/July	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5
	June	0.5	0.5	0.5	0.5	0.0	0.5	0.0	0.0	-0.5	1.1
48	December	-3.3	-4.4	-6.1	-7.7	-7.2	-5.5	-1.6	1.1	3.3	-13.8
	Jan./Nov.	-3.3	-4.4	-6.1	-7.2	-6.1	-4.4	-0.5	2.7	4.4	-13.3
	Feb./Oct.	-2.7	-3.8	-5.5	-6.1	-4.4	-2.7	0.5	4.4	6.1	-10.0
	Mar/Sept.	-2.2	-3.3	-3.3	-3.8	-2.2	-0.5	2.2	4.4	6.1	-6.1
	Apr./Aug.	-1.6	-1.6	-1.6	-1.6	-0.5	0.0	2.2	3.3	3.8	-2.7
	May/July	0.0	-0.5	0.0	0.0	0.5	0.5	1.6	1.6	2.2	0.0
	June	0.5	0.5	1.1	0.5	1.1	0.5	1.1	1.1	1.6	1.1

TABLE 9-4 Cooling load temperature differences (CLTD) for various construction groups of sunlit walls, °C.

North Latitude Wall Facing	Solar Time <i>h</i>																								Hour of Max. Difference			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	CLTD	CLTD	CLTD	CLTD
<b>Group A Walls</b>																												
N	8	8	8	7	7	7	7	6	6	6	6	6	6	6	6	6	6	6	7	7	7	7	8	8	2	6	8	2
NE	11	11	10	10	10	9	9	9	8	8	8	8	9	9	9	9	10	10	10	11	11	11	11	11	22	8	11	3
E	14	13	13	13	12	12	11	11	10	10	10	11	11	12	12	13	13	13	14	14	14	14	14	22	10	14	4	
SE	13	13	13	12	12	11	11	10	10	10	10	10	11	11	12	12	13	13	13	13	13	13	22	10	13	3		
S	11	11	11	11	10	10	9	9	9	8	8	8	8	8	8	8	9	9	10	10	11	11	11	23	8	11	3	
SW	14	14	14	14	13	13	12	12	11	11	10	10	10	9	9	10	10	10	11	12	13	13	14	24	9	14	5	
W	15	15	15	14	14	14	13	13	12	12	11	11	10	10	10	10	10	11	11	12	13	14	14	1	10	15	5	
NW	12	12	11	11	11	11	10	10	10	9	9	8	8	8	8	8	8	8	9	9	10	11	11	1	8	12	4	
<b>Group B Walls</b>																												
N	8	8	8	7	7	6	6	6	5	5	5	5	5	5	5	6	6	7	7	8	8	8	8	24	5	8	3	
NE	11	10	10	9	9	8	7	7	7	7	8	8	9	9	10	10	11	11	11	12	12	12	11	21	7	12	5	
E	13	13	12	11	10	10	9	8	8	8	9	9	10	12	13	13	14	14	15	15	15	15	14	20	8	15	7	
SE	13	12	12	11	10	10	9	8	8	8	8	8	9	10	11	12	13	14	14	14	14	14	21	8	14	6		
S	12	11	11	10	9	9	8	7	7	6	6	6	6	7	8	9	10	11	11	12	12	12	23	6	12	6		
SW	15	15	14	13	13	12	11	10	9	9	8	8	7	7	8	9	10	11	13	14	15	15	24	7	16	9		
W	16	16	15	14	14	13	12	11	10	9	9	8	8	8	8	8	9	11	12	14	15	16	24	8	17	9		
NW	13	12	12	11	11	10	9	9	8	7	7	6	6	7	7	8	8	9	11	12	13	13	24	6	13	7		
<b>Group C Walls</b>																												
N	9	8	7	7	6	5	5	4	4	4	4	4	5	5	6	6	7	8	9	9	9	10	9	22	4	10	6	
NE	10	10	9	8	7	6	6	6	6	7	8	10	10	11	12	12	12	13	13	13	13	12	12	20	6	13	7	
E	13	12	11	10	9	8	7	7	8	9	11	13	14	15	16	16	17	17	16	16	16	15	14	18	7	17	10	
SE	13	12	11	10	9	8	7	6	7	7	9	10	12	14	15	16	16	16	16	16	16	15	14	19	6	16	10	
S	12	11	10	9	8	7	6	6	5	5	5	5	6	8	9	11	12	13	14	14	14	13	20	5	14	9		
SW	16	15	14	12	11	10	9	8	7	7	6	6	6	7	8	10	12	14	16	18	18	18	17	22	6	18	12	
W	17	16	15	14	12	11	10	9	8	7	7	7	7	7	8	9	11	13	16	18	19	20	19	22	7	20	13	

TABLE 9-5 Description of wall construction groups.

Group No.	Description Of Construction	$U_{eq}$ W/m <sup>2</sup> ·°C
<b>101.6 mm Face Brick + (Brick)</b>		
C	Air space + 101.6 mm face brick	2.033
D	101.6 mm common brick	2.356
C	25.4 mm insulation or air space + 101.6 mm common brick	0.987-1.709
B	50.6 mm insulation + 101.6 mm common brick	0.630
B	203.2 mm common brick	1.714
A	Insulation or air space + 203.2 mm common brick	0.874-1.379
<b>101.6 mm Face Brick + (H.W. Concrete)</b>		
C	Air space + 50.8 mm concrete	1.987
B	50.8 mm insulation + 101.6 mm concrete	0.658
A	Air space or insulation + 203.2 mm or more concrete	0.625-0.636
<b>101.6 mm Face Brick + (L.W. or H.W. Concrete Block)</b>		
E	101.6 mm block	1.811
D	Air space or insulation + 101.60 mm block	0.868-1.397
D	203.2 mm block	1.555
C	Air space or 25.4 mm insulation + 152.4 mm or 203.2 mm block	1.255-1.561
B	50.8 mm insulation + 203.2 mm block	0.545-0.607
<b>101.6 mm Face Brick + (Clay Tile)</b>		
D	101.6 mm tile	2.163
D	Air space + 101.6 mm tile	1.595
C	Insulation + 101.6 mm tile	0.959
C	203.2 mm tile	1.561
B	Air space or 25.4 mm insulation + 203.2 mm tile	0.806-1.255
A	50.8 mm insulation + 203.2 mm tile	0.551
<b>L.W. Concrete Wall + (Finish)</b>		
E	101.5 mm concrete	3.321
D	101.6 mm concrete + 25.4 mm or 50.8 mm insulation	1.136 - 0.675
C	50.8 mm insulation + 101.6 mm concrete	0.675
C	203.2 mm concrete	2.782
B	203.2 mm concrete + 25.4 mm or 50.8 mm insulation	1.061 - 0.653
A	203.2 mm concrete + 50.8 mm insulation	0.653
B	304.8 mm concrete	2.390
A	304.8 mm concrete + insulation	0.642
<b>L.W. and H.W. Concrete Block + (Finish)</b>		
F	101.6 mm block + air space/insulation	0.914-1.493
E	50.8 mm insulation + 101.6 mm block	0.596-0.647
E	203.2 mm block	1.669-2.282
D	203.2 mm block + air space/insulation	0.846-0.982

TABLE 9-6 Approximate CLTD values for light, medium, and heavy weight construction walls, °C.

Solar Time	Wall construction											
	Light				Medium				Heavy			
	N	E	S	W	N	E	S	W	N	E	S	W
8:00	—	16	—	—	—	—	—	—	—	—	—	—
9:00	—	20	—	—	—	6	—	—	—	—	—	—
10:00	—	21	2	—	—	11	—	—	—	—	—	—
11:00	—	18	7	—	—	14	—	—	—	3	—	—
12:00	—	12	12	—	—	15	—	—	—	5	—	—
13:00	2	9	15	5	—	14	5	—	—	7	—	—
14:00	3	7	16	13	—	12	9	1	—	8	—	—
15:00	3	7	14	21	1	10	11	6	—	8	1	—
16:00	4	6	11	27	2	9	12	12	—	8	3	—
17:00	4	5	7	30	2	8	11	17	—	8	5	3
18:00	5	3	4	27	3	7	9	22	—	8	6	7
19:00	2	1	1	17	3	5	7	23	—	7	6	10
20:00	—	—	—	6	3	3	5	20	1	7	6	12

TABLE 9-7 Solar heat gain factor (SHG) for sunlit glass, W/m<sup>2</sup>, for a latitude angle of 32 °N.

Month	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.
N	76	85	101	114	120	139	126	117	104	88	76	69
NNE/NNW	76	85	117	252	350	385	350	249	110	88	76	69
NE/NW	91	205	338	461	536	555	527	445	325	199	91	69
ENE/WNW	331	470	577	631	656	656	643	615	546	451	325	265
E/W	552	647	716	716	694	675	678	691	678	615	546	511
ESE/WSW	722	764	748	691	628	596	612	663	716	738	710	688
SE/SW	786	782	716	590	489	439	473	571	688	754	773	776
SSE/SSW	789	732	615	445	213	262	303	429	596	710	776	795
S	776	697	555	363	233	189	227	350	540	678	767	795
Horizontal	555	685	795	855	874	871	861	836	770	672	552	498

**TABLE 9-8** Shading coefficient (SC) for glass windows without interior shading.<sup>1</sup>

Type of Glass	Nominal Thickness, mm	Solar Trans.	Shading Coefficient, W/m <sup>2</sup> ·K	
			<i>h<sub>o</sub></i> = 22.7	<i>h<sub>o</sub></i> = 17.0
<b>Single Glass</b>				
Clear	3	0.84	1.00	1.00
	6	0.78	0.94	0.95
	10	0.72	0.90	0.92
	12	0.67	0.87	0.88
Heat absorbing	3	0.64	0.83	0.85
	6	0.46	0.69	0.73
	10	0.33	0.60	0.64
	12	0.42	0.53	0.58
<b>Double Glass</b>				
Regular	3	—	0.90	—
Plate	6	—	0.83	—
Reflective	6	—	0.20-0.40	—
<b>Insulating Glass</b>				
Clear	3	0.71	0.88	0.88
	6	0.61	0.81	0.82
Heat absorbing*	6	0.36	0.55	0.58

**TABLE 9-10** Cooling load factors (CLF) for glass windows without interior shading, north latitudes.

Glass Facing	Building Construction	Solar Time, h																
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
N	L	0.17	0.14	0.11	0.09	0.08	0.33	0.24	0.48	0.56	0.61	0.71	0.76	0.80	0.82	0.82	0.79	0.75
	M	0.23	0.20	0.18	0.16	0.14	0.34	0.14	0.46	0.53	0.59	0.65	0.70	0.73	0.75	0.76	0.74	0.75
	H	0.25	0.23	0.21	0.20	0.19	0.38	0.45	0.49	0.55	0.60	0.65	0.69	0.72	0.72	0.72	0.70	0.70
NNE	L	0.06	0.05	0.04	0.03	0.03	0.26	0.43	0.47	0.44	0.41	0.40	0.39	0.39	0.38	0.36	0.33	0.30
	M	0.09	0.08	0.07	0.06	0.06	0.24	0.38	0.42	0.39	0.37	0.37	0.36	0.36	0.36	0.34	0.33	0.30
	H	0.11	0.10	0.09	0.09	0.08	0.26	0.39	0.42	0.39	0.36	0.35	0.34	0.34	0.33	0.32	0.31	0.28
NE	L	0.04	0.04	0.03	0.02	0.02	0.23	0.41	0.51	0.51	0.45	0.39	0.36	0.33	0.31	0.28	0.26	0.23
	M	0.07	0.06	0.06	0.05	0.04	0.21	0.36	0.44	0.45	0.40	0.36	0.33	0.31	0.30	0.28	0.26	0.24
	H	0.09	0.08	0.08	0.07	0.07	0.23	0.37	0.44	0.44	0.39	0.34	0.31	0.29	0.27	0.26	0.24	0.22
ENE	L	0.04	0.03	0.03	0.02	0.02	0.21	0.40	0.52	0.57	0.53	0.45	0.39	0.34	0.31	0.28	0.25	0.22
	M	0.07	0.06	0.05	0.05	0.04	0.20	0.35	0.45	0.49	0.47	0.41	0.36	0.33	0.30	0.28	0.26	0.23
	H	0.09	0.09	0.08	0.07	0.07	0.22	0.36	0.46	0.49	0.45	0.38	0.31	0.30	0.27	0.25	0.23	0.21
E	L	0.04	0.03	0.03	0.02	0.02	0.19	0.37	0.51	0.57	0.57	0.50	0.42	0.37	0.32	0.29	0.25	0.22
	M	0.07	0.06	0.06	0.05	0.05	0.18	0.33	0.44	0.50	0.51	0.46	0.39	0.35	0.31	0.29	0.26	0.23
	H	0.09	0.09	0.08	0.08	0.07	0.20	0.34	0.45	0.49	0.49	0.43	0.39	0.32	0.29	0.26	0.24	0.22
ESE	L	0.05	0.04	0.03	0.03	0.02	0.17	0.34	0.49	0.58	0.61	0.57	0.48	0.41	0.36	0.32	0.28	0.24
	M	0.08	0.07	0.06	0.05	0.05	0.16	0.31	0.43	0.51	0.54	0.51	0.44	0.39	0.35	0.32	0.29	0.26
	H	0.10	0.09	0.09	0.08	0.08	0.19	0.32	0.43	0.50	0.52	0.49	0.41	0.36	0.32	0.29	0.26	0.24

SE	L	0.05	0.04	0.04	0.03	0.03	0.13	0.28	0.43	0.55	0.62	0.63	0.57	0.48	0.42	0.37	0.33	0.28
	M	0.09	0.08	0.07	0.06	0.05	0.14	0.26	0.38	0.48	0.54	0.56	0.51	0.45	0.40	0.36	0.33	0.29
	H	0.11	0.10	0.10	0.09	0.08	0.17	0.28	0.40	0.49	0.53	0.53	0.48	0.41	0.36	0.33	0.30	0.27
SSE	L	0.07	0.05	0.04	0.04	0.03	0.06	0.15	0.29	0.43	0.55	0.63	0.64	0.60	0.25	0.45	0.40	0.35
	M	0.11	0.09	0.08	0.07	0.06	0.08	0.16	0.26	0.38	0.58	0.55	0.57	0.54	0.48	0.43	0.39	0.35
	H	0.12	0.11	0.11	0.10	0.09	0.12	0.19	0.29	0.40	0.49	0.54	0.55	0.51	0.44	0.39	0.35	0.31
S	L	0.08	0.07	0.05	0.04	0.04	0.06	0.09	0.14	0.22	0.34	0.48	0.59	0.65	0.65	0.59	0.50	0.43
	M	0.12	0.11	0.09	0.08	0.07	0.08	0.11	0.14	0.21	0.31	0.42	0.52	0.57	0.58	0.53	0.47	0.41
	H	0.13	0.12	0.12	0.11	0.10	0.11	0.14	0.17	0.24	0.33	0.43	0.51	0.56	0.55	0.50	0.43	0.37
SSW	L	0.10	0.08	0.07	0.06	0.05	0.06	0.09	0.11	0.15	0.19	0.27	0.39	0.52	0.62	0.67	0.65	0.58
	M	0.14	0.12	0.11	0.09	0.08	0.09	0.11	0.13	0.15	0.18	0.25	0.35	0.46	0.55	0.59	0.59	0.53
	H	0.15	0.14	0.13	0.12	0.11	0.12	0.14	0.16	0.18	0.21	0.27	0.37	0.46	0.53	0.57	0.55	0.49
SW	L	0.12	0.10	0.08	0.06	0.05	0.06	0.08	0.10	0.12	0.14	0.16	0.24	0.36	0.49	0.60	0.66	0.66
	M	0.15	0.14	0.12	0.10	0.09	0.09	0.10	0.12	0.13	0.15	0.17	0.23	0.33	0.44	0.53	0.58	0.59
	H	0.15	0.14	0.13	0.12	0.11	0.12	0.13	0.14	0.16	0.17	0.19	0.25	0.34	0.44	0.52	0.56	0.56
WSW	L	0.12	0.10	0.08	0.07	0.05	0.06	0.07	0.09	0.10	0.12	0.13	0.17	0.26	0.40	0.52	0.62	0.66
	M	0.15	0.13	0.12	0.10	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.17	0.24	0.35	0.46	0.54	0.58
	H	0.15	0.14	0.13	0.12	0.11	0.11	0.12	0.13	0.14	0.15	0.16	0.19	0.26	0.36	0.46	0.53	0.56
	L	0.12	0.10	0.08	0.06	0.05	0.06	0.07	0.08	0.10	0.11	0.12	0.14	0.20	0.32	0.45	0.57	0.64

TABLE 9-11 Cooling Load factors (CLF) for glass windows with interior shading, North latitude.

Fenestration Facing	Solar Time, <i>h</i>																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
N	0.08	0.07	0.06	0.06	0.07	0.73	0.66	0.65	0.73	0.80	0.86	0.89	0.89	0.86	0.82	0.75	0.78
NNE	0.03	0.03	0.02	0.02	0.03	0.64	0.77	0.62	0.42	0.37	0.37	0.37	0.36	0.35	0.32	0.28	0.23
NE	0.03	0.02	0.02	0.02	0.02	0.56	0.76	0.74	0.58	0.37	0.29	0.27	0.26	0.24	0.22	0.20	0.16
ENE	0.03	0.02	0.02	0.02	0.02	0.52	0.76	0.80	0.71	0.52	0.31	0.26	0.24	0.22	0.20	0.18	0.15
E	0.03	0.02	0.02	0.02	0.02	0.47	0.72	0.80	0.76	0.62	0.41	0.27	0.24	0.22	0.20	0.17	0.14
ESE	0.03	0.03	0.02	0.02	0.02	0.41	0.67	0.79	0.80	0.72	0.54	0.34	0.27	0.24	0.21	0.19	0.15
SE	0.03	0.03	0.02	0.02	0.02	0.30	0.57	0.74	0.81	0.79	0.68	0.49	0.33	0.28	0.25	0.22	0.18
SSE	0.04	0.03	0.03	0.03	0.02	0.12	0.31	0.54	0.72	0.81	0.81	0.71	0.54	0.38	0.32	0.27	0.22
S	0.04	0.04	0.03	0.03	0.03	0.09	0.16	0.23	0.38	0.58	0.75	0.83	0.80	0.68	0.50	0.35	0.27
SSW	0.05	0.04	0.04	0.03	0.03	0.09	0.14	0.18	0.22	0.27	0.43	0.63	0.78	0.84	0.80	0.66	0.46
SW	0.05	0.05	0.04	0.04	0.03	0.07	0.11	0.14	0.16	0.19	0.22	0.38	0.59	0.75	0.83	0.81	0.69
WSW	0.05	0.05	0.04	0.04	0.03	0.07	0.10	0.12	0.14	0.16	0.17	0.23	0.44	0.64	0.78	0.84	0.78
W	0.05	0.05	0.04	0.04	0.03	0.06	0.09	0.11	0.13	0.15	0.16	0.17	0.31	0.53	0.72	0.82	0.81
WNW	0.05	0.05	0.04	0.03	0.03	0.07	0.10	0.12	0.14	0.16	0.17	0.18	0.22	0.43	0.65	0.80	0.84
NW	0.05	0.04	0.04	0.03	0.03	0.07	0.11	0.14	0.17	0.19	0.20	0.21	0.22	0.30	0.52	0.73	0.82
NNW	0.05	0.05	0.04	0.03	0.03	0.11	0.17	0.22	0.26	0.30	0.32	0.33	0.34	0.34	0.39	0.61	0.82
HORIZ.	0.06	0.05	0.04	0.04	0.03	0.12	0.27	0.44	0.59	0.72	0.81	0.85	0.85	0.81	0.71	0.58	0.42

TABLE 9-14 Cooling load factor (CLF)<sub>U</sub> for lights.<sup>3</sup>

Number of hours after lights are turned On	Fixture X <sup>c</sup> hours of operation		Fixture Y <sup>c</sup> hours of operation	
	10	16	10	16
	0	0.08	0.19	0.01
1	0.62	0.72	0.76	0.79
2	0.66	0.75	0.81	0.83
3	0.69	0.77	0.84	0.87
4	0.73	0.80	0.88	0.89
5	0.75	0.82	0.90	0.91
6	0.78	0.84	0.92	0.93
7	0.80	0.85	0.93	0.94
8	0.82	0.87	0.95	0.95
9	0.84	0.88	0.96	0.96
10	0.85	0.89	0.97	0.97
11	0.32	0.90	0.22	0.98
12	0.29	0.91	0.18	0.98
13	0.26	0.92	0.14	0.98
14	0.23	0.93	0.12	0.99
15	0.21	0.94	0.09	0.99
16	0.19	0.94	0.08	0.99
17	0.17	0.40	0.06	0.24
18	0.15	0.36	0.05	0.20

TABLE 9-15 Diversity factor for selected applications.<sup>4</sup>

Application	Diversity Factor	
	Lights	People
Peripheral areas of offices with glazing area of 20%-50%	0.70-0.85	0.7-0.8
Core areas of offices and peripheral areas with less than 20% glazing	0.90-1.00	0.7-0.8
Apartments and hotel bedrooms	0.30-0.50	0.4-0.6
Public rooms in hotels	0.90-1.00	0.4-0.6
Department stores and supermarkets	0.90-1.00	0.8-1.0

### 9.9 MISCELLANEOUS HEAT GAINS

These heat gains or heat losses are considered part of the total cooling load and include the following:

- (1) Supply and return duct system heat losses:  
All supply and return duct systems, if they are located outside the conditioned space, must be well insulated to minimize this heat loss and to prevent moisture condensation on the duct surface.

<sup>3</sup> Adapted from Stoecker and Jones, 1982, "Refrigeration and Air Conditioning", 2<sup>nd</sup> ed., MacGraw Hill. (Fixture X = not vented recessed lights and Fixture Y = vented or free-hanging light.)

<sup>4</sup> Adapted from Jones, 1979 "Air Conditioning applications and Design", Edward Arnold.

TABLE 9-16 Cooling load factor due to occupants (CLF)<sub>occ</sub>, for sensible heat gain.<sup>5</sup>

Hours after each entry into space	Total hours in space							
	2	4	6	8	10	12	14	16
1	0.49	0.49	0.50	0.51	0.53	0.55	0.58	0.61
2	0.58	0.59	0.60	0.61	0.62	0.64	0.66	0.71
3	0.17	0.66	0.67	0.67	0.69	0.70	0.72	0.71
4	0.13	0.71	0.72	0.72	0.74	0.75	0.77	0.71
5	0.10	0.27	0.76	0.76	0.77	0.79	0.80	0.81
6	0.08	0.21	0.79	0.80	0.80	0.81	0.83	0.81
7	0.07	0.16	0.34	0.82	0.83	0.84	0.85	0.81
8	0.06	0.14	0.26	0.84	0.85	0.86	0.87	0.81
9	0.05	0.11	0.21	0.38	0.87	0.88	0.89	0.91
10	0.04	0.10	0.18	0.30	0.89	0.89	0.9	0.9
11	0.04	0.08	0.15	0.25	0.42	0.91	0.91	0.9
12	0.03	0.07	0.13	0.21	0.34	0.92	0.92	0.9
13	0.03	0.06	0.11	0.18	0.28	0.45	0.93	0.9
14	0.02	0.06	0.10	0.15	0.23	0.36	0.94	0.9
15	0.02	0.05	0.08	0.13	0.20	0.30	0.47	0.9
16	0.02	0.04	0.07	0.12	0.17	0.25	0.38	0.9
17	0.02	0.04	0.06	0.10	0.15	0.21	0.31	0.4
18	0.01	0.03	0.06	0.09	0.13	0.19	0.26	0.3

The recommended duct insulation thickness  $\Delta x_{ins}$ , for this purpose must satisfy the following condition:

$$R_{ins} = (T_{s,avg} - T_{sur,avg})/47.3 = (\Delta x_{ins}/k_{ins}) \quad (9-8)$$

where  $R_{ins}$  is the thermal resistance of the insulation,  $T_{s,avg}$  is the average supply air temperature and  $T_{sur,avg}$  is the surrounding air temperature. Thus, if the temperature difference  $(T_{s,avg} - T_{sur,avg})$  and the thermal conductivity  $k_{ins}$ , of the insulating material are given or known then the required insulation material thickness can be calculated using Eq. (9-8).

The heat loss from the duct system  $Q_{Loss}$ , is calculated by using the following equation:

$$Q_{Loss} = U_{ov} A_s (T_{s,avg} - T_{sur,avg}) \quad (9-9)$$

where,  $U_{ov}$  is the duct overall heat transfer coefficient and  $A_s$  is the duct outside surface area.

- (2) Supply duct air leakage into non-conditioned space:  
It occurs due to poor construction and workmanship of duct connections.
- (3) Heat generated by fans and blowers:  
Such heat gains are added to the air stream if the fan is located on the supply side of the cooling coil.

## 9.10 COOLING LOAD FORM

The calculation of various components of the cooling load of a building must be done on a room-by-room basis, as the case for heating load calculation. The cooling load is calculated as follows:

<sup>5</sup> Stoecker and Jones, 1982, "Refrigeration and Air Conditioning" 2<sup>nd</sup> ed. McGraw Hill.

**TABLE 4-2** Instantaneous heat gain from occupants in units of Watts<sup>(a)</sup>.

Type of Activity	Typical Application	Total Heat Dissipation Adult Male	Total Adjusted <sup>(a)</sup> Heat Dissipation	Sensible Heat, W	Latent Heat, W
Seated at rest	<i>Theater :</i>				
	Matinee	111.5	94.0	64.0	30.0
	Evening	111.5	100.0	70.0	30.0
Seated, very light work	Offices, hotels, apartments, restaurants	128.5	114.0	70.0	44.0
Moderately active office work	Offices, hotels, apartments	135.5	128.5	71.5	57.0
Standing, light work, walking	Department store, retail store, supermarkets	157.0	143.0	71.5	71.5
	Drug store	157.0	143.0	71.5	71.5
Standing, walking slowly	Bank	157.0	143.0	71.5	71.5
Sedentary work	Restaurant	168.5	157.0	78.5	78.5
Light bench work	Factory	238.0	214.0	78.0	136.0
	Small-Parts assembly	257.0	243.0	87.0	156.0
Moderate work					
Moderate dancing	Dance halls	257.0	243.0	87.0	156.0
Walking at 1.5 m/s	Factory	286.0	285.0	107.0	178.0
Bowling (participant)	Bowling alley	428.5	414.0	166.0	248.0
Heavy work	Factory	428.5	414.0	166.0	248.0

Table 9.3 Water Supply Fixture Units and Fixture Branch Sizes

Fixture <sup>a</sup>	Use	Type of Supply Control	Fixture Units <sup>b</sup>	Min. Size of Fixture Branch <sup>c</sup> in.
Bathroom group <sup>a</sup>	Private	Flushometer	8	—
Bathroom group <sup>a</sup>	Private	Flush tank for closet	6	—
Bath tub	Private	Faucet	2	1/2
Bath tub	General	Faucet	4	1/2
Clothes washer	Private	Faucet	2	1/2
Clothes washer	General	Faucet	4	1/2
Combination fixture	Private	Faucet	3	1/2
Dishwasher <sup>c</sup>	Private	Automatic	1	1/2
Drinking fountain	Offices, etc.	Faucet 1/4 in.	0.25	1/2
Kitchen sink	Private	Faucet	2	1/2
Kitchen sink	General	Faucet	4	1/2
Laundry trays (1-3)	Private	Faucet	3	1/2
Lavatory	Private	Faucet	1	3/8
Lavatory	General	Faucet	2	1/2
Separate shower	Private	Mixing valve	2	1/2
Service sink	General	Faucet	3	1/2
Shower head	Private	Mixing valve	2	1/2
Shower head	General	Mixing valve	4	1/2
Urinal	General	Flushometer	5	3/4
Urinal	General	Flush tank	3	1/2
Water closet	Private	Flushometer	6	1
Water closet	Private	Flushometer/tank	3	1/2
Water closet	Private	Flush tank	3	1/2
Water closet	General	Flushometer	10	1
Water closet	General	Flushometer/tank	5	1/2
Water closet	General	Flush tank	5	1/2

Water supply outlets not listed above shall be computed at their maximum demand, but in no case less than the following values:

Table 9.4 Table for Estimating Demand

<i>Supply Systems Predominantly for Flush Tanks</i>		<i>Supply Systems Predominantly for Flushometers</i>	
<i>Load, WSFU*</i>	<i>Demand, gpm</i>	<i>Load, WSFU*</i>	<i>Demand, gpm</i>
6	5	—	—
10	8	10	27
15	11	15	31
20	14	20	35
25	17	25	38
30	20	30	41
40	25	40	47
50	29	50	51
60	33	60	55
80	39	80	62
100	44	100	68
120	49	120	74
140	53	140	78
160	57	160	83
180	61	180	87
200	65	200	91
225	70	225	95
250	75	250	100
300	85	300	110
400	105	400	125
500	125	500	140
750	170	750	175
1000	210	1000	218
1250	240	1250	240
1500	270	1500	270
1750	300	1750	300
2000	325	2000	325
2500	380	2500	380
3000	435	3000	435
4000	525	4000	525
5000	600	5000	600
6000	650	6000	650
7000	700	7000	700
8000	730	8000	730
9000	760	9000	760
10,000	790	10,000	790

Table 9.5 Demand at Individual Water Outlets

Type of Outlet	Demand, gpm
Ordinary lavatory faucet	2.0
Self-closing lavatory faucet	2.5
Sink faucet, 3/8 or 1/2 in.	4.5
Sink faucet, 3/4 in.	6.0
Bath faucet, 1/2 in.	5.0
Shower head, 1/2 in.	5.0
Laundry faucet, 1/2 in.	5.0
Ballcock in water closet flush tank	3.0
1-in. flush valve (25-psi flow pressure)	35.0
1-in. flush valve (15-psi flow pressure)	27.0
3/4-in. flush valve (15-psi flow pressure)	15.0
Drinking fountain jet	0.75
Dishwashing machine (domestic)	4.0
Laundry machine (8 or 16 lb)	4.0
Aspirator (operating room or laboratory)	2.5
Hose bibb or sill cock (1/2 in.)	5.0

Source. Data reproduced with permission from National Standard Plumbing Code, published by the National Association of Plumbing, Heating, Cooling Contractors.

Table 9.10 Estimated Hot Water Demand

Building Type	Hot Water* per Person, gal/day	Maximum Hourly Demand, Portion of Daily Use, gal	Duration of Peak Load, hr	Storage Capacity, Portion of Daily Use, gal	Heating Capacity Portion of Daily Use, gph
Residences, apartments, hotels*	20-40	1/2	4	1/2	1/2
Office buildings	2-3	1/2	2	1/2	1/6
Factory buildings	5	1/2	1	1/2	1/6

\*at 140°F.

\*Allow additional 15 gal per dishwasher and 40 gal per domestic clothes washer.

Source. From Ramsey and Sleeper, *Architectural Graphic Standards*, 8th ed., 1989, reprinted by permission of John Wiley & Sons.

Table 10.1 Approximate Discharge Rates and Velocities\* in Sloping Drains Flowing Half Full\*

Actual Inside Diameter of Pipe, in.	1/8 in./ft Slope 1.9%		1/4 in./ft Slope		1/2 in./ft 2% Slope		1 in./ft Slope	
	Discharge, gpm	Velocity, fps	Discharge, gpm	Velocity, fps	Discharge, gpm	Velocity, fps	Discharge, gpm	Velocity, fps
1/4					3.13	1.34	4.44	1.75
1/2					3.91	1.42	5.53	2.01
3/4					4.81	1.50	6.80	2.12
1					5.42	1.72	11.9	2.43
2			10.8	1.41	15.3	1.99	21.6	2.82
2 1/2			17.6	1.59	24.8	2.25	35.1	3.19
3			17.6	1.59	24.8	2.25	35.1	3.19
4	26.70	1.36	37.8	1.93	53.6	2.73	75.5	3.86
5	48.3	1.58	68.3	2.23	96.6	3.16	137.	4.47
6	78.5	1.78	111.	2.52	157.	3.57	222.	5.04
8	170.	2.17	240.	3.07	340.	4.34	480.	6.13
10	308.	2.52	436.	3.56	616.	5.04	872.	7.12
12	500.	2.83	707.	4.01	999.	5.67	1413	8.02

Table 10.2 Drainage Fixture Unit Values for Various Plumbing Fixtures

Type of Fixture or Group of Fixtures	Drainage Fixture Unit Value, dfu
Automatic clothes washer (2-in. standpipe and trap required, direct connection)	3
Bathtub group consisting of a water closet, lavatory and bathtub or shower stall	6
Bathtub (with or without overhead shower)*	2
Bidet	1
Clinic sink	6
Clothes washer	2
Combination sink-and-tray with food waste grinder	4
Combination sink-and-tray with one 1-in. trap	2
Combination sink-and-tray with separate 1-in. trap	3
Dental unit of cuspidor	1
Dental lavatory	1
Drinking fountain	1/2
Dishwasher, domestic	2
Floor drains with 2-in. waste	3
Kitchen sink, domestic, with one 1-in. trap	2
Kitchen sink, domestic, with food waste grinder	2
Kitchen sink, domestic, with food waste grinder and dishwasher 1-in. trap	3
Kitchen sink, domestic, with dishwasher 1-in. trap	3
Lavatory with 1-in. waste	1
Laundry tray (1 or 2 compartments)	2
Shower stall, domestic	2
Showers (group) per head	2
Sinks	
surgeon's	3
flushing rim (with valve)	6
service (trap standard)	3
service (P trap)	2
pot, scullery, etc.	4

Table 10.3 Minimum Size of Nonintegral Traps

<i>Plumbing Fixture</i>	<i>Trap Size, in.</i>
Bathtub (with or without overhead shower)	1½
Bidet	1¼
Clothes washing machine standpipe	2
Combination sink and wash (laundry) tray	1½
Combination sink and wash (laundry) tray with food waste grinder unit*	1½
Combination kitchen sink, domestic, dishwasher, and food waste grinder	1½
Dental unit or cuspidor	1¼
Dental lavatory	1¼
Drinking fountain	1¼
Dishwasher, commercial	2
Dishwasher, domestic (nonintegral trap)	1½
Floor drain	2
Food waste grinder, commercial	2
Food waste grinder, domestic	1½
Kitchen sink, domestic, with food waste grinder unit	1½
Kitchen sink, domestic	1½
Kitchen sink, domestic, with dishwasher	1½
Lavatory, common	1¼
Lavatory (barber shop, beauty parlor or surgeon's)	1½
Lavatory, multiple type (wash fountain or wash sink)	1½
Laundry tray (1 or 2 compartments)	1½
Shower stall or drain	2
Sink (surgeon's)	1½
Sink flushing rim type (flush valve supplied)	3
Sink (service type with floor outlet trap standard)	3
Sink (service trap with P trap)	2
Sink, commercial (pot, scullery, or similar type)	2
Sink, commercial (with food grinder unit)	2


**Table 10.5 Building Drains and Sewers<sup>a</sup>**

Diameter of Pipe, in.	Maximum Number of Fixture Units That May Be Connected to Any Portion of the Building Drain or the Building Sewer			
	Slope per Foot			
	1/16 in.	1/8 in. 1 %	1/4 in. 2 %	1/2 in.
2			21	26
2 1/2			24	31
3			42 <sup>b</sup>	50 <sup>b</sup>
4		180	216	250
5		390	480	575
6		700	840	1000
8	1400	1600	1920	2300
10	2500	2900	3500	4200
12	2900	4600	5600	6700
15	7000	8300	10,000	12,000

**Table 10.7 Size and Length of Vents**

Size of Soil or Waste Stack, in.	Fixture Units Connected	Diameter of Vent Required, in.									
		1/4	1/2	2	2 1/2	3	4	5	6	8	
		Maximum Length of Vent, ft									
1 1/2	8	50	150								
2	12	30	75	200							
2	20	26	50	150							
2 1/2	42		30	100	300						
3	10		30	100	100	600					
3	30			60	200	500					
3	60			50	80	400					
4	100			35	100	260	1000				
4	200			30	90	250	900				
4	500			20	70	180	700				
5	200				35	80	350	1000			
5	500				30	70	300	900			
5	1100				20	50	200	700			
6	350					25	50	200	400	1300	
6	600					15	30	125	300	1100	
6	960						24	100	250	1000	
6	1900						20	70	200	700	
8	600							50	150	500	1300
8	1400							40	100	400	1200
8	2200							30	80	350	1100
8	3600							25	60	250	800
10	1000								75	125	1000
10	2500								50	100	500
10	3800								30	80	350
10	5600								25	60	250

Determine the proper size referring to following tables and reference figure (only for indication).



**A, B, C: Piping between outdoor unit and (first) refrigerant branch kit**

Choose from the following table in accordance with the outdoor unit total capacity type, connected downstream.

Outdoor unit capacity type (HP)	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
8	19.1	9.5
10	22.2	9.5
12-16	28.6	12.7
18-22	28.6	15.9
24	34.9	15.9
26-34	34.9	19.1
36-54	41.3	19.1

**D: Piping between refrigerant branch kits**

Choose from the following table in accordance with the indoor unit total capacity type, connected downstream. Do not let the connection piping exceed the refrigerant piping size chosen by the general system model name.

Indoor unit capacity index	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
<150	15.9	9.5
150<math>\leq</math>200	19.1	
200<math>\leq</math>290	22.2	12.7
290<math>\leq</math>420	28.6	
420<math>\leq</math>640	34.9	15.9
640<math>\leq</math>920	34.9	19.1
$\geq 920$	41.3	

**Example:**


- Downstream capacity for E=capacity index of unit 1
- Downstream capacity for D=capacity index of unit 1+capacity index of unit 2

**E: Piping between refrigerant branch kit and indoor unit**

Pipe size for direct connection to indoor unit must be the same as the connection size of the indoor unit (in case indoor unit is VRV DX indoor or Hydrobox).

Indoor unit capacity index	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
15-20	12.7	6.4
63-125	15.9	9.5
200	19.1	
250	22.2	

When the equivalent pipe length between outdoor and indoor units is 90 m or more, the size of the main pipes (both gas side and liquid side) must be increased. Depending on the length of the piping, the capacity may drop, but even in such a case it is possible to increase the size of the main pipes.



HP class	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
8	19.1 → 22.2	9.5 → 12.7
10	22.2 → 25.4 <sup>(a)</sup>	
12+14	28.6 <sup>(a)</sup>	12.7 → 15.9
16	28.6 → 31.8 <sup>(a)</sup>	
18-22		15.9 → 19.1
24	34.9 <sup>(a)</sup>	
26-34	34.9 → 38.1 <sup>(a)</sup>	19.1 → 22.2
36-54	41.3 <sup>(a)</sup>	

- (a) If size is NOT available, increase is NOT allowed.  
 (b) Increase is NOT allowed.

# VRV TABLES

Choose from the following table in accordance with the outdoor unit total capacity type, connected downstream.

Outdoor unit capacity type (HP)	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
8	19.1	9.5
10	22.2	9.5
12-16	28.6	12.7
18-22	28.6	15.9
24	34.9	15.9
26-34	34.9	19.1
36-54	41.3	19.1

**D: Piping between refrigerant branch kits**

Choose from the following table in accordance with the indoor unit total capacity type, connected downstream. Do not let the connection piping exceed the refrigerant piping size chosen by the general system model name.

Indoor unit capacity index	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
<150	15.9	9.5
150<math>\leq</math>200	19.1	
200<math>\leq</math>290	22.2	12.7
290<math>\leq</math>420	28.6	
420<math>\leq</math>640	34.9	15.9
640<math>\leq</math>920	34.9	19.1
$\geq 920$	41.3	

**Example:**

- Downstream capacity for E=capacity index of unit 1
- Downstream capacity for D=capacity index of unit 1+capacity index of unit 2

- a Main pipes  
 b Increase  
 c First refrigerant branch kit  
 d Indoor unit

HP class	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
8	19.1 → 22.2	9.5 → 12.7
10	22.2 → 25.4 <sup>(a)</sup>	
12+14	28.6 <sup>(a)</sup>	12.7 → 15.9
16	28.6 → 31.8 <sup>(a)</sup>	
18-22		15.9 → 19.1
24	34.9 <sup>(a)</sup>	
26-34	34.9 → 38.1 <sup>(a)</sup>	19.1 → 22.2
36-54	41.3 <sup>(a)</sup>	

- (a) If size is NOT available, increase is NOT allowed.  
 (b) Increase is NOT allowed.

The pipe thickness of the refrigerant piping shall comply with the applicable legislation. The minimal pipe thickness for R410A piping must be in accordance with the table below.

Pipe Ø (mm)	Minimal thickness t (mm)
8.4/9.5/12.7	0.80
15.9	0.90
19.1/22.2	0.80
28.6	0.99
34.9	1.21
41.3	1.43

In case the required pipe sizes (inch sizes) are not available, it is also allowed to use other diameters (mm sizes), taken the following into account:

- Select the pipe size nearest to the required size.
- Use the suitable adapters for the change-over from inch to mm pipes (field supply).
- The additional refrigerant calculation has to be adjusted as mentioned in 5.6.3 To determine the additional refrigerant amount on page 16.

## 4 Preparation

### F: Piping between refrigerant branch kit and BP unit

Pipe size for direct connection on BP unit must be based on the total capacity of the connected indoor units (only in case RA DX indoor units are connected).

Total capacity index of connected indoor units	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
20~62	12.7	6.4
63~149	15.9	9.5
150~208	19.1	

#### Example:

Downstream capacity for F=capacity index of unit 4+capacity index of unit 5

### G: Piping between BP unit and RA DX indoor unit

Only in case RA DX indoor units are connected.

Indoor unit capacity index	Piping outer diameter size (mm)	
	Gas pipe	Liquid pipe
20, 25, 30	9.5	6.4
50	12.7	
60		9.5
71	15.9	

#### 4.1.3 To select refrigerant branch kits

##### Refrigerant reflets

For piping example, refer to "4.1.2 To select the piping size" on page 7.

- When using reflet joints at the first branch counted from the outdoor unit side, choose from the following table in accordance with the capacity of the outdoor unit (example: reflet joint a).

Outdoor unit capacity type (HP)	2 pipes
8~10	KHRQ22M29T9
12~22	KHRQ22M54T
24~54	KHRQ22M75T

- For reflets joints other than the first branch (example reflet joint b), select the proper branch kit model based on the total capacity

### INFORMATION

Maximum 8 branches can be connected to a header.

- How to choose an outdoor multi connection piping kit. Choose from the following table in accordance with the number of outdoor units.

Number of outdoor units	Branch kit name
2	BHFQ22P1007
3	BHFQ22P1517

The RYYQ22~54 models, consisting of two or three RYMQ modules, require a 3-pipe system. There is an additional equalising pipe for such modules (in addition to the conventional gas and liquid piping). This equalising pipe does not exist for RYYQ5~20 or RXYQ5~54 units.

The equalising pipe connections for the different RYMQ modules are mentioned in below table.

RYMQ	Equalising pipe Ø (mm)
5	19.1
10~16	22.2
18~20	25.0


Deciding the equalising pipe diameter:

- In case of 3 multi units: the connection diameter of outdoor to T-joint has to be kept.
- In case of 2 multi units: the connection pipe has to have the largest diameter.

There is never a connection of the equalising pipe with the indoor units.

Example: (free multi combination)

RYMQ8+RYMQ12+RYMQ18. Largest connection is Ø28.6 (RYMQ18), Ø22.2 (RYMQ12) and Ø19.1 (RYMQ8). In figure below only equalising pipe is shown.



### INFORMATION

Reducers or T-joints are field supplied.

# VRV TABLES

#### 4.1.3 To select refrigerant branch kits

##### Refrigerant reflets

For piping example, refer to "4.1.2 To select the piping size" on page 7.

- When using reflet joints at the first branch counted from the outdoor unit side, choose from the following table in accordance with the capacity of the outdoor unit (example: reflet joint a).

Outdoor unit capacity type (HP)	2 pipes
8~10	KHRQ22M29T9
12~22	KHRQ22M54T
24~54	KHRQ22M75T

- For reflets joints other than the first branch (example reflet joint b), select the proper branch kit model based on the total capacity index of all indoor units connected after the refrigerant branch.

Indoor unit capacity index	2 pipes
<200	KHRQ22M20T
200≤<290	KHRQ22M29T9
290≤<640	KHRQ22M54T
≥640	KHRQ22M75T

- Concerning reflet headers, choose from the following table in accordance with the total capacity of all the indoor units connected below the reflet header.

Indoor unit capacity index	2 pipes
<200	KHRQ22M20H
200≤<290	
290≤<640	KHRQ22M54H*
≥640	KHRQ22M75H


(\*) If the pipe size above the reflet header is Ø34.3 or more, KHRQ22M75H is required.

largest diameter.

There is never a connection of the equalising pipe with the indoor units.

Example: (free multi combination)

RYMQ8+RYMQ12+RYMQ18. Largest connection is Ø28.6 (RYMQ18), Ø22.2 (RYMQ12) and Ø19.1 (RYMQ8). In figure below only equalising pipe is shown.



### INFORMATION

Reducers or T-joints are field supplied.

### NOTICE

Refrigerant branch kits can only be used with R410A.

## References

- [1] B. Stein, *Building Technology Mechanical and Electrical Systems*, John Wiley & sons, Canada, 1997.
- [2] J. F. Kreider, *Handbook of Heating, Ventilation, and Air Conditioning*, Boca Raton, CRC Press LLC, Florida, 2001.
- [3] M. A. A. M. A.Hammad, *Heating and Air Conditioning for Residential Buildings*, National Library Department, Jordan, 2007.
- [4] J. A. D. W. A.Beckman, *Solar Engineering of Thermal Processes*, John Wiley & Sons, 2006.

# Cataloge



## Five Key Features

- 1 Guaranteed quality: 12 year product warranty, 25 year linear performance warranty \*
- 2 Predictable output: Positive power sorting of 0 to + 5 W
- 3 Innovative solutions: Anti-reflecting coating for high sunlight absorption
- 4 Robust design: Module certified to withstand high snow loads, up to 5.4 kN/m<sup>2</sup> \*\*
- 5 Long term responsibility: Free module recycling in PV Cycle member countries

\* Please refer to Hanwha Solar Product Warranty for details.  
 \*\* Please refer to Hanwha Solar Module Installation Guide.

### Quality and Environmental Certificates

- ISO 9001 quality standards and ISO 14001 environmental standards
- OHSAS 18001 occupational health and safety standards
- IEC 61215 and IEC 61730 Class A certifications
- Conformity to CE



• Long term  
responsibility  
• Product integrity



### About Hanwha Solar

Hanwha Solar is a vertically integrated manufacturer of photovoltaic modules designed to meet the needs of the global energy consumer.

- High reliability, guaranteed quality, and excellent cost-efficiency due to vertically integrated production and control of the supply chain
- Optimization of product performance and manufacturing processes through a strong commitment to research and development
- Global presence throughout Europe, North America, and Asia, offering regional technical and sales support

# SF260 | Poly x-tra

## Electrical Characteristics

### Electrical Characteristics at Standard Test Conditions (STC)

Power Class	275 W	280 W	285 W	290 W	295 W	300W
Maximum Power ( $P_{max}$ )	275 W	280 W	285 W	290 W	295 W	300W
Open Circuit Voltage ( $V_{oc}$ )	44.1 V	44.3 V	44.5 V	44.7 V	44.9 V	45.0V
Short Circuit Current ( $I_{sc}$ )	8.35 A	8.40 A	8.45 A	8.50 A	8.55 A	8.60A
Voltage at Maximum Power ( $V_{mp}$ )	36.1 V	36.1 V	36.2 V	36.3 V	36.4 V	36.5V
Current at Maximum Power ( $I_{mp}$ )	7.62 A	7.76 A	7.87 A	7.99 A	8.11 A	8.22A
Module Efficiency (%)	14.0 %	14.3 %	14.5 %	14.7 %	15.0 %	15.2%
Cell Efficiency (%)	15.8 %	16.0 %	16.2 %	16.5 %	16.8 %	17.1%

$P_{max}$ ,  $V_{oc}$ ,  $I_{sc}$ ,  $V_{mp}$  and  $I_{mp}$  tested at STC defined as irradiance of 1000 W/m<sup>2</sup> at AM 1.5 solar spectrum and temperature 25 ± 2 °C.  
Electrical Characteristics: measurement tolerance of ± 3 %

### Electrical Characteristics at Normal Operating Cell Temperature (NOCT)

Power Class	275 W	280 W	285 W	290 W	295 W	300W
Maximum Power ( $P_{max}$ )	200 W	204 W	208 W	211 W	215 W	219W
Open Circuit Voltage ( $V_{oc}$ )	40.6 V	40.8 V	40.9 V	41.1 V	41.3 V	41.4V
Short Circuit Current ( $I_{sc}$ )	6.76 A	6.80 A	6.84 A	6.88 A	6.92 A	6.96A
Voltage at Maximum Power ( $V_{mp}$ )	32.8 V	32.9 V	33.0 V	33.1 V	33.2 V	33.3V
Current at Maximum Power ( $I_{mp}$ )	6.10 A	6.21 A	6.30 A	6.39 A	6.49 A	6.58A
Module Efficiency (%)	12.7 %	13.0 %	13.2 %	13.4 %	13.7 %	13.9%

$P_{max}$ ,  $V_{oc}$ ,  $I_{sc}$ ,  $V_{mp}$  and  $I_{mp}$  tested at NOCT defined as irradiance of 800 W/m<sup>2</sup>; wind speed 1 m/s.  
Electrical Characteristics: measurement tolerance of ± 3 %

### Temperature Characteristics

Normal Operating Cell Temperature (NOCT)	45 °C ± 3 °C
Temperature Coefficient of P	- 0.45 %/°C
Temperature Coefficient of V	- 0.32 %/°C
Temperature Coefficient of I	+ 0.04 %/°C

### Maximum Ratings

Maximum System Voltage	1000 V (IEC)
Series Fuse Rating	15 A
Maximum Reverse Current	Series fuse rating multiplied by 1.35

## Mechanical Characteristics

Dimensions	1966 mm × 1000 mm × 50 mm
Weight	26 kg
Frame	Aluminum alloy
Front	Tempered glass
Encapsulant	EVA
Back Cover	Composite sheet
Cell Technology	Polycrystalline
Cell Size	156 mm × 156 mm
Number of Cells (Pieces)	72 (6 × 12)
Junction Box	Protection class IP67 with bypass-diode
Output Cables	Solar cable: 4 mm <sup>2</sup> ; length 1200 mm
Connector	Linyang LY0706-2

## System Design

Operating Temperature	- 40 °C to 85 °C
Hail Safety Impact Velocity	25 mm at 23 m/s
Fire Safety Classification (IEC 61730)	Class C
Static Load/Wind/Snow	2400 Pa / 5400 Pa

## Packaging and Storage



Storage Temperature	- 40 °C to 85 °C
Packaging Configuration	20 pieces per pallet
Loading Capacity (40 ft. HQ Container)	440 pieces

### Nomenclature

Full product name:  
SF260-36-1Pxxx  
xxx represents the power class

### Performance at Low Irradiance:

The typical relative change in module efficiency at an irradiance of 200 W/m<sup>2</sup> in relation to 1000 W/m<sup>2</sup> (both at 25 °C and AM 1.5 spectrum) is less than 5 %.



OUTDOOR SYSTEM				RYQ221	RYQ241	RYQ261	RYQ281	RYQ301	RYQ321	RYQ341	RYQ361	RYQ381	RYQ401
System	Outdoor unit module 1			RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T	RYMQ10T
	Outdoor unit module 2			RYMQ12T	RYMQ12T	RYMQ16T	RYMQ16T	RYMQ16T	RYMQ16T	RYMQ16T	RYMQ16T	RYMQ16T	RYMQ16T
Capacity range			HP	22	24	26	28	30	32	34	36		
Cooling capacity	Nom.		kW	61.5	67.4	73.5	78.5	83.5	90.0	95.0	101.0		
				69.0	75.0	82.5	87.5	93.5	100.0	106.0	113.0		
Power input - 50Hz	Cooling	Nom.	kW	16.3	18.2	20.0	22.0	23.7	26.0	27.7	31.5		
	Heating	Nom.	kW	16.5	18.3	20.3	21.9	23.5	25.6	27.2	29.8		
EER				3.77	3.70	3.68	3.57	3.52	3.46	3.43	3.21		
ESEER				7.07 <sup>1)</sup>	6.81 <sup>1)</sup>	6.89 <sup>1)</sup>	6.69 <sup>1)</sup>	6.60 <sup>1)</sup>	6.50 <sup>1)</sup>	6.44 <sup>1)</sup>	6.02 <sup>1)</sup>		
COP				4.18	4.10	4.06	4.00	3.98	3.91	3.90	3.79		
Maximum number of connectable indoor units				64 <sup>2)</sup>									
Piping connections	Liquid	OD	mm	15.9				19.1					
				28.6				41.3					
	Piping length	OU - IU	Max.	m	165 <sup>3)</sup>								
					1,000 <sup>3)</sup>								
	Level difference	OU - IU	m	90° Outdoor unit in highest position / 90° Indoor unit in highest position									
Current - 50Hz	Maximum fuse amps (MFA)			63				80					

1) The AUTOMATIC ESEER value compares with normal 50V/50Hz Heat Pump operation, taking into account advanced energy saving operation functionality (variable refrigerant temperature control operation) 2) Actual number of connectable indoor units depends on the indoor unit type (VRV indoor, Hydrobox, RA indoor, etc.) and the connection cable selection for the system (30% or 120%) 3) Refer to technical specifications for more detail

OUTDOOR SYSTEM				RYQ38T	RYQ40T	RYQ42T	RYQ44T	RYQ46T	RYQ48T	RYQ50T	RYQ52T	RYQ54T	RYQ56T
System	Outdoor unit module 1			RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T
	Outdoor unit module 2			RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T	RYMQ18T
	Outdoor unit module 3			RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T	RYMQ20T
Capacity range			HP	38	40	42	44	46	48	50	52	54	
Cooling capacity	Nom.		kW	106.0	112.0	118.0	124.0	130.0	135.0	140.0	145.0	150.0	
				120.0	125.0	132.0	138.0	145.0	150.0	156.0	162.0	168.0	
Power input - 50Hz	Cooling	Nom.	kW	31.0			33.3	35.0	37.0	39.0	40.7	42.4	44.1
	Heating	Nom.	kW	29.9	30.9	33.0	34.7	36.8	38.4	40.0	41.6	43.2	
EER				3.42	3.61	3.54		3.51	3.46	3.44	3.42	3.40	
ESEER				6.36 <sup>1)</sup>	6.74 <sup>1)</sup>	6.65 <sup>1)</sup>	6.62 <sup>1)</sup>	6.60 <sup>1)</sup>	6.50 <sup>1)</sup>	6.46 <sup>1)</sup>	6.42 <sup>1)</sup>	6.38 <sup>1)</sup>	
COP				4.01	4.05	4.00	3.98	3.94	3.91	3.90	3.89	3.89	
Maximum number of connectable indoor units				64 <sup>2)</sup>									
Piping connections	Liquid	OD	mm	15.9				19.1					
				28.6				41.3					
	Piping length	OU - IU	Max.	m	165 <sup>3)</sup>								
					1,000 <sup>3)</sup>								
	Level difference	OU - IU	m	90° Outdoor unit in highest position / 90° Indoor unit in highest position									
Current - 50Hz	Maximum fuse amps (MFA)			100				125					

# FXFQ-A

# Round flow cassette



FXFQ 20-63A



BRC VLS2AVB BRC VLS3ZF




- > The round flow cassette provides a more comfortable environment and offers greater savings in energy consumption to shop, office and restaurant owners
- > 360° air discharge ensures uniform air flow and temperature distribution
- > Modern style decoration panel is available in 3 different variations: pure white (RAL9010) auto cleaning panel, pure white (RAL9010) standard panel with grey louvers and pure white (RAL9010) standard panel with white louvers
- > Daikin introduces first auto cleaning cassette to European market.
- > Higher efficiency and comfort thanks to daily auto cleaning of the filter
- > Lower maintenance costs thanks to auto cleaning function.
- > Easy dust removal with vacuum cleaner without opening the unit.
- > The presence sensor (optional) adjusts the set point with standard 1°C if no one is detected in the room, it is possible to adjust the set point with 2, 3 or 4°C (optional). It also automatically directs air flow away from any person to avoid draught.
- > The floor sensor (optional) detects the average floor temperature and ensures even temperature distribution between ceiling and floor. Gold feet will become history
- > Individual flap control: one or more flaps can be easily closed via the wired remote controller (BRC ES2) in case you would refurbish or rearrange your interior
- > Low energy consumption thanks to specially developed small tube heat exchanger, DC fan motor and drain pump
- > Fresh air intake: up to 20 %
- > Low installation height: 214mm for class 20-63
- > Standard drain pump with 850mm lift



INDOOR UNIT			FXFQ20A	FXFQ25A	FXFQ32A	FXFQ40A	FXFQ50A	FXFQ63A	FXFQ80A	FXFQ100A	FXFQ125A		
Cooling capacity	Nom.	kW	2.2	2.8	3.6	4.5	5.6	7.1	9.0	11.2	14.0		
Heating capacity	Nom.	kW	2.5	3.2	4.0	5.0	6.3	8.0	10.0	12.5	16.0		
Power input - 50Hz	Cooling	Nom.	0.038			0.053			0.061	0.092	0.115	0.186	
	Heating	Nom.	0.038			0.053			0.061	0.092	0.115	0.186	
Dimensions	Unit	Height/Width/Depth	mm						244x910x94		286x1064		
Weight	Unit	kg	19			20		21		24		26	
Decoration panel 1	Model		BYCQ140D7W1										
	Colour		Pure White (RAL 9010)										
	Dimensions	Height/Width/Depth	mm										
	Weight	kg	60x930x950										
Decoration panel 2	Model		BYCQ140D7W1W										
	Colour		Pure White (RAL 9010)										
	Dimensions	Height/Width/Depth	mm										
	Weight	kg	60x930x950										
Decoration panel 3	Model		BYCQ140D7GW1										
	Colour		Pure White (RAL 9010)										
	Dimensions	Height/Width/Depth	mm										
	Weight	kg	145x910x950										
Fan Air flow rate - 50Hz	Cooling	High/Nom./Low	m <sup>3</sup> /min			13.6/11.6/9.5			15.0/12.9/10.5			16.5/13.5/10.5	
	Heating	High/Nom./Low	m <sup>3</sup> /min			13.6/11.6/9.5			15.0/12.9/10.5			16.5/13.5/10.5	
Sound power level	Cooling	High/Nom.	dB(A)			45/-			51/-			53/-	
Sound pressure level	Cooling	High/Nom./Low	dB(A)			31.0/29/28			33.0/31/29			35/33/30	
	Heating	High/Nom./Low	dB(A)			31.0/29/28			33.0/31/29			35/33/30	
Refrigerant	Type		R410A										
Piping connections	Liquid/OD/Gas/OD/Drain	mm	6.35/12.7/19.25 (O.D. 52/1.D. 25)						9.52/15.9/19.25 (O.D. 52/1.D. 25)				
Power supply	Phase/Frequency/Voltage	Hz/V	1~/50/60/220-240/230										
Current - 50Hz	Maximum fuse amps (MFA)	A	16										


BYCQ140D7W1 = pure white panel with grey louvers, BYCQ140D7W1W = pure white standard panel with the louvers, BYCQ140D7GW1 = pure white auto cleaning panel. The BYCQ140D7W1W white louvers are informed that formation of dirt on white material is very average. Therefore consequently not advised to install the decoration panel in environments exposed to concentrations of dirt.

# ESK Koala Oil/Water Separator



ESK Model	Max. Flow (gpm)	Structure ID (in)	Sump Depth (in)	Inlet Min Cover Depth (in)	Outlet Min Cover Depth (in)	Outlet Pipe OD Dia (in)	Total Volume (gal)	Oil Storage Volume (Gal)
1.5	24	48	32	19	20	6	251	72
3	48	48	32	19	20	6	251	72
6	95	48	32	19	20	6	251	72
10	159	48	32	19	20	6	251	72
15	238	48	38	24	25	8	298	133
20	317	48	38	24	25	8	298	133
30	476	60	48	26	27	12	588	269
40	634	60	48	26	27	12	588	269
50	793	72	68	25	26	12	1199	426
65	1030	72	68	25	26	12	1199	426
80	1268	72	68	25	26	12	1199	426
100	1585	96	68	25	26	12	2131	758
110	1744	96	78	36	37	16	2444	988
120	1902	96	78	36	37	16	2444	988
130	2061	96	78	36	37	16	2444	988
140	2219	96	78	36	37	16	2444	988
150	2378	96	78	36	37	16	2444	988
160	2536	96	78	36	37	16	2444	988
170	2695	96	78	36	37	16	2444	988
180	2853	96	78	36	37	16	2444	988
190	3012	96	78	36	37	16	2444	988
200	3170	96	78	36	37	16	2444	988
225	3566	120	88	37	38	20	4308	2144
250	3963	120	88	37	38	20	4308	2144
275	4359	120	88	37	38	20	4308	2144
300	4755	120	88	37	38	20	4308	2144

**VORTICE® LINEO**



Lineo series extractors have certified air flow, pressure (to UNI 10531/1995), corresponding to ISO 8804) and noise levels (UNI EN ISO 2741). Certification of these parameters guarantees that our products will always meet the your requirements and expectations.

- Compact overall dimensions. The products have a very small overall size, making them ideal for installation in cramped areas. Their air powerful flow control diameter is only slightly larger than the extraction duct's diameter.
- Protection rating IP44. The products are protected against jets of water from all directions, making them ideal for installation in humid and wet areas.
- Two speeds. All models feature two speed operation, including timer equipped models.
- Adjustable Timer. Most Lineo products are also available with an adjustable timer from 2 to 30 minutes, custom timer.
- Double insulation. No-start is required.
- Self-ventinging IP3 plastic. All models are constructed in VS grade plastic to guarantee the highest available self-venting rating as well as excellent mechanical strength.
- Extra-tightly. All Lineo components can be easily disassembled and are designed to be recyclable and comply with the requirements of Article 4 of the "REUSE" directive (simple electrical and electronic equipment). The products are

carefully designed to provide an advanced life cycle and to provide a low environmental impact both in manufacture and use.

- Speed Adjustable. All models, except timer models, can be speed adjusted with the optional electronic speed controller. Intelligent Vortice Lineo products are capable of advanced functionality in combination with optional sensor units for monitoring humidity, detecting perspiration, ambient temperature, reduced levels and air quality.
- The entire Lineo range is fitted with ball bearing motors for a minimum 30,000 hours operation without mechanical maintenance.
- Safe. Safety power rating protection rating (PFA) is EN 60335 and insulation are certified by the IEC Quality Mark Institute, the Italian national certifying agency.
- Optimum energy efficiency. Our research programmes have enabled us to obtain the best possible ratio between running costs and performance.
- Lineo ES are fitted by an electronically controlled (EC) brushless motor, especially designed to maximize the product efficiency minimizing its power consumption and noise emissions.
- Quietest production. The top of the range models feature a manual noise limiter on the motor. Other models are equipped with thermal cut-off switch.
- Compliance to standards. The entire range of Vortice Lineo extractors has been constructed to comply with CEI EN 60335-1-99 1997 Performance standards to LVD 1992/90/EEC Category II, they bear the CE Mark for compliance with the Low Voltage Directive (LVD) and Electromagnetic Compatibility Directive (EMC).


Wiring diagrams shown on page 82/83.

**LONG LIFE 30.000 h**



- Quick, easy installation. The mounting brackets supplied with the unit make installation quick and easy. The junction box can be fitted to fit the mounting panel for even simpler installation. Mounting tools included.
- Simple maintenance. Lineo products are equipped with a unique double-throw circuit which allows the fan unit to be removed in just a few seconds without affecting the installation as a whole. Instructions clearly show that correct effort to be exerted in installation. Re-fitting the unit is just as quick and easy.

**Dimensions (mm)**



Model	Code	Ø	H	Ø1	Ø2	Ø3	Ø4	Ø5	Ø6	Ø7	Ø8	Ø9	Ø10
Lineo 100 G VS	17090	100	40	82	116	130	80	104	120				
Lineo 100 Q T VS	17092	100	40	82	116	130	80	104	120				
Lineo 125 VS T VS	17091	125	40	101	131	145	80	104	120				
Lineo 125 VS T VS	17093	125	40	101	131	145	80	104	120				
Lineo 150 VS T VS	17094	150	40	112	144	158	80	104	120				
Lineo 150 VS T VS	17095	150	40	112	144	158	80	104	120				
Lineo 180 VS T VS	17096	180	40	124	156	170	80	104	120				
Lineo 180 VS T VS	17097	180	40	124	156	170	80	104	120				
Lineo 200 VS VS	17098	200	40	136	168	182	80	104	120				
Lineo 200 VS T VS	17099	200	40	136	168	182	80	104	120				
Lineo 250 VS VS	17100	250	40	152	184	198	80	104	120				
Lineo 250 VS VS	17101	250	40	152	184	198	80	104	120				



**SAFETY GUARANTEED AND CERTIFIED**

The IMQ mark certifies that the product is manufactured in compliance with the provisions of established safety standards EN 60335-1 and EN 60335-2-95, the Low Voltage Directive (LVD) and the Electromagnetic Compatibility Directive (EMC). IMQ further guarantees regular constant production quality monitoring.

The IMQ mark is equivalent to the following European marks:



Model	1903 8801				1903 8802				Temperature class
	air flow	Pa	air flow	Pa	air flow	Pa	air flow	Pa	
Lineo 100 G VS	200	40	100	15.0	100	15.0	100	15.0	40
Lineo 100 Q T VS	200	40	100	15.0	100	15.0	100	15.0	40
Lineo 125 VS	250	40	125	15.0	125	15.0	125	15.0	40
Lineo 125 T VS	250	40	125	15.0	125	15.0	125	15.0	40
Lineo 150 VS	300	40	150	15.0	150	15.0	150	15.0	40
Lineo 150 T VS	300	40	150	15.0	150	15.0	150	15.0	40
Lineo 180 VS	350	40	180	15.0	180	15.0	180	15.0	40
Lineo 180 T VS	350	40	180	15.0	180	15.0	180	15.0	40
Lineo 200 VS - 0.18	400	40	200	15.0	200	15.0	200	15.0	40
Lineo 200 T VS	400	40	200	15.0	200	15.0	200	15.0	40
Lineo 250 VS	450	40	250	15.0	250	15.0	250	15.0	40
Lineo 250 T VS	450	40	250	15.0	250	15.0	250	15.0	40






**PERFORMANCE AND SILENCE GUARANTEED AND CERTIFIED BY IMQ PERFORMANCE**

IMQ PERFORMANCE is an independent quality mark which certifies, to international standards\*, the performance (flow rate and pressure) and noise levels of the product.

Model	1903 8801				1903 8802				ISO 8804/EN 12454-1:1999
	air flow	Pa	air flow	Pa	air flow	Pa	air flow	Pa	
Lineo 100 G VS	190	42.1	80	15.0	80	15.0	7.5	75.0	35.0
Lineo 100 Q T VS	190	42.1	80	15.0	80	15.0	7.5	75.0	35.0
Lineo 125 VS	230	40.0	100	15.0	100	15.0	10.0	100.0	35.0
Lineo 125 T VS	230	40.0	100	15.0	100	15.0	10.0	100.0	35.0
Lineo 150 VS	270	38.0	120	15.0	120	15.0	12.0	120.0	35.0
Lineo 150 T VS	270	38.0	120	15.0	120	15.0	12.0	120.0	35.0
Lineo 180 VS	310	36.0	140	15.0	140	15.0	14.0	140.0	35.0
Lineo 180 T VS	310	36.0	140	15.0	140	15.0	14.0	140.0	35.0
Lineo 200 VS - 0.18	350	34.0	160	15.0	160	15.0	16.0	160.0	35.0
Lineo 200 T VS	350	34.0	160	15.0	160	15.0	16.0	160.0	35.0



Vortice Lineo extractors can be installed in a wide range of places: at the beginning, middle or end of the duct and horizontally, vertically, against walls, ceiling, into ceiling or the surface. One of the main features of the new Vortice Lineo range is, in addition to ease of installation, is the fact that the fan unit can be removed from the duct in a few seconds without affecting the installation as a whole. Instructions clearly show that correct effort to be exerted in installation. Re-fitting the unit is just as quick and easy.



**KING GIANT**



**INDUSTRY  
CENTRIFUGAL PUMP**

**Model**

**CMI Series**



CMI

**CONSTRUCTION:**

PUMP Centrifugal - Big Capacity

Pump Body: Cast Iron

Impeller: Brass / Cast Iron

Mechanical Seal: Carbon / Ceramic / Stainless steel

MOTOR Single Phase Heavy Duty Continuous Work

Motor Housing: Aluminium

Shaft: Carbon Steel / Stainless Steel

Insulation: Class B / Class F

Protection: IP44 / IP54

Cooling: External ventilation



**USES** - Monobloc horizontal centrifugal pumps, constructed to EN 733 standards, widely used in water supplies, pressurisation and fire-fighting systems, standard supply with counter-flange.

Main application: household water pumping, circulation and domestic power boosting.

High building water supplying boosting.

Industry water supplying circulating boosting.





Feeling assembly




DIMENSIONS (mm)				
DN	D	X	holes	
			r <sup>1</sup>	r <sup>2</sup>
32	140	100	4	18
40	150	110	4	18
50	165	125	4	18
65	185	145	4	18
80	200	160	4	18
100	220	180	6	18

INSTALLATION DIMENSION

TYPE	DIMENSIONS (mm)																	K <sub>2</sub>	
	DNm	DNa	A	F	H	H1	H2	N	N1	H2	W	W1	W2	W3	S	I	L		M
CMI 50-125 A	50	65	100	525	292	132	165	250	190	240	100	70	50	12	14	520	290	355	50
CMI 50-160 B	50	65	100	590	340	150	180	270	212	265	100	70	50	12	14	615	310	480	65
CMI 50-160 A	50	65	100	590	340	150	180	270	212	265	100	70	50	12	14	615	310	480	71
CMI 65-125 B	65	80	100	605	340	160	180	280	212	260	125	95	65	14	14	615	310	480	64
CMI 65-125 A	65	80	100	605	340	160	180	260	212	260	125	95	65	14	14	615	310	480	70
CMI 65-160 B	65	80	100	635	360	160	200	290	212	280	125	95	65	14	14	665	335	535	90
CMI 80-160 D	80	100	125	665	405	180	225	330	250	320	125	95	65	14	14	665	335	535	98,5
CMI 80-160 C	80	100	125	735	405	180	225	330	250	320	125	95	65	14	14	735	365	535	129
CMI 80-160 B	80	100	125	790	405	180	225	330	250	320	125	95	65	14	14	815	365	535	143

Fire fighting units with horizontal pumps back pull-out type, made according to standard EN 12845


1 Electric main pump + 1 Diesel main motorpump + 1 jockey pump  
"EDP" Series



Fire fighting unit, according to standard EN 12845, consists of: 1 electric main pump + 1 diesel main motorpump + 1 jockey pump.

Fire fighting units with horizontal pumps back pull-out type, made according to standard EN 12845

1 Electric main pump + 1 Diesel main motorpump + 1 jockey pump  
"EDP" Series



Details with capacity from m³/h 8 up to m³/h 50

Model	Motor	Discharge (m³/h)	CAPACITY OF MAIN MOTORPUMP															
			8	10	12	15	18	20	22	25	28	30	32	35	38	40	45	
76100	EP-LS-20000-10	1000	10	12	15	18	20	22	25	28	30	32	35	38	40	45		
76101	EP-LS-20000-12	1200	12	15	18	20	22	25	28	30	32	35	38	40	45			
76102	EP-LS-20000-15	1500	15	18	20	22	25	28	30	32	35	38	40	45				
76103	EP-LS-20000-18	1800	18	20	22	25	28	30	32	35	38	40	45					
76104	EP-LS-20000-20	2000	20	22	25	28	30	32	35	38	40	45						
76105	EP-LS-20000-22	2200	22	25	28	30	32	35	38	40	45							
76106	EP-LS-20000-25	2500	25	28	30	32	35	38	40	45								
76107	EP-LS-20000-28	2800	28	30	32	35	38	40	45									
76108	EP-LS-20000-30	3000	30	32	35	38	40	45										
76109	EP-LS-20000-32	3200	32	35	38	40	45											
76110	EP-LS-20000-35	3500	35	38	40	45												
76111	EP-LS-20000-38	3800	38	40	45													
76112	EP-LS-20000-40	4000	40	45														
76113	EP-LS-20000-45	4500	45															
76114	EP-LS-20000-50	5000	50															

**SPLASHPROOF AXIAL EXTRACT FANS USED TO EXTRACT AIR EITHER DIRECTLY TO THE OUTSIDE OR INTO DUCTING UP TO 4m LONG**

**VORTICE® PUNTO RANGE**



• For intermittent or continuous ventilation of bathrooms, toilets, kitchens or utility rooms in domestic or commercial properties.

• 52 models available with or without the option of automatic shutters, timer, pull cord, humidistat, electronic microprocessor and Passive Infrared.

• Motor with shielded poles, either with bronze or ball bearings, and with thermal cut-out.

• The standard models can be speed regulated.

- Data and performance MQ Performance certified.
- High airflow rate, low operating noise level and low power consumption due to the wing profile blades and motor support.
- IP44 splashproof protection on all models.
- Motor support and grille made of anti-UV ABS.
- Available in three outer sizes: Ø 100, 120 and 150 mm.
- Conforms to the following standards: CEI EN 60335-2-80 (Part 2: Particular requirements for fans), CEI EN 60529 (Code IP) and CEI 107-531986.

Design: F. Trabucco & Associates


**Accessories**  
(Description and data on page 25)

Wiring diagrams shown on page 100/1.



- Installation showing extract directly to the outside.
- Ceiling installation on up to 4m duct.
- Through the wall installation with wall sleeve and grille.
- Window installation with standard window kit.

**Dimensions (mm)**



	A	B	C	D	Ø E
<b>M 100/4"</b>	108	160	100	47	30
<b>M 120/5"</b>	179	161	110	47	119
<b>M 150/6"</b>	214	210	117	47	156

Product	V - 50 Hz	W	A	Rpm	Delivery				P max	Lp dB(A) 2 m	Approvals	kg	Insulation	IP	°C max
					g/s	g	l/h	l							
<b>M 100/4"</b>	230-240	18	0.1	2300	80	25	3	28	37.5	CE, ENEC	0.6	U18	A4	50	
<b>M 120/5"</b>	230-240	26	0.12	2100	175	49.8	4.5	44	39.5	CE, ENEC	0.8	U18	A4	50	
<b>M 150/6"</b>	230-240	30	0.15	2100	300	85.1	6	58	46	CE, ENEC	1.1	U18	A4	50	



**Fire Cabinet SP 300**

Cabinets made of steel.  
 Rubber hose of 30 meter available in manual and automatic models.  
 Available in different sizes & design to meet architectural requirements.

**Fire Cabinet SP 300M**

New design from OFFICO.  
 Cabinets made of steel.  
 Available in manual and automatic models.

**Fire Cabinet SP 300S**

Cabinets made of stainless steel no 304  
 Manual and automatic models.  
 Available in different sizes & design.  
 Cabinets in stainless steel with hairline or mirror finish available on request.

**Fire Cabinet SP 600**

Available in manual and automatic models.  
 Two door steel cabinets, one is equipped with foam neat and the other with fire extinguisher.

**Fire Cabinet SP 600S**

Similar to SP600 but in stainless steel.  
 Available in manual and automatic models.  
 Cabinets in stainless steel with hairline or mirror finish available on request.

Optional: Dry Beer, Fire blanket or Fire axe can be fitted in place of extinguisher in SP600 / SP600S.

MODEL	INSIDE DIMENSIONS			WALL OPENING SIZE		
	Width (mm)	Height (mm)	Depth (mm)	Width (mm)	Height (mm)	Depth (mm)
SP 300	600	600	250	610	610	260
SP 300A	600	600	250	610	610	260
SP 300M	600	600	250	610	610	260
SP 300S	700	700	250	710	710	260
SP 300M	700	700	250	710	710	260
SP 300S	700	700	250	710	710	260
SP 300M	700	700	250	710	710	260
SP 600	1010	600	250	1020	600	260
SP 600A	1010	600	250	1020	600	260
SP 600M	1010	600	250	1020	600	260

MODEL	INSIDE DIMENSIONS		
	Width (mm)	Height (mm)	Depth (mm)
SP 600M	700	700	260

Note: All dimensions in mm.